

Example of Stage 2 DBP Compliance Determination LRAA Calculation for TTHM

Quarterly Monitoring Results for Sample Site $(Q1 + Q2 + Q3 + Q4) \div 4$			
Date	TTHM (mg/L)	LRAA (mg/L)	Violation? YES, if LRAA > MCL MCL for TTHM = 0.080 mg/L
11/14/2013	0.096	$(0.096 + 0 + 0 + 0) \div 4 = 0.024$	NO
2/15/2014	0.072	$(0.096 + 0.072 + 0 + 0) \div 4 = 0.042$	NO
5/12/2014	0.060	$(0.096 + 0.072 + 0.060 + 0) \div 4 = 0.057$	NO
8/16/2014	0.088	$(0.096 + 0.072 + 0.060 + 0.088) \div 4 = 0.079$	NO
11/12/2014	0.120	$(0.072 + 0.060 + 0.088 + 0.120) \div 4 = 0.085$	YES