

USE TYPEWRITER OR BALL POINT PEN

State of Idaho Department of Water Administration

WELL DRILLER'S REPORT

ENT'D

RECORDED

State law requires that this report be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

*Carson*

**1. WELL OWNER**  
 Name EAST GREENACRES IRRIGATION DIST  
 Address RT 1 Box 116 Post Falls IDA.  
 Owner's Permit No. 95-7055 (AIR. REG.)

**7. WATER LEVEL**  
 Static water level 160 feet below land surface  
 Flowing?  Yes  No G.P.M. flow \_\_\_\_\_  
 Temperature 48 ° F. Quality GOOD  
 Artesian closed-in pressure \_\_\_\_\_ p.s.i.  
 Controlled by  Valve  Cap  Plug

**2. NATURE OF WORK** 95-71-N-71  
 New well  Deepened  Replacement  
 Abandoned (describe method of abandoning)

**8. WELL TEST DATA** NO TEST MADE  
 Pump  Bailer  Other

Discharge G.P.M.	Draw Down	Hours Pumped

**3. PROPOSED USE**  
 Domestic  Irrigation  Test  
 Municipal  Industrial  Stock

**4. METHOD DRILLED**  
 Cable  Rotary  Dug  Other

**5. WELL CONSTRUCTION**  
 Diameter of hole 20 inches Total depth 230 feet  
 Casing schedule:  Steel  Concrete  

Thickness	Diameter	From	To
<u>.375</u> inches	<u>20</u> inches	<u>+ 2</u> feet	<u>201</u> feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet
_____ inches	_____ inches	_____ feet	_____ feet


 Was a packer or seal used?  Yes  No  
 Perforated?  Yes  No  
 How perforated?  Factory  Knife  Torch  
 Size of perforation \_\_\_\_\_ inches by \_\_\_\_\_ inches  

Number	From	To
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet
_____ perforations	_____ feet	_____ feet

 Well screen installed?  Yes  No  
 Manufacturer's name U.O.P JOHNSON  
 Type TELESCOPE Model No. IRRIGATOR  
 Diameter 18 Slot size 18 Set from 200 feet to 210 feet  
 Diameter 18 Slot size 150 Set from 210 feet to 215 feet  
18 125 215 230  
 Gravel packed?  Yes  No Size of gravel \_\_\_\_\_  
 Placed from \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface seal?  Yes  No To what depth 20 feet  
 Material used in seal  Cement grout  Puddling clay

**9. LITHOLOGIC LOG**

Hole Diam.	Depth		Material	Water	
	From	To		Yes	No
20"	0	20	GRAVEL 3" MINUS		X
20"	20	28	BOULDER		X
20"	28	38	GRAVEL + BOULDERS		X
20"	38	114	GRAVEL 4" MINUS		X
20"	114	165	GRAVEL 2" MINUS		X
20"	165	210	GRAVEL 2" MINUS		X
20"	210	230	GRAVEL + SAND 1" MINUS		X

**6. LOCATION OF WELL**  
 Sketch map location must agree with written location.  
  
 County KOOTENAI  
1/4 W 1/4 SW 1/4 Sec. 28, T. 51 N, R. 5 E

**10.** Work started MAY 24 1971 finished JUNE 28 1971

**11. DRILLER'S CERTIFICATION**  
 This well was drilled under my supervision and this report is true to the best of my knowledge.  
HOLMAN DRILLING CORP 108  
 Driller's or Firm's Name Number  
E 3410 9TH AVE SPOKANE W.N.  
 Address  
Arnold E Holman July 8 1971  
 Signed By Date

007121