

REPORT OF WELL DRILLER  
State of Idaho



RECEIVED

MAR 29 1968

State law requires that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well. Department of Reclamation

WELL OWNER:  
Name CITY OF ATHOL  
Address ATHOL IDAHO  
96-68-N-2  
Owner's Permit No. 96-7021  
NATURE OF WORK (check): Replacement well   
New well  Deepened  Abandoned   
Water is to be used for: MUNICIPAL  
METHOD OF CONSTRUCTION: Rotary  Cable   
Dug  Other

(explain)  
CASING SCHEDULE: Threaded  Welded   
12"Diam. from 12 ft. to 391.8 ft.  
"Diam. from        ft. to        ft.  
"Diam. from        ft. to        ft.  
"Diam. from        ft. to        ft.  
Thickness of casing: 330 Material:  
Steel  concrete  wood  other

(explain)  
PERFORATED? Yes  No  Type of perforator used:       


Size of perforations: " by "  
perforations from        ft. to        ft.  
WAS SCREEN INSTALLED? Yes  No

Manufacturer's name JOHNSON  
Type STAINLESS Model No. TELESCOPE  
Diam. 12" Slot size 110 Set from 390 ft. to 410 ft.  
Diam.        Slot size        Set from        ft. to        ft.

CONSTRUCTION: Well gravel packed? Yes   
No.  size of gravel        Gravel placed from        ft. to        ft. Surface seal provided? Yes  No  To what depth?        ft. Material used in seal: BENTONITE  
SLURRY 20 TO 100 FT CEMENT GRAVEL 10 TO 20 FT  
Did any strata contain unusable water? Yes   
No.  Type of water:         
Depth of strata        ft. Method of sealing strata off:       

Surface casing used? Yes  No   
Cemented in place? Yes  No

Locate well in section



LOCATION OF WELL: County MOOTENAI  
SE 1/4 SW 1/4 Sec. 9 T. 53N R. 3 E

Size of drilled hole: 12" Total  
depth of well: 410 Standing water level below ground: 391.6 Temp. Fahr. 45° Test delivery: 1000 gpm or        cfs Pump?  Bail   
Size of pump and motor used to make test: 8 1/2" BOWLS 450 H.P. ENGINES  
Length of time of test: 8 Hrs. Min.  
Drawdown: 3.6 ft. Artesian pressure: ft. above land surface Give flow        cfs or        gpm. Shutoff pressure:         
Controlled by: Valve  Cap  Plug   
No control  Does well leak around casing? Yes  No

DEPTH		MATERIAL	WATER YES OR NO
FROM	TO		
FEET	FEET		
0	43	GRAVEL 2" MINUS	NO
43	91	GRAVEL + BOULDERS TO 18"	NO
91	128	GRAVEL 1" MINUS	NO
128	131	BOULDERS	NO
131	290	GRAVEL 2" MINUS	NO
290	306	GRAVEL + BOULDERS	NO
306	330	GRAVEL 1" MINUS	NO
330	344	GRAVEL 1" MINUS CEMENTED	NO
344	350	BOULDERS	NO
350	365	GRAVEL 1/2" MINUS CEMENTED	YES
365	389	GRAVEL 1/2" MINUS	YES
389	395	GRAVEL 1/2" MINUS LOOSE	YES
395	402	BOULDERS + GRAVEL 2" MINUS	YES
402	410	GRAVEL 1/2" MINUS	YES

Work started: NOV 30 1967  
Work finished: FEB 13 1968  
Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.  
Name: HOLMAN DRILLING CORP.  
Address: E 340 9TH SPARANE WLD.  
Signed by: Ronald E. Holman PRES  
License No. 108 Date: MARCH 14 1968

Use other side for additional remarks

USGS