ENT'D

REPORT OF WELL [illegible]
State of [illegible]

RECEIVED
AUG 4 1967
Department of Reclamation

State law requires that this report shall be filed with the [illegible] Reclamation Engineer within 30 days after completion or abandonment of [illegible]

WELL OWNER:
Name HAUSER LAKE WATER ASSOC. INC.
Address HAUSER LAKE ~~[illegible]~~ IDAHO
95-67-N-27
Owner's Permit No. G 33090
NATURE OF WORK (check): Replacement well [ ]
New well [X] Deepened [ ] Abandoned [ ]
Water is to be used for: MUNICIPAL
METHOD OF CONSTRUCTION: Rotary [ ] Cable [X]
Dug [ ] Other _____
(explain)
CASING SCHEDULE: Threaded [ ] Welded [ ]
12 "Diam. from +2 ft. to 191 ft.
____ "Diam. from ____ ft. to ____ ft.
____ "Diam. from ____ ft. to ____ ft.
____ "Diam. from ____ ft. to ____ ft.
Thickness of casing: .330 Material:
Steel [X] concrete [ ] wood [ ] other [ ]
(explain)
PERFORATED? Yes [ ] No [X] Type of perforator used: _____
Size of perforations ____ " by ____ "
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
____ perforations from ____ ft. to ____ ft.
WAS SCREEN INSTALLED? Yes [X] No [ ]
Manufacturer's name JOHNSON
Type STAINLESS STEEL Model No. 12" STANDARD
Diam. 12 Slot size 90 Set from 188 ft. to 198 ft.
Diam. 12 Slot size 50 Set from 198 ft. to 208 ft.
CONSTRUCTION: Well gravel packed? Yes [ ]
No. [X] size of gravel _____ Gravel placed from ____ ft. to ____ ft. Surface seal provided? Yes [X] No [ ] To what depth? 35 ft. Material used in seal: SURFACE - 10FT CEMENT 10FT - 35FT BENTONITE SLURRY
Did any strata contain unusable water? Yes [ ]
No. [X] Type of water: _____
Depth of strata _____ ft. Method of sealing strata off: _____
Surface casing used? Yes [X] No. [ ]
Cemented in place? Yes [ ] No [X]
Locate well in section

Size of drilled hole 12" Total depth of well 208 Standing water level below ground: 140 Temp. Tahu. 51 ° Test delivery: 1000 gpm or ____ cfs Pump: [X] Bail [ ]
Size of pump and motor used to make test: 10"x8" TEST PUMP 450 H.P. Diesel Engines
Length of time of test: 8 Hrs. ____ Min.
Drawdown 7 ft. Artesian pressure: ft. above land surface ____ Give flow ____ cfs or ____ gpm. Shutoff pressure: _____
Controlled by: Valve [ ] Cap [X] Plug [ ]
No control [ ] Does well leak around casing? Yes [ ] No [X]

DEPTH FROM FEET	DEPTH TO FEET	MATERIAL	WATER YES OR NO
0	41	CEMENTED GRAVEL + BOULDERS	NO
41	65	LOOSE GRAVEL 1" MINUS	NO
65	78	CEMENTED GRAVEL	NO
78	96	GRAVEL 4" MINUS	NO
96	115	GRAVEL 2" MINUS	NO
115	136	GRAVEL 3/8" MINUS	NO
136	175	GRAVEL 3/4" MINUS	YES
175	180	CEMENTED GRAVEL	NO
180	185	GRAVEL 1/2" MINUS	YES
185	189	GRAVEL + YELLOW CLAY	NO
189	195	GRAVEL 3/4" MINUS	YES
195	200	GRAVEL 1/2" MINUS	YES
200	213	SAND COARSE	YES

006901

JUNE 12 1967
JUNE 30 1967
[illegible] well was [illegible] and this report [illegible] knowledge.
HOLMAN DRILLING CORP.
EAST 3410 NINTH SPOKANE WN.
Arnold E. Holman
~~182~~ 108
Date: July 24 1967

X

[illegible] HOOTENAI
NW SE [illegible] 19 51 0 5 0

USGS

95