

<b>Aerobic Treatment Device (Std 40)</b>	<b>Gallons per day</b>	<b>BOD<sub>5</sub> Removal</b>	<b>Total Suspended Solids Removal</b>	<b>Trench Size</b>	<b>Certification Date</b>
H.E. McGrew, Inc. Class I Alliance 500, 750, 1000 Mighty Mac, 500, 600, 750 Cajun Aire Basic 500, 750, 1000 Cajun Aire Advanced, 500, 750, 1000	500 to 1,000	96.5% Ave. 7 mg/L Ave. 13 mg/L	97.2% Ave. 13 mg/L Ave. 19 mg/L	Intermittent sand filter drainfield	6/5/00 12/5/97 12/30/02
Hoot Aerobic Systems, Inc. Class I H 500, 600, 750, 1000 LA 500, 1000	500 to 1,000	Ave. 3.2 mg/L	Ave. 3.6 mg/L	Intermittent sand filter drainfield	2/6/01
Hydro-Action, Inc.: Class I AP-500, 600, 750, 900, 1500	500 to 1,500	Ave. 9 mg/L	Ave. 15 mg/L	Intermittent sand filter drainfield	4/2/96 3/99 8/1/03
Jet Inc.: Class I J-500, J-600 J-750,1000, 1250, 1500	500 600 750–1,500	88%–96% Ave. 15 mg/L	91%–97% Ave. 12 mg/L	Intermittent sand filter drainfield	10/96 5/93 7/29/97
MICROSEPTEC: Class I Enviroserver, ENFG 600, 1200, 1500	600 1,200 1,500	Ave. 6 mg/L	Ave 8 mg/L	Intermittent sand filter drainfield	6/25/99
National Wastewater Systems Inc., Solar Air 500, 800, 1000, 1200	500 800 1,000 1,200	Ave. 13 mg/L	Ave. 19 mg/L	Intermittent sand filter drainfield	8/1/03
Norweco, Inc. Singulair 950 series Class I Singulair 960 series Class I Singulair TNT	600–1,500 500–1,500 500-1,500	>85% Ave. 6 mg/L Ave. 4 mg/L	>85% Ave. 10 mg/L Ave. 9 mg/L	Intermittent sand filter drainfield	4/3/96 8/96 8/08