STATE OF IDAHO
DEPARTMENT OF
ENVIRONMENTAL QUALITY

2110 Ironwood Parkway, Coeur d'Alene, ID 83814 (208) 769-1422

C. L. "Butch" Otter, Governor
John H. Tippets, Director

October 19, 2015

Mr. Dean Allara
CDS Stoneridge Utilities
364 Stoneridge Rd
Blanchard, ID 83804
dallara@stoneridgeidaho.com

CERTIFIED MAIL: **7011 0110 0000 4529 7961**

Subject: CDS Stoneridge Utilities, Reuse Permit LA-000017-03, Minor Permit Modification No. 2

Dear Mr. Allara:

This letter is a notification regarding a modification to the CDS Stoneridge Utilities Reuse Permit LA-000017-03 issued by the Idaho Department of Environmental Quality (DEQ) on June 1, 2010. Your permit is currently scheduled to expire on June 1, 2016. This modification, referred to as Modification 2, extends the permit expiration date by two (2) years. With the issuance of this modification, CDS Stoneridge Utilities is permitted to continue operating the wastewater reuse system under the terms and conditions of the current permit until June 1, 2018

Per IDAPA 58.01.17.700, a modification may be initiated by DEQ in the event of a change to standards or regulations after the permit was issued. In 2011, IDAPA 58.01.17 (Recycled Water Rules) were changed to allow DEQ to issue permits for up to 10 years. Per the Recycled Water Rules, this modification is considered a minor modification; therefore, no public comment period is necessary.

Annual reports and monitoring data from the CDS Stoneridge Utilities recycled water system demonstrate substantial compliance with Permit LA-000017-03. Permit LA-000017-03 allows CDS Stoneridge Utilities to irrigate up to 16.5 million gallons per year on 27.5 acres. Hydraulic loading has ranged between 5.2 and 9.4 million gallons through the duration of this permit. Permit LA-000017-03 also sets a maximum nitrogen loading limit of 98 lbs/acre-year; annual nitrogen loading has ranged from 5.3 to 23.3 lbs/acre-year. Allowing CDS Stoneridge Utilities to continue operating the reuse facility in compliance with their permit for an additional two (2) years will not pose any increased risk to human health or the environment.

Please note that the dates of the compliance activities listed in the permit will not change with the exception of Compliance Activity CA-017-05 which will now correspond with the new permit expiration date. All monitoring and reporting requirements remain unchanged by this permit modification.

The attached document, Modification "2," serves as the modification to the expiration date of Reuse Permit LA-000017-03. This appendix must be attached to the permit. Should you have any questions regarding this permit modification, please contact Matt Plaisted at (208) 666-4622.

Sincerely,

Daniel Redline
Regional Administrator
Daniel.Redline@deq.idaho.gov

c: Keith Rusho, Operator, krusho@stoneridgeidaho.com
Ruth Leatham, Stoneridge, rleatham@stoneridgeidaho.com
Dan Larson, P.E. HMH Engineering, dlarson@hmh-llc.com
Matthew Plaisted, P.E. Regional Engineering Manager, matthew.plaisted@deq.idaho.gov
Chas Ariss, P.E. DEQ State Office, Boise chas.ariss@deq.idaho.gov

File in TRIM: WW CDS Stoneridge Utilities, 2010AFL127

MODIFICATION OF LAND APPLICATION PERMIT
MODIFICATION "2" TO PERMIT No. LA-000017-03

Permittee Name: **CDS Stoneridge Utilities**

Effective Date of this Modification: **October 19, 2015**

Complete Description of Modification

The purpose of this Permit Modification is to extend the expiration date of Wastewater Reuse Permit LA-000017-03.

1. Section A. Permit Certificate, shall be replaced with the following.

MUNICIPAL
WASTEWATER REUSE PERMIT
LA-000017-03

CDS Stoneridge Utilities LOCATED AT **364 Stoneridge Road, Blanchard, ID 83804** AND IN **Township 54N, Range 5W, Section 29** IS HEREBY AUTHORIZED TO CONSTRUCT, INSTALL, AND OPERATE A WASTEWATER REUSE SYSTEM IN ACCORDANCE WITH THE IDAHO RULES FOR THE RECLAMATION AND REUSE OF MUNICIPAL AND INDUSTRIAL WASTEWATER (IDAPA 58.01.17), WASTEWATER RULES (IDAPA 58.01.16), THE GROUND WATER QUALITY RULE (IDAPA 58.01.11), AND ACCOMPANYING PERMIT, APPENDICES, AND REFERENCE DOCUMENTS. THIS PERMIT IS EFFECTIVE FROM THE DATE OF SIGNATURE AND EXPIRES ON **June 1, 2018**.

10-19-2015

Daniel Redline, Regional Administrator
Coeur d'Alene Regional Office
Department of Environmental Quality

Date: