

Idaho Pollutant Discharge Elimination System

Effluent Limit Development Guidance



**State of Idaho
Department of Environmental Quality**

April 2017



Printed on recycled paper, DEQ April 2017, PID
IPGF, CA code 82988. Costs associated with this
publication are available from the State of Idaho
Department of Environmental Quality in accordance
with Section 60-202, Idaho Code.

Idaho Pollutant Discharge Elimination System

Effluent Limit Development Guidance

April 2017



**Prepared by
Idaho Department of Environmental Quality
Water Quality Division
1410 N. Hilton
Boise, ID 83706**

Table of Contents

Abbreviations and Acronyms	vii
1 Introduction.....	1
1.1 Purpose and Need	1
1.2 Effluent Limit Development Process	2
1.3 Relationship to Existing Rules and Guidance	2
1.3.1 Clean Water Act Background.....	3
1.3.2 Idaho Water Quality Standards.....	3
1.4 Regulatory Citations.....	3
1.5 Data Analysis and Considerations.....	3
2 Determining Technology-Based Effluent Limits (TBELs).....	4
2.1 TBELs for Publicly Owned Treatment Works (POTWs)	4
2.1.1 Secondary and Equivalent to Secondary Treatment	5
2.1.2 Adjustments to Equivalent to Secondary Treatment	7
2.1.3 Applying Secondary and Equivalent to Secondary Treatment Standards	8
2.1.4 Pretreatment Standards	15
2.2 TBELs for Non-POTWs.....	17
2.2.1 Effluent Guidelines and the Statutory Foundation	18
2.2.2 Apply Effluent Guidelines.....	20
2.2.3 Case-by-Case TBELs for Industrial Dischargers	37
3 Determining Water Quality-Based Effluent Limits (WQBELs).....	42
3.1 Characterize the Effluent.....	42
3.1.1 Identify Pollutants of Concern in the Effluent.....	42
3.1.2 Identify Effluent Critical Conditions.....	44
3.2 Characterize Receiving Water Critical Conditions	45
3.2.1 Receiving Water Upstream Flow.....	45
3.2.2 Receiving Water Upstream Pollutant Concentration.....	46
3.2.3 Other Receiving Water Characteristics	46
3.3 Determine Applicable Water Quality Standards (WQS).....	46
3.3.1 Beneficial Uses	47
3.3.2 Water Quality Criteria	48
3.3.3 Antidegradation	56
3.4 Determine the Need for WQBELs	56
3.4.1 Define Reasonable Potential.....	57
3.4.2 Assess Critical Conditions.....	57
3.4.3 Establish an Appropriate Mixing Zone.....	58

3.4.4 Conduct a Reasonable Potential Analysis (RPA)..... 96

3.5 Calculate Pollutant-Specific WQBELs 100

3.5.1 Calculate Pollutant-Specific WQBELs from Aquatic Life Criteria 100

3.5.2 Calculate Chemical-Specific WQBELs Based on Human Health Criteria for Toxic Pollutants 104

3.6 Calculate RPA and WQBELs for Whole Effluent Toxicity (WET) 104

3.6.1 Expressing WET Limits or Test Results 105

3.6.2 WET WLA and RPA 107

3.6.3 Determine WET Triggers and Limits 108

3.6.4 Document RPA and WQBELs Calculation for WET in the Fact Sheet..... 110

4 Final Effluent Limits and Antibacksliding 110

References..... 110

Key Terms..... 114

Appendix A. Significant Figures and Precision for Permit Limits and Reporting 117

Appendix B. Potential Approaches for Limiting Toxic Pollutants..... 119

Appendix C. Pollutants Regulated by Categorical Pretreatment Standards 121

Appendix D. Fact Sheet SOP and Checklist..... 125

Endnotes: IDAPA and CFR References 126

List of Tables

Table 1. Secondary treatment standards. 5

Table 2. Equivalent to secondary treatment standards..... 6

Table 3. Summary of technology levels of control for indirect dischargers..... 17

Table 4. Summary of technology levels of control for direct non-POTW dischargers..... 18

Table 5. Example of BPT limits from 40 CFR 417.42 (glycerine concentration)..... 19

Table 6. Existing point source categories. 22

Table 7. Technology levels of control for new and existing dischargers. 24

Table 8. BPT limits for 40 CFR 405 Subpart F.^a 26

Table 9. BPT Limits for 40 CFR 414, Subpart G (bulk organic chemicals). 27

Table 10. PSES limitations for anodizing facilities discharging less than 38,000 liters per day.. 28

Table 11. BPT effluent limitations for tungstic acid rinse, 40 CFR 421, Subpart J (Primary Tungsten)..... 31

Table 12. BPT effluent limitations for acid leach wet air pollution control, 40 CFR 421, Subpart J (Primary Tungsten)..... 31

Table 13. BPT effluent limitations for alkali leach wash, 40 CFR 421, Subpart J (Primary Tungsten)..... 31

Table 14. BAT effluent limitations for tungstic acid rinse, 40 CFR 421, Subpart J (Primary Tungsten)..... 32

Table 15. BAT effluent limitations for acid leach wet air pollution control, 40 CFR 421, Subpart J (Primary Tungsten)..... 32

Table 16. BAT effluent limitations for alkali leach wash, 40 CFR 21, Subpart J (Primary Tungsten).....	32
Table 17. Available variances, waivers, and intake credits for IPDES permits.	36
Table 18. Receiving water low flow design conditions for reasonable potential analysis and effluent limit development.	45
Table 19. Available variances and intake credits for IPDES permits.....	55
Table 20. Cross-reference of IDAPA mixing zone rules and ELDG sections.....	62
Table 21. Summary of key considerations for mixing zone evaluations.....	64
Table 22. Threshold concentrations observed to elicit avoidance responses in salmonids (DEQ 2000).....	68
Table 23. Low-flow design discharge conditions to use in mixing zone evaluations.	75
Table 24. Mixing zone level of analysis data inputs.....	90
Table 25. Reasonable potential multiplying factors: 95% confidence level and 95% probability basis.....	98
Table 26. Reasonable potential multiplying factors: 99% confidence level and 99% probability basis.....	98
Table 27. Example WET data.....	107

List of Figures

Figure 1. The effluent limit development process for IPDES permits.	2
Figure 2. Secondary and equivalent to secondary treatment standards decision tree.	9
Figure 3. Overview of TBELs calculation for Non-POTW (Industrial) dischargers.	21
Figure 4. Examples of mixing zones in flowing (top) and non-flowing (bottom) waters. ZID indicates the zone of initial dilution.	59
Figure 5. Mixing zone process for new or reissued permit applications.	61
Figure 6. Decision flow chart for determining level of analysis.....	83
Figure 7. Far-field plume, passive ambient diffusion processes (Jirka et al. 1996).	87
Figure 8. Example plots of water hardness versus flow.	94
Figure 9. Process for developing chemical specific WQBELs.....	100

List of Equations

Equation 1. POTW secondary treatment standard mass-based limit calculations.....	11
Equation 2. Mass-based limits.....	12
Equation 3. BOD ₅ conversion factor.	26
Equation 4. Milk to BOD ₅ equivalent.	26
Equation 5. Final calculation for BOD ₅ and TSS.	26
Equation 6. Conversion of gallons per day (gpd) to million gallons per day (mgd).	27
Equation 7. Building block approach maximum daily limit calculation	31
Equation 8. Calculation for tiered limits.....	34

Equation 9. CV calculation. 45

Equation 10. Calculation for hardness dependent metals criteria (acute). 50

Equation 11. Calculation for hardness dependent metals criteria (chronic). 50

Equation 12. Acute conversion factor calculation for cadmium. 50

Equation 13. Chronic conversion factor calculation for cadmium. 50

Equation 14. Acute and chronic conversion factor calculation for lead. 50

Equation 15. Calculation for ammonia criteria (acute). 51

Equation 16. Calculation for ammonia criteria (chronic, early life stages present). 51

Equation 17. Calculation for ammonia criteria (chronic, early life stages absent). 52

Equation 18. Dilution factor calculation. 84

Equation 19. Simple mass-balance equation. 97

Equation 20. Calculation of critical effluent flow. 99

Equation 21. Simple mass-balance equation for calculating WLA for flow water. 101

Equation 22. Simple mass-balance equation for calculating WLA for non-flowing water. 101

Equation 23. Non-flowing water dilution ratio. 101

Equation 24. Acute Long Term Average for Toxics 102

Equation 25. Chronic Long Term Average for Toxics 102

Equation 26. Maximum Daily Limit for Toxics. 103

Equation 27. Average Monthly Limit for Toxics. 103

Equation 28. Example of endpoint conversion to toxic units. 105

Equation 29. ACR expression. 106

Equation 30. TU_a and TU_c expressions. 106

Equation 31. Toxicity expressed as percent sample. 106

Equation 32. ACR in terms of TU. 106

Equation 33. Simple mass-balance equation for WET WLA. 107

Equation 34. WET acute LTA. 108

Equation 35. Acute WET maximum daily limit. 109

Equation 36. Acute WET average monthly limit. 109

Equation 37. Chronic WET long-term average. 109

Equation 38. Chronic WET maximum daily limit. 109

Equation 39. Chronic WET average monthly limit. 109

Abbreviations and Acronyms

§	section (usually a section of federal or state rules or statutes)	EPA	United States Environmental Protection Agency
BAT	best available technology economically achievable	ESA	Endangered Species Act
BCT	best conventional pollutant control technology	FDF	fundamentally different factors
BMP	best management practice	HEM	hexane extractable materials
BOD₅	five-day biochemical oxygen demand	IBR	incorporated by reference (into IDAPA 58.01.25)
BPJ	best professional judgment	IC	inhibition concentration
BPT	best practicable control technology currently available	IDAPA	refers to citations of Idaho administrative rules
cBOD₅	carbonaceous five-day biochemical oxygen demand	IDFG	Idaho Fish and Game Department
CCC	Criterion continuous concentration	I/I	infiltration and inflow
CFR	code of federal regulations (refers to citations in the federal administrative rules)	IP	individual permit
CMC	Criterion maximum concentration	IPDES	Idaho Pollutant Discharge Elimination System
CV	coefficient of variation	IU	industrial user
CWA	Clean Water Act	kg	kilogram
DEQ	Idaho Department of Environmental Quality	L	liter
DMR	discharge monitoring report	LC₅₀	lethal concentration 50
EDU	equivalent dwelling unit	LOEC	lowest observed effects concentration
ELDG	IPDES Effluent Limit Development Guidance	LTA	long-term average
ELG	effluent limit guideline	MCL	maximum contaminant level
		MDL	method detection limit
		mg/L	milligrams per liter
		mgd	million gallons per day

ML	minimum level of quantitation	SIC	standard industrial classification
NAICS	North American industry classification system	SPCC	spill prevention, control and countermeasure
NMFS	National Marine Fisheries Service	SS	suspended solids
NOEC	no observed effects concentration	SSO	sanitary sewer overflow
NPDES	National Pollutant Discharge Elimination System	SWMP	storm water management program
NSPS	new source performance standard	SWPPP	storm water pollution prevention plan
O&M	operations and maintenance	TBEL	technology-based effluent limit
ORW	outstanding resource waters	TMDL	total maximum daily load
PCB	polychlorinated biphenyl	TOC	total organic carbon
POTW	publicly owned treatment works	TRC	technical review criteria
PSES	pretreatment standards for existing sources	TSS	total suspended solids
PSNS	Pretreatment Standards for New Sources	TWTDS	treatment works treating domestic sewage
QAPP	quality assurance project plans	UAA	Use attainability analysis
QA/QC	quality assurance/quality control	US	United States
RPA	reasonable potential analysis	USGS	U.S. Geological Survey
RPTE	reasonable potential to exceed	USACE	United States Army Corps of Engineers
SEP	supplemental environmental project	USFWS	United States Fish and Wildlife Service
SHPO	state historic preservation offices	WER	water effects ration
		WET	whole effluent toxicity
		WLA	wasteload allocation
		WQBEL	water quality-based effluent limit
		WQS	Water quality standards

1 Introduction

The Idaho Department of Environmental Quality's (DEQ's) Idaho Pollutant Discharge Elimination System (IPDES) Program developed this Effluent Limit Development Guidance (ELDG) to help DEQ personnel, the regulated community, and public users understand the process for developing effluent limits in IPDES permits, including how DEQ evaluates the reasonable potential to exceed (RPTe) water quality standards. IPDES permits implement both technology-based and water quality-based controls, and contain effluent limits for point source dischargers consistent with the statutory and regulatory requirements of the IPDES Program, which governs the discharge of pollutants to waters of the United States in Idaho.

Effluent limits can have significant impacts to communities, businesses, the economy, and the environment of the State of Idaho. Given the implications, DEQ strives to appropriately navigate these interests, while adhering to requirements of the CWA, and associated state and federal rules, regulations, and implementation policies.

IPDES permit writers consider contemporary issues from many perspectives including water quality, data collection, laboratory analysis, treatment, and other issues relevant to permitting. IPDES program implementation is an adaptive process, often facing interesting and challenging issues (e.g., toxics, temperature, nutrients), and the IPDES program adapts implementation strategies, as appropriate, to address emerging issues as they occur.

While no circumstances are identical and every permit is unique, the ELDG provides logical pathways for developing effluent limits that appropriately address the issues, not a rigid framework that defaults to generic limitations. DEQ recognizes it is critically important to document the permit process from the beginning of monitoring, data management, mathematical computations, and interpretation of data all the way through to conclusions and effluent limits. DEQ also recognizes that an efficient and transparent process that provides access to permit writers with local knowledge and experience will lead to streamlined, more effective, and fewer contested permits, ultimately benefitting water quality and the citizens of Idaho.

1.1 Purpose and Need

The purpose of this guide is to provide Idaho-specific direction for the development of effluent limits in IPDES permits by defining the requirements for permits and addressing the challenges and perspectives unique to Idaho. For example, most of Idaho's communities are small, with limited technical resources and limited funds. Because permit monitoring and implementation are challenging and expensive for permittees, permit conditions and monitoring requirements must be clear, accurate, and appropriate to be beneficial. And it is critical that a high level of skill is used in the data analyses and interpretation.

The ELDG provides direction for DEQ to recognize unique circumstances and find pathways to logical solutions that avoid previously-identified pitfalls and traps. This will occur by helping permit writers use reasonable assumptions and innovative approaches in developing permits that connect the water quality issues with effluent limits, monitoring requirements, and compliance frequencies that make sense, while aligning with data needs, statutory requirements, and water quality objectives.

This guide serves as a reference for IPDES permit writers to develop, and permittees to understand the development of, permits and effluent limits by explaining:

- Framework and process for developing effluent limits
- Statutory/regulatory requirements and existing guidance
- Technical and statistical tools and constraints

While this guide provides direction in many cases, DEQ may have to develop specific effluent limits in a permit to address site-specific concerns and conditions.

1.2 Effluent Limit Development Process

The ELDG follows the process of developing effluent limits in IPDES permits (Figure 1). Because of the process complexity it is impossible to completely identify each function chronologically. However, the ELDG does identify the procedural steps that IPDES permit writers will follow in drafting effluent limits, beginning with the initial information gathering and data assessment, through establishing technology-based effluent limits (TBELs), evaluating RPTE and establishing water-quality based effluent limits (WQBELs), the antidegradation review, antibacksliding analyses and developing final effluent limits.

Figure 1. The effluent limit development process for IPDES permits.

1.3 Relationship to Existing Rules and Guidance

This guide is not intended to be a stand-alone document; rather, it supports implementation of the Clean Water Act (CWA), Idaho Code and administrative rules, federal regulations, and state and national policies, guidance, and standards. These include compliance with Idaho's "Water Quality Standards" (IDAPA 58.01.02), "Wastewater Rules" (IDAPA 58.01.16), and "Rules Regulating the IPDES Program" (IDAPA 58.01.25).

Some sections of this guide are newly developed to address rules, regulations, and conditions specific to Idaho, while other sections reference or represent an adaptation of numerous existing state and US Environmental Protection Agency (EPA) guidance documents, including but not limited to:

- *NPDES Permit Writer's Manual* (EPA 2010):
https://www3.epa.gov/npdes/pubs/pwm_2010.pdf
- *NPDES Decision Analysis Report #2 – Appendix 4. Guidance for Water Quality-Based Effluent Limits* (DEQ 2002): [www.deq.idaho.gov/media/529907-
npdes_primacy_report2.pdf](http://www.deq.idaho.gov/media/529907-
npdes_primacy_report2.pdf)
- *Technical Support Document for Water Quality-based Toxics Control* (EPA 1991):
<https://www3.epa.gov/npdes/pubs/owm0264.pdf>
- *The EPA NPDES website*:
<https://www.epa.gov/npdes>

This guide does not replace, supplant, or change any requirements under state or federal rules and regulations but does identify and reference relevant regulations, policies, and other guidance documents.

1.3.1 Clean Water Act Background

The Federal Water Pollution Control Act, or CWA, is the primary US law addressing pollutants in receiving waters (e.g., streams, rivers, lakes, and reservoirs). The CWA was originally enacted in 1948 and was revised by significant amendments in 1972 (P.L. 92-500), and to a lesser degree in 1977 (P.L. 95-217) and in 1981 (P.L. 97-117). The most recent major amendments to the CWA were made in 1987 (P.L. 100-4). A major part of the CWA is a requirement for controls on discharges to meet the statutory goal of eliminating the discharge of pollutants under the National Pollutant Discharge Elimination System (NPDES) permit program.

1.3.2 Idaho Water Quality Standards

A water quality standard defines the water quality goals for a water body. WQBELs in IPDES permits are a mechanism to achieve and maintain water quality standards in specific receiving waters. The federal rules regulating water quality standards at 40 CFR 131 describe state requirements and procedures for developing water quality standards and EPA procedures for reviewing and, where appropriate, promulgating water quality standards. Idaho's water quality standards were developed in accordance with these federal requirements.

1.4 Regulatory Citations

The following conventions are used to cite legislation and regulations throughout this guide:

- Idaho Code—Title of the code follow by the code citation: “Approval of State NPDES Program” (Idaho Code §39-175C). After initial use, the code is then referred to by the citation (e.g., Idaho Code §39-175C).
- Idaho Administrative Rules—Title of the rule is followed by the rule citation: “Rules Regulating the Idaho Pollutant Discharge Elimination System Program” (IDAPA 58.01.25). After initial use, the rule is then referred to by the rule citation (e.g., IDAPA 58.01.25).
- Code of Federal Regulations—Initial and subsequent references to CFRs use the regulation citation (e.g., 40 CFR 136).
- US Code—Initial and subsequent references to US code use the code citation (e.g., 16 U.S.C. §1531 et seq. or 33 U.S.C. §§1251–1387).
- Clean Water Act (CWA)—Title of the act is followed by the act citation: Clean Water Act section 402 (e.g., CWA §402). After initial use, the act is then referred to by the act citation (e.g., CWA §402).

Guidance and other documents are referenced in full citation when used for the first time.

1.5 Data Analysis and Considerations

Section 12 (Data Analysis and Considerations) of the DEQ *User's Guide to Permitting and Compliance Volume 1—General Information* (DEQ 2017) identifies procedures **that for** IPDES

permit writers and permittees **should to** follow when reporting or performing calculations on permit-related water quality data, **including data relevancy and representativeness**.

Additionally, permit writers should include, in IPDES permits, the information in Appendix A or similar language, clarifying how permittees should report significant figures on the DMR.

Finally, Appendix B **identifies some potential approaches to consider when limiting toxic pollutants**.

2 Determining Technology-Based Effluent Limits (TBELs)

Effluent limits are restrictions imposed by DEQ on the quantities, discharge rates, and concentrations of pollutants that are discharged from point sources. Establishing effluent limits based on available pollutant control technologies is the first step in reducing the discharge of pollutants to waters of the United States in Idaho. These TBELs are the treatment requirements set under CWA §301(b), and represent the minimum level of control used to achieve these limits. The effluent limit determination and derivation process carefully considers cost of applying control technologies, the age of equipment, processes employed, engineering aspects of control technologies, and non-water quality environmental impacts at each facility applying for an IPDES permit. The resulting effluent limits may be expressed as mass- or concentration-based values. TBELs reflect process controls and do not consider the receiving water's ability to assimilate the discharged pollutants.

The impact to receiving water will be determined using a Reasonable Potential Analysis (RPA). Any impacts to the receiving water will be considered when WQBELs are assessed (Section 4). The more stringent of the two effluent limit types, technology-based or water quality-based, must be identified in an IPDES permit and met by the discharger.

There are two general approaches to deriving TBELs. The permit writer can use the federal effluent limitation guidelines (ELG) and standards, if they are applicable and appropriate, or, if no applicable ELG or standard exists, then develop effluent limits specifically for an individual discharger or pollutant on a case-by-case basis employing Best Professional Judgement (BPJ). It is possible that a permit may contain effluent limits derived from either or both methods.

Point source pollutant discharges to surface water requiring an individual permit are typically either a POTW or non-POTW (e.g., industrial, commercial, mining, or silvicultural). The following subsections will first address establishing TBELs for POTWs in Subsection 2.1, briefly touch upon industrial discharges to POTWs in Subsection 2.1.4, followed by Non-POTW dischargers in Subsection 2.2.

2.1 TBELs for Publicly Owned Treatment Works (POTWs)

The largest category of dischargers requiring individual IPDES permits is POTWs. A POTW, as defined in IDAPA 58.01.25.010.73, includes any devices and systems used in the storage, treatment, recycling and reclamation of municipal sewage or industrial wastes of a liquid nature. A POTW also includes the sewage collection system, pipes, mains, lift stations, and other conveyances that deliver wastewater to the facility. The term also means the municipality as

defined in the Clean Water Act section 502(4), which has jurisdiction over the indirect discharges to and the discharges from such a treatment works.

IDAPA 58.01.25.010.55 provides a definition of municipality as:

A city, town, county, district, association, or other public body created by or under state law and having jurisdiction over disposal of sewage, industrial wastes, or other wastes, or an Indian tribe or an authorized Indian tribal organization, or a designated and approved management agency under the Clean Water Act section 208.

The EPA has established TBELs for POTWs that set minimum technology-based limits. These minimum levels are called secondary treatment and equivalent to secondary treatment standards and are codified in 40 CFR 133 (IBR). In general, POTWs are required to meet discharge limits based on secondary treatment standards. However, if the facility meets specific criteria described in Section 2.1.1.2, then it may be eligible for equivalent to secondary treatment standards.

2.1.1 Secondary and Equivalent to Secondary Treatment

IDAPA 58.01.25.302.03 requires that IPDES permits include applicable technology-based limits and standards, while regulations at 40 CFR 125.3(a)(1) (IBR), state that TBELs for POTWs must be based on secondary treatment standards (which includes the “equivalent to secondary treatment standards”) specified in 40 CFR 133. The following sections will explain how to determine TBELs for the conventional pollutants BOD₅, TSS, and pH discharged by POTWs.

2.1.1.1 Secondary Treatment Standards

In 40 CFR 133, EPA published secondary treatment standards based on an evaluation of performance data for POTWs practicing a combination of physical and biological treatment to remove biodegradable organics and suspended solids. The regulation applies to all POTWs and identifies the technology-based performance standards achievable based on secondary treatment for BOD₅, TSS, and pH.

Table 1 presents the secondary treatment standards established in 40 CFR 133.

Table 1. Secondary treatment standards.

Parameter	Average Concentration	
	30-day	7-day
BOD ₅	30 mg/L (or 25 mg/L cBOD ₅)	45 mg/L (or 40 mg/L cBOD ₅)
TSS	30 mg/L	45 mg/L
Percent removal (BOD ₅ and TSS)	≥85%	NA
pH	Within the range 6.0 to 9.0 standard units (instantaneous minimum or maximum limits) ^a	

a. Unless the POTW demonstrates (1) inorganic chemicals are not added to the waste stream as part of the treatment process; and (2) contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0

2.1.1.2 Equivalent to Secondary Treatment Standards

Some widely used and inexpensive wastewater treatment processes, like trickling filters and waste stabilization ponds, provide significant pollutant reduction, but their consistency may not

always attain the levels and efficiencies specified in the secondary treatment standards. These processes are typically found serving small communities which may have difficulty implementing more expensive treatment processes. These processes may not consistently achieve the secondary treatment standards for TSS and BOD₅, or attain the 85% reduction requirement under extreme conditions. During warm, clear weather, waste stabilization ponds tend to experience algal blooms, resulting in excessive TSS. Similarly, trickling filters may experience excessive biofilm growth on the media which then sluffs off, contributing to excessive TSS. Conversely, in cold weather, both waste stabilization ponds and trickling filters may have lower efficiency, resulting in higher BOD₅ values in the effluent. These effluent performance deficiencies contribute to lower removal efficiencies.

Congress recognized that small communities were ill-suited to shoulder the expense of upgrading to processes that meet secondary treatment standards and increased periodic maintenance costs. Also recognizing that the secondary treatment standards may be overly restrictive for these communities, Congress authorized EPA to develop treatment standards suitable for these processes. A wastewater facility that uses these treatment processes must meet certain criteria described later in this section before these equivalent treatment standards, shown in Table 2, should be used in the permit.

Table 2. Equivalent to secondary treatment standards.

Parameter	Average Concentration	
	30-day	7-day
BOD ₅	45 mg/L (or 40 mg/L cBOD ₅)	65 mg/L (or 60 mg/L cBOD ₅)
TSS	45 mg/L	65 mg/L
Percent removal (BOD ₅ & TSS)	≥65%	NA
pH	Within the range 6.0 to 9.0 standard units (instantaneous minimum or maximum limits) ^a	

a. Unless the POTW demonstrates (1) inorganic chemicals are not added to the waste stream as part of the treatment process; and (2) contributions from industrial sources do not cause the pH of the effluent to be less than 6.0 or greater than 9.0

The equivalent to secondary treatment standards are not automatically granted to facilities that use the processes identified, or meet other criteria that allows equivalent to secondary treatment standards to be applied in their permit. 40 CFR 133.105(f) specifies that the equivalent to secondary treatment standards may be made more restrictive (e.g. 30-day average concentration for BOD₅ and/or TSS ≤ 37 mg/L, and/or 30-day removal efficiency ≥ 75%), if the permit writer determines that the facility can attain higher effluent quality through proper operation and maintenance. Additionally, if the POTW is a new facility, and the facility's design capacity, in conjunction with geographical and climatic conditions, and proper operation and maintenance indicate that effluent limits more restrictive than equivalent to secondary treatment standards are warranted, the permit may reflect this.

Criteria to Qualify for Equivalent to Secondary Treatment Standards

For a POTW to be eligible for discharge limits based on equivalent to secondary standards, the facility must meet all three of the following criteria:

Criterion #1—Principal Treatment Process: Its principal treatment process must be a trickling filter or waste stabilization pond (i.e., the largest percentage of BOD₅ and TSS removal is from a trickling filter or waste stabilization pond system).

Criterion #2—Consistently Does not Achieve Secondary Treatment Standards: Demonstrate that the BOD₅ and TSS effluent concentrations consistently achievable through proper operation and maintenance of the treatment works cannot attain the secondary treatment standards set forth in Table 1. The regulation at 40 CFR 133.101(f) defines “effluent concentrations consistently achievable through proper operation and maintenance” as:

- For a given pollutant parameter, the 95th percentile value for the 30-day average effluent quality achieved by a treatment works in a period of at least 2 years, excluding values attributable to upsets, bypasses, operational errors, or other unusual conditions.
- A 7-day average value equal to 1.5 times the 30-day average value derived in the bullet above.

Some facilities might meet this criterion only for the BOD₅ limits or only for the TSS limits. DEQ believes that it is acceptable to adjust the limits for only one parameter (BOD₅ or TSS) if the effluent concentration of only one of the parameters is demonstrated to consistently not attain the secondary treatment standards.

Criterion #3—Provides Significant Biological Treatment: The treatment works provides significant biological treatment of municipal wastewater. The regulations at 40 CFR 133.101(k) define significant biological treatment as using an aerobic or anaerobic biological treatment process in a treatment works to consistently achieve a 30-day average of at least 65 percent removal of BOD₅.

Each facility should be considered on a case-by-case basis to determine whether it meets those three criteria. To apply the criteria, enough influent, effluent, and flow data from the facility should be collected to adequately characterize the facility’s performance or require the discharger to provide an appropriate analysis. If the facility has made substantial changes in its operations or treatment processes during the current permit term, then data for a period that is representative of the current discharge quality may be necessary to establish limits.

Facilities that do not meet all three criteria do not qualify as equivalent to secondary treatment facilities. For such facilities, the secondary treatment standards apply. EPA noted in its December 1985 *Draft Guidance for NPDES Permits and Compliance Personnel—Secondary Treatment Redefinition* (EPA 1985) that a treatment works operating beyond its design hydraulic or organic loading limit is not eligible for application of equivalent to secondary standards. If overloading or structural failure is causing poor performance, then the solution to the problem is construction, not effluent limit adjustments.

2.1.2 Adjustments to Equivalent to Secondary Treatment

The adjustments to limits presented in this section are applicable to properly operated and maintained POTWs that use trickling filters or waste stabilization ponds as their primary treatment process. Additionally, the facilities must be located in a contiguous area of where other POTWs, similarly configured, experience the same difficulty meeting the BOD₅ and TSS limits.

The revised secondary treatment regulations (adopted in 1984) include provisions in 40 CFR 133.105(d) allowing flexibility to address potential variations in facility performance arising from geographic, climatic, or seasonal conditions. The provisions allow modifying the maximum allowable concentrations of both BOD₅ and TSS for trickling filter facilities and for BOD₅ for waste stabilization pond facilities. The limits are set at levels consistently achievable through proper operation and maintenance [40 CFR 133.101(f)] by the median facility in a representative sample of facilities within the appropriate contiguous geographical area that meet the definition for facilities to be eligible for equivalent to secondary treatment standards. These relaxed limits are classified in 40 CFR 133.105(d) as Alternative State Requirements (ASRs). Establishing these limits requires both the public's input and approval by EPA. Idaho does not currently have approved ASRs and does not foresee proposing ASRs.

The permit writer can adjust the maximum allowable TSS concentration for waste stabilization ponds upward from those specified in equivalent to secondary treatment standards to conform to TSS concentrations achievable with waste stabilization ponds. The regulation, found at 40 CFR 133.103(c), defines "SS concentrations achievable with waste stabilization ponds" as the effluent concentration achieved 90 percent of the time within an appropriate contiguous geographical area by waste stabilization ponds that are achieving the levels of effluent quality for BOD₅ specified in 40 CFR 133.105(a)(1) (45 milligrams per liter [mg/L] as a 30-day average). This higher TSS concentration requires EPA approval. To qualify for an adjustment up to as high as the maximum concentration allowed, a facility must use a waste stabilization pond as its principal process for secondary treatment and its operations and maintenance data must indicate that it cannot achieve the equivalent to secondary standards.

2.1.3 Applying Secondary and Equivalent to Secondary Treatment Standards

Determining whether secondary treatment standards or equivalent to secondary standards apply to a POTW and determining the specific discharge limits for the facility based on either set of standards can be a complex process. Compliance with established permit limits requires that both influent and effluent must be measured in order to calculate the percent removal. This section presents a protocol to establish TBELs for POTWs. A synopsis of this protocol is presented in Figure 2.




Figure 2. Secondary and equivalent to secondary treatment standards decision tree.

2.1.3.1 Determine Appropriate Standards to Apply

Initially, a facility evaluation must be completed to determine whether secondary treatment, equivalent to secondary treatment, or some adjustment to the equivalent to secondary treatment standards are applicable for the facility. New facilities using tricking filters or waste stabilization ponds will, with a high probability, achieve secondary treatment standards. The ultimate design capability of the treatment processes (waste stabilization ponds, trickling filters, or both), geographical and climatic conditions, and the performance capabilities of recently constructed facilities in similar situations should be considered when determining which standard applies.

Once the standard (secondary or equivalent to secondary) is selected, it can be used to set the permit limits. Subsection 3.1.3.2 will address the development of permit limits if secondary treatment standards are deemed appropriate. If equivalent to secondary treatment standards are deemed appropriate, then follow subsection 3.1.3.3 to address permit limit development.

2.1.3.2 Calculate Effluent Limits Based on Secondary Treatment

If a permit writer deems secondary treatment standards are appropriate for the POTW, then the following procedures will be used to establish concentration and mass based limits. If the secondary treatment standards do not apply, then the permit writer will move on to Section 2.1.3.3, Calculating Effluent Limits Based on Equivalent to Secondary Treatment Standards.

Application of secondary treatment standards is straightforward. If these standards apply, then the permit should contain the permit limits listed in Table 1. These limits will be used to calculate the load limits for the permit.

First, the secondary treatment standards are stated as 30-day and 7-day averages, whereas IDAPA 58.01.25.303.04 requires that effluent limits for POTWs be expressed, unless impracticable, as average monthly and average weekly limits. The IPDES regulations define average monthly (or average weekly) discharge limits as the average of daily discharges over a calendar month (or week), calculated as the sum of all daily discharges measured during a calendar month (or week) divided by the number of daily discharges measured during that month (or week). Consequently, it is recommended that the 30-day and 7-day average secondary treatment standards be used as average monthly (calendar month) and average weekly (calendar week) discharge limits.

Second, IDAPA 58.01.25.303.06 requires that all permit limits, standards, or prohibitions be expressed in terms of mass except in any of the following cases:

- For pH, temperature, radiation or other pollutants that cannot appropriately be expressed by mass limits.
- When applicable standards and limits are expressed in terms of other units of measure.
- If in establishing permit limits on a case-by-case basis under 40 CFR 125.3, limits expressed in terms of mass are infeasible because the mass of the pollutant discharged cannot be related to a measure of operation, and permit conditions ensure that dilution will not be used as a substitute for treatment.

The first condition applies to pH requirements established by secondary treatment standards. Because the 30-day and 7-day average requirements for BOD₅ and TSS, including percent removal, are expressed in terms of concentration, the second condition applies to these standards.

Thus, mass-based discharge limits are not specifically required to implement secondary treatment standards, yet there may be valid reasons to include mass-based limits in the permit. Including both concentration and mass-based limits may be necessary to safeguard the environment and human health. IDAPA 58.01.25.303.02 requires using the POTW’s design flow rate to calculate limits. To calculate a mass-based limit for a POTW (in pounds per day [lb/day]) the equations and procedures presented in Equation 1 should be followed.

$$\begin{array}{l}
 \text{POTW design flow} \\
 \text{(mgd)}
 \end{array}
 \times
 \begin{array}{l}
 \text{Concentration-based} \\
 \text{limits} \\
 \text{(mg/L)}
 \end{array}
 \times
 \begin{array}{l}
 \text{Conversion factor} \\
 8.34 \text{ (lb} \times \text{L/mg} \times \text{millions of} \\
 \text{gallons)}
 \end{array}$$

Equation 1. POTW secondary treatment standard mass-based limit calculations.

A POTW with a design flow of 2.0 mgd would have mass-based limits calculated from secondary treatment standards as follows:

$$\text{Mass-based limits} = \text{POTW design flow} \times \text{Concentration-based limits} \times \text{Conversion Factor}$$

BOD₅

$$\text{Average Monthly} = (2.0 \text{ mgd}) \times \left(30 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 \text{ (lb} \times \text{L)}}{\text{(mg} \times \text{millions of gallons)}} = 500 \text{ lb/day}$$

$$\text{Average Weekly} = (2.0 \text{ mgd}) \times \left(45 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 \text{ (lb} \times \text{L)}}{\text{(mg} \times \text{millions of gallons)}} = 750 \text{ lb/day}$$

TSS

$$\text{Average Monthly} = (2.0 \text{ mgd}) \times \left(30 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 \text{ (lb} \times \text{L)}}{\text{(mg} \times \text{millions of gallons)}} = 500 \text{ lb/day}$$

$$\text{Average Weekly} = (2.0 \text{ mgd}) \times \left(45 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 \text{ (lb} \times \text{L)}}{\text{(mg} \times \text{millions of gallons)}} = 750 \text{ lb/day}$$

2.1.3.3 Calculate Effluent Limits Based on Equivalent to Secondary Standards

For facilities that qualify for equivalent to secondary standards for any pollutant, effluent limits must meet the requirements specified in 40 CFR 133.105 and summarized above in Table 2 (not accounting for any further approved adjustments). It is important to note that the equivalent to secondary standards specify the maximum allowable discharge concentration of BOD₅ and TSS and a minimum percent removal requirement for qualified facilities. The regulations at 40 CFR 133.105(f) require the permit writer to include more stringent limits when the permit writer determines that the 30-day average and 7-day average BOD₅ and TSS concentrations are achievable through proper operation and maintenance of the treatment works. This is based on an analysis of the past performance for an existing facility or considering the design capability of the treatment process and geographical and climatic conditions for a new facility, which would enable the treatment works to achieve more stringent limits than the least stringent effluent quality allowed by the equivalent to secondary standards. The regulations at 40 CFR 133.101(f) define, “effluent concentrations consistently achievable through proper operation and maintenance” as the 95th percentile value for the 30-day average effluent quality achieved by a treatment works in a period of at least two years, excluding values attributable to upsets, bypasses, operational errors, or other unusual conditions. The 7-day average value is set equal to

1.5 times the 30-day average value. As with limits based on secondary treatment standards, limits based on equivalent to secondary standards are expressed as average monthly (calendar month) and average weekly (calendar week) limits. Mass balance calculations for equivalent to secondary standards are presented below using Equation 2.

A POTW with a design flow of 1.25 mgd would have mass-based limits calculated from equivalent to secondary treatment standards as follows

$$\text{Mass-based limits} = \text{POTW design flow} \times \text{Concentration-based limits} \times \text{Conversion Factor}$$

Equation 2. Mass-based limits.

BOD₅

$$\text{Average Monthly} = (1.25 \text{ mgd}) \times \left(45 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 (\text{lbs} * \text{L})}{(\text{mg} * \text{millions of gallons})} = 470 \text{ lbs/day}$$

$$\text{Average Weekly} = (1.25 \text{ mgd}) \times \left(65 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 (\text{lbs} * \text{L})}{(\text{mg} * \text{millions of gallons})} = 680 \text{ lbs/day}$$

TSS

$$\text{Average Monthly} = (1.25 \text{ mgd}) \times \left(45 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 (\text{lbs} * \text{L})}{(\text{mg} * \text{millions of gallons})} = 470 \text{ lbs/day}$$

$$\text{Average Weekly} = (1.25 \text{ mgd}) \times \left(65 \frac{\text{mg}}{\text{L}}\right) \times \frac{8.34 (\text{lbs} * \text{L})}{(\text{mg} * \text{millions of gallons})} = 680 \text{ lbs/day}$$

If an existing facility does not have sufficient data to establish past performance, a compliance schedule item should be included in the permit that requires monitoring and reporting to generate the necessary data. IDAPA 58.01.25.201.02 provides provisions allowing the permitting authority to reopen and, if necessary, modify the permit after reviewing the additional data submitted by the discharger (201.02.c.ii).

2.1.3.4 Apply Special Considerations and Adjustments

40 CFR 133 allows the permit writer to make further adjustments when calculating effluent limits derived from secondary treatment standards or equivalent to secondary standards based on several special considerations. The permit writer should determine whether any of the special considerations outlined in this section apply and, as appropriate, make any further adjustments to the concentration limits or percent removal requirements. The calculated limits, after making such adjustments, are the final TBELs for the POTW.

2.1.3.4.1 Substitution of cBOD₅ for BOD₅

Wastewater contains carbonaceous oxygen demanding substances and nitrogenous oxygen demanding substances. A cBOD₅ test measures the 5-day carbonaceous biochemical oxygen demand while the BOD₅ test measures both the carbonaceous biochemical oxygen demand and the nitrogenous biochemical oxygen demand. During nitrification, nitrifying bacteria use a large amount of oxygen to consume nitrogenous oxygen demanding substances (e.g. unoxidized ammonia, urea, and proteins) and convert these to oxidized nitrate. For wastewaters with significant nitrogen content, basing permit limits on cBOD₅ instead of BOD₅ eliminates the

impact of nitrification on discharge limits and compliance determinations. The cBOD₅ test can provide accurate information on treatment plant performance in many cases and, 40 CFR 133 allows for the use of cBOD₅ limits in place of BOD₅ limits to minimize false indications of poor facility performance as a result of nitrogenous oxygen demand.

EPA has established cBOD₅ standards for cases where secondary treatment standards or equivalent to secondary treatment standards are applied.

Secondary Treatment:

- The cBOD₅ secondary treatment performance standards specified by the regulations are as follows:
 - 25 mg/L as a 30-day average.
 - 40 mg/L as a 7-day average.
- The EPA-approved test procedures in Part 136 include a cBOD₅ (nitrogen inhibited) test procedure. Permits can specify these cBOD₅ limits along with cBOD₅ monitoring requirements in any POTW permit requiring performance based on secondary treatment standards [40 CFR 133.102(a)(4)].

Equivalent to Secondary Treatment:

- The cBOD₅ equivalent to secondary treatment performance standards specified by the regulations are as follows:
 - No greater than 40 mg/L as a 30-day average.
 - No greater than 60 mg/L as a 7-day average.
- Where data are available to establish cBOD₅ limits, permit writers may require cBOD₅ instead of BOD₅ and specify cBOD₅ limits and monitoring requirements when applying equivalent to secondary standards.

2.1.3.4.2 Substitution of COD or TOC for BOD₅

Chemical oxygen demand (COD) and total organic carbon (TOC) laboratory tests can provide an accurate measure of the organic content of wastewater in a shorter time frame than a BOD₅ test (i.e., several hours versus five days). The regulations at 40 CFR 133.104(b) allow permit limits for COD or TOC instead of BOD₅ if a long-term BOD₅:COD or BOD₅:TOC correlation has been demonstrated. If the applicant has sufficient data to establish a correlation between BOD₅ and either COD or TOC, then these alternate monitoring methods may be included in the permit.

2.1.3.4.3 Adjustments for Industrial Contributions

Under 40 CFR 133.103(b), treatment works receiving wastes from industrial categories with ELGs and standards or pretreatment standards for BOD₅ or TSS, which are less stringent than the secondary treatment standards or, if applicable, the equivalent to secondary treatment standards in 40 CFR 133, can qualify to have their 30-day BOD₅ or TSS limits adjusted upward provided that the following are true:

- The permitted discharge of pollutants for the applicable industrial category is not greater than the limits in ELGs for the industrial category.
- The flow or loading introduced by the industrial category exceeds 10% of the design flow or loading to the POTW.

When making this adjustment, the 40 CFR 133 values for BOD₅ and TSS should be adjusted proportionately using a flow-weighted or loading-weighted average of the two concentration limits (i.e., the limits developed from effluent guidelines for the industrial facility and the secondary or equivalent to secondary limits).

2.1.3.4.4 Adjustments to Percent Removal Requirements

The 85% removal requirement, for a 30-day average, in secondary treatment standards was originally established to achieve two basic objectives:

- To encourage municipalities to remove high quantities of infiltration and inflow (I/I) from their sanitary sewer systems.
- To prevent intentional dilution of influent wastewater.

In facilities with dilute influent that is not attributable to high quantities of I/I or intentional dilution, the percent removal requirement could result in forcing advanced treatment rather than the intended secondary treatment. Advanced treatment generally refers to treatment processes following secondary treatment (e.g., filtration, chemical addition, or two-stage biological treatment). Advanced treatment can achieve significantly greater pollutant removals than secondary treatment processes but at a higher cost.

The regulations at 40 CFR 133.103(a), (d) and (e) provide that, under certain circumstances, less stringent limits for BOD₅ and TSS percent removal may be established. The specific circumstances and the potential adjustments to the percent removal requirement are as follows:

- Treatment works that receive less concentrated wastes from *combined sewer systems* are eligible to have less stringent monthly percent removal limits during wet-weather events [40 CFR 133.103 (a)] and, under certain conditions, less stringent percent removal requirements or a mass loading limit instead of a percent removal requirement during dry weather [40 CFR 133.103 (e)].

Determining whether any attainable percentage removal level can be defined during wet weather and, if so, what the level should be must be evaluated on a case-by-case basis. To qualify for a less stringent percent removal requirement or substitution of a mass limit during dry weather, the discharger must satisfactorily demonstrate the following:

- The facility is consistently meeting, or will consistently meet, its permit effluent concentration limits, but cannot meet its percent removal limits because of less concentrated influent.
- To meet the percent removal requirements, the facility would have to achieve significantly more stringent effluent concentrations than would otherwise be required by the concentration-based standards.
- The less concentrated influent wastewater does not result from either excessive infiltration or clear water industrial discharges during dry weather periods. The determination of whether the less concentrated wastewater results from excessive infiltration is discussed in regulations at 40 CFR 35.2005(b)(28). This regulation defines non-excessive infiltration as the quantity of flow that is less than 120 gallons per capita per day (domestic base flow and infiltration) or the quantity of infiltration that cannot be economically and effectively eliminated from a sewer system as determined in a cost-effectiveness analysis.

- The regulation at 40 CFR 133.103(e) includes the additional criterion that either 40 gallons per capita per day or 1,500 gallons per inch diameter per mile of sewer may be used as the threshold value for that portion of dry-weather base flow attributed to infiltration. If the less concentrated influent wastewater is the result of clear water industrial discharges, then the treatment works must control such discharges pursuant to 40 CFR 403.
- Treatment works that receive less concentrated wastes from *separate sewer systems* can qualify to have less stringent percent removal requirement or receive a mass loading limit instead of the percent removal requirement provided the treatment plant demonstrates all of the following [40 CFR 133.103(d)]:
 - The facility is consistently meeting or will consistently meet its permit effluent concentration limits but cannot meet its percent removal limits because of less concentrated influent wastewater.
 - To meet the percent removal requirements, the facility would have to achieve significantly more stringent limits than would otherwise be required by the concentration-based standards.
 - The less concentrated influent wastewater does not result from excessive I/I. The regulation indicates that the determination of whether the less concentrated wastewater is the result of excessive I/I will use the definition of excessive I/I at 40 CFR 35.2005(b)(16), plus the additional criterion that flow is non-excessive if the total flow to the POTW (i.e., wastewater plus I/I) is less than 275 gallons per capita per day.
 - The regulation at 40 CFR 35.2005(b)(16) defines excessive I/I as the quantities of I/I that can be economically eliminated from a sewer system as determined in a cost-effectiveness analysis that compares the costs for correcting the I/I conditions to the total costs for transportation and treatment of the I/I. This regulation also refers to definitions of non-excessive I/I in 40 CFR 35.2005(b)(28) and 40 CFR 35.2005(b)(29).

2.1.3.5 Document the Application Standards, Adjustments, and Considerations in the Fact Sheet

The permit writer will clearly document in an IPDES POTW permit fact sheet:

- The application of secondary or equivalent to secondary treatment standards
- The data and information used to determine whether secondary treatment standards or equivalent to secondary treatment standards apply
- How that information was used to derive the permit's effluent limits
- All adjustments and special considerations

The information in the fact sheet will provide the IPDES permit applicant and the public a transparent, reproducible, and defensible description of how the IPDES permit properly incorporates secondary treatment standards.

2.1.4 Pretreatment Standards

The National Pretreatment Program authorizes a POTW to control industrial discharges to its facility through a DEQ-approved pretreatment program. These controls are developed to protect the POTW's equipment and personnel from damage. Regulatory national pretreatment standards

that apply to a POTW's IUs include prohibited discharges, categorical standards, and local limits.

POTWs, or a group of POTWs operated by the same entity, with a total design flow of more than 5 mgd and receiving industrial pollutants that may cause pass through or interference are required to establish a pretreatment program under IPDES. In some cases, a POTW with a total design flow of less than 5 mgd may be required to establish a pretreatment program if the nature or volume of the industrial discharge causes POTW treatment process upsets, effluent limit violations, contamination of municipal sludge, or other circumstances as warranted. All POTWs meeting the above criteria must submit a pretreatment program for DEQ evaluation and approval within one year of written notification from DEQ for the need of a Pretreatment Program.

Prohibitions and categorical standards are designed to provide a minimum acceptable level of control over IU discharges. Site specific controls can be developed and enforced by the POTW through local limits. DEQ will not develop or approve a POTW's local limits but will evaluate the POTW's local limits development processes for appropriateness during program review. Therefore, local limits are not discussed here. For additional information about the development of local limits, see EPA's Local Limits Development Guidance (EPA 2004).

2.1.4.1 Prohibited Discharges

Prohibited discharges, comprised of general and specific prohibitions, apply to all industrial users regardless of the size or type of operation. A user may not introduce into a POTW any pollutant(s) which causes pass through or interference. These general prohibitions and the specific prohibitions below apply to each user introducing pollutants into a POTW whether or not the user is subject to other National Pretreatment Standards or any national, state, or local pretreatment requirements.

- General prohibitions [40 CFR 403.5(a)] forbid the discharge to a POTW of any pollutant that causes pass through or interference.
- Specific prohibitions [40 CFR 403.5(b)(1) to (8)] are categories of pollutant discharges that shall not be introduced to POTWs that are volatile, explosive, corrosive, or a hazard to the health and safety of personnel

2.1.4.2 Categorical Standards

Categorical standards apply to specific process wastewater discharges from particular industrial categories. These are uniform, technology-based, and applicable nationwide. Developed by the EPA, these standards apply to specific categories of IUs and limit the discharge of specified toxic and non-conventional pollutants to POTWs. Expressed as numerical limits and management standards, the categorical standards are found at 40 CFR 405 through 471. They include specific limitations for 35 industrial sectors. Appendix B of this ELDG contains a list of pollutants regulated by categorical pretreatment standards.

2.1.4.3 Pretreatment Standards for Existing Sources (PSES)

PSES are designed to prevent the discharge of pollutants that cause pass through or interference at a POTW or causes contamination of a POTW's biosolids from IU discharges (Table 3). The categorical pretreatment standards for existing IU discharges are technology-based and are analogous to BAT for non-POTWs. The general pretreatment regulations, which set forth the

framework for the implementation of national pretreatment standards, are at 40 CFR 403 (see CWA §307(b)).

2.1.4.4 Pretreatment Standards for New Sources (PSNS)

Like PSES, PSNS are designed to prevent the discharges of pollutants that cause pass through or interference at a POTW or cause contamination of a POTW's biosolids from IU discharges (Table 3). PSNS are issued in concurrence with New Source Performance Standards (NSPS). New IU dischargers have the opportunity to incorporate the best available demonstrated technologies into their facilities at the time of construction. The same factors for NSPS are considered when assessing PSNS.

PSNS applies to non-conventional and toxic pollutants because POTWs are designed to treat conventional pollutants. However, the permit writer has the authority to establish categorical pretreatment standards for conventional pollutants as surrogates for toxic or non-conventional pollutants or to prevent interference.

Table 3. Summary of technology levels of control for indirect dischargers.

Pollutants Regulated	PSES	PSNS
Nonconventional pollutants	✓	✓
Toxic (Priority) pollutants	✓	✓

2.2 TBELs for Non-POTWs

TBELs are the treatment requirements set under CWA §301(b). These controls are promulgated by DEQ through the IPDES program for direct dischargers while indirect dischargers are controlled through DEQ-approved POTW pretreatment programs.

Under the CWA, the requirements for discharge controls on industries were to first meet limits that could be achieved through the use of BPT for wastewater treatment, and later by improved BAT. BCT was added by EPA in 1986 to evaluate conventional pollutant control processes using a two part cost-reasonableness test. BPT, BAT, and BCT are termed “technology-based” limits, in that the discharge limits were set on the basis of what the treatment technology could reasonably achieve, and not necessarily what was needed to protect the receiving water quality for its designated uses, such as aquatic life habitat.

When developing TBELs for industrial (non-POTW) facilities, the permit writer considers all applicable technology standards and requirements for all pollutants discharged and determines how much of a pollutant can be removed from the facility's effluent using available technology. TBELs represent the minimum level of industrial wastewater control that must be imposed in a discharge permit for all industrial facilities within a 40 CFR 405-471 category or subcategory. The type of technology-based effluent control required for each facility depends on whether the discharge is from a new or existing source and the type of pollutants discharged. There are cases where a single facility may be permitted for several different effluent limits. In these cases, a building block approach is used to develop the final TBEL.

Effluent guidelines can include numeric and narrative limits, including best management practices (BMPs), to control the discharge of pollutants from categories of point sources. The limits are based on data characterizing the performance of technologies available and, in some

cases, from modifying process equipment or the use of raw materials. Although the regulations do not require the use of any particular treatment technology, they do require facilities to achieve effluent limits that reflect the proper operation of the model technologies selected as the basis for the effluent guidelines and from which the performance data were obtained to generate the limits. Therefore, each facility has the discretion to select any technology and process necessary to meet the performance-based discharge limits and standards specified by the effluent guidelines.

If no applicable ELGs exist for a discharge or pollutant, the permit writer must identify any needed site-specific TBELs on a case-by-case basis according to CWA §§301(b)(2) and 304(b). The site-specific TBELs reflect the permit writer's BPJ, taking into account the same factors EPA would use in establishing a national effluent guideline but applying them to the permit circumstances. The permit writer will identify if state laws or regulations might require more stringent performance standards than those required by federal regulations.

2.2.1 Effluent Guidelines and the Statutory Foundation

For dischargers other than POTWs, TBELs are based on BPT, BCT, BAT, or NSPS. For industrial discharges to a POTW the discharger must adhere to TBELs established for PSES, or if the facility is new, then they must comply with the PSNS. Section 2.1.4 includes additional information related to the standards required for IU discharges into a POTW with an approved pretreatment program. The performance standard required for each discharger is evaluated based on its current status as a new source, existing source, or new discharger (Figure 2) and the types of pollutants regulated (Table 4).

Table 4. Summary of technology levels of control for direct non-POTW dischargers.

Pollutants Regulated	BPT	BCT	BAT	NSPS
Conventional pollutants	✓	✓		✓
Nonconventional pollutants	✓		✓	✓
Toxic (priority) pollutants	✓		✓	✓

Conventional pollutants include BOD₅, TSS, pH, *E. coli*, and oil and grease. EPA has identified 65 pollutants and classes of pollutants as *toxic pollutants*, which can be found at the link below. All other pollutants are considered *nonconventional*.

<https://www.epa.gov/eg/toxic-and-priority-pollutants-under-clean-water-act>

2.2.1.1 Best Practicable Control Technology Currently Available (BPT)

BPT is the first type of technology-based control for direct dischargers and applies to all pollutants. When applying BPT to effluent limits, the following considerations must be made:

- The total cost of applying the control technology in relation to the benefits of the effluent reduction
- Age of the equipment and facilities
- Processes employed by the industry and any required process changes
- Engineering aspects of the control technologies
- Non-water quality environmental impacts, including energy requirements

BPT effluent limits have traditionally been based on the average of the best performance of well-operated facilities within each industrial category or subcategory. Where existing performance is uniformly inadequate, BPT may reflect higher levels of control than currently in place in an industrial category if the permit writer determines that the technology can be practically applied.

The economic reasonableness of BPTs must be evaluated prior to applying them to an IPDES permit; however, there is currently no precisely-defined test to determine economic reasonableness and must be considered from industry to industry.

Limits for industrial facilities are stated in the 40 CFR 405-471 subcategories, and these limits can take numerous forms. Most commonly, tables for each technology-based requirement will explicitly state the 1-day maximum and 30-day average values for each pollutant controlled under that subcategory (Table 5). In other cases, narrative requirements may be included, or a technology-based requirement may be excluded completely (noted as [Reserved] in the subcategory). Categories and subcategories are explained in further detail in Section 2.2.2.2.

Table 5. Example of BPT limits from 40 CFR 417.42 (glycerine concentration).

Pollutant or Pollutant Property	BPT Limits	
	1-Day Maximum	Average of Daily Values (30 Consecutive Days)
	English units (pounds per 1,000 lb of anhydrous product)	
BOD ₅	4.50	1.50
COD	13.50	4.50
TSS	0.60	0.20
Oil and grease	0.30	0.10
pH	6.0–9.0	6.0–9.0

2.2.1.2 Best Conventional Pollutant Control Technology (BCT)

BCT is the second type of technology-based control and applies to conventional pollutants only. The control of conventional pollutants under BCT is always at least as stringent as under BPT. The following factors are considered when evaluating the applicability of BCT:

- Age of the equipment and facilities
- Processes employed by the industry and any required process changes
- Engineering aspects of the control technologies
- Non-water quality environmental impacts, including energy requirements

In addition to using these factors, BCT consideration uses a two part economic reasonableness test, described in 40 CFR 125.3(d)(2)(i) and (ii). Consistent with CWA §304(b)(4)(B), the permit writer will consider:

- The reasonableness of the relationship between the costs of attaining a reduction in effluent and the effluent reduction benefits derived.
- The comparison of the cost and level of reduction of such pollutants from the discharge from publicly owned treatment works (POTW) to the cost and level of reduction of such pollutants from a class or category of industrial sources.

This test compares the economic burden of an industrial user removing conventional pollutants beyond the limits set forth in BPT to a POTW’s economic burden of removing the same

pollutants beyond secondary treatment. Additional information about EPA's methodology for developing BCT limits is available in 51 FR 24974:

https://www3.epa.gov/npdes/pubs/fr_bct_1986.pdf

2.2.1.3 Best Available Technology Economically Achievable (BAT)

Limits for the direct discharge of non-conventional and toxic pollutants are promulgated using BAT. BAT is defined on the basis of the performance associated with the best control and treatment measures that facilities in an industrial category are capable of achieving. Factors to consider when assessing BAT include:

- The total cost of applying the control technology in relation to the benefits of the effluent reduction
- Age of the equipment and facilities
- Processes employed by the industry and any required process changes
- Non-water quality environmental impacts, including energy requirements

Unlike the cost analysis in BPT, BAT does not require the permit writer to balance the cost of implementation against the pollution reduction benefit. BAT may be based on process changes or internal controls, even when those technologies are not common industry practice.

2.2.1.4 New Source Performance Standards (NSPS)

NSPS, like BPT, applies to direct dischargers for all pollutants. NSPS reflect effluent reductions that are achievable based on "best available demonstrated control technology." New sources have the opportunity to install the best and most efficient production processes and wastewater treatment technologies. NSPS should represent the most stringent controls attainable through the application of the best available demonstrated control technology for all pollutants. Factors to consider when assessing NSPS include:

- The total cost of applying the control technology in relation to the benefits of the effluent reduction
- Non-water quality environmental impacts, including energy requirements
- Other factors as DEQ deems appropriate

2.2.2 Apply Effluent Guidelines

Effluent guidelines are implemented and enforced through the IPDES permit for each industrial user. Direct dischargers are regulated by permits that specify limits using BPT, BAT, BCT, and NSPS. An overview of the process a permit writer will follow to determine applicable effluent guidelines and calculate final effluent limits for an industrial user is presented in Figure 3.




Figure 3. Overview of TBELs calculation for Non-POTW (Industrial) dischargers.

2.2.2.1 Learn about the Industrial Discharger

Facility-specific information is required to properly identify applicable effluent guidelines and derive TBELs. The following information, at a minimum, is necessary:

- Industrial processes and raw materials
- Products and services
- Amount of manufacturing production or servicing
- Number of production and non-production days
- Current pollution prevention practices and wastewater treatment technology
- Discharge location of the wastewater pollutants and potential compliance sampling points
- The source and characteristics of the wastewaters (including flow) and pollutants that are being discharged or have the potential to be discharged from the facility

Sources of information include the facility's permit application, the current permit and fact sheet (if the facility is permitted), DMRs, site visits, site inspections (such as compliance evaluation inspections for an existing permit), and other information submitted by the facility.

2.2.2.2 Identify the Applicable Effluent Guideline Categories

Existing effluent guideline regulations are organized by EPA into industry categories and are found in 40 CFR 405-471 (Table 6). These are further broken down into subcategories. When determining subcategories, EPA considers a number of different factors, including manufacturing products and processes, raw materials used, wastewater characteristics, facility size, geographic location, age of the facility and equipment, and wastewater treatability. The results are a series of subcategories that cover certain types of industrial users and specify the effluent limits applicable to that industry's pollutants.

Table 6. Existing point source categories.

Industry Category	40 CFR Part	Industry Category	40 CFR Part
Aluminum Forming	467	Meat and Poultry Products	432
Asbestos Manufacturing	427	Metal Finishing	433
Battery Manufacturing	461	Metal Molding and Casting	464
Canned and Preserved Fruits and Vegetable Processing	407	Metal Products and Machinery	438
Canned and Preserved Seafood Processing	408	Mineral Mining and Processing	436
Carbon Black Manufacturing	458	Nonferrous Metals Forming and Metal Powders	471
Cement Manufacturing	411	Nonferrous Metals Manufacturing	421
Centralized Waste Treatment	437	Oil and Gas Extraction	435
Coal Mining	434	Ore Mining and Dressing	440
Coil Coating	465	Organic Chemicals, Plastics, and Synthetic Fibers	414
Concentrated Animal	412	Paint Formulating	446

Industry Category	40 CFR Part	Industry Category	40 CFR Part
Feeding Operations (CAFOs)			
Concentrated Aquatic Animal Production	451	Paving and Roofing Materials (Tars and Asphalt)	443
Copper Forming	468	Pesticide Chemicals	455
Dairy Products Processing	405	Petroleum Refining	419
Electrical and Electronic Components	469	Pharmaceutical Manufacturing	439
Electroplating ^a	413	Phosphate Manufacturing	422
Explosives Manufacturing	457	Photographic	459
Ferroalloy Manufacturing	424	Plastic Molding and Forming	463
Fertilizer Manufacturing	418	Porcelain Enameling	466
Glass Manufacturing	426	Pulp, Paper, and Paperboard	430
Grain Mills	406	Rubber Manufacturing	428
Gum and Wood Chemicals	454	Soaps and Detergents Manufacturing	417
Hospitals	460	Steam Electric Power Generating	423
Ink Formulating	447	Sugar Processing	409
Inorganic Chemicals	415	Textile Mills	410
Iron and Steel Manufacturing	420	Timber Products Processing	429
Landfills	445	Transportation Equipment Cleansing	442
Leather Tanning and Finishing	425	Waste Combustors	444

a. This category contains only categorical pretreatment standards and no effluent guidelines for direct dischargers

Identifying the applicable effluent guidelines for a facility is dependent upon the user providing DEQ as much information as possible about its operations. DEQ will additionally use the following sources of information in determining the appropriate 40 CFR 405-471 category and subcategory for an industrial user:

- **CFR titles and applicability section of the effluent guidelines.** The first step is to cross check the current information about the facility against Table 6. The category titles may indicate to which category the facility belongs. The General Provisions section under each category includes an applicability section that describes the types of industrial users covered under the category.
- **North American Industry Classification System (NAICS) and Standard Industrial Classification (SIC).** If finding the correct category for the industrial user using the titles in Table 6 is unsuccessful, the current NAICS or former SIC codes could be helpful in determining the appropriate 400 series category. NAICS and SIC codes are federal industrial classifications by activity. The NAICS and/or SIC code should be available in the IPDES permit or permit application.

NAICS Search: <https://www.naics.com/search/>

SIC Search: <https://www.osha.gov/pls/imis/sicsearch.html>

For example, a facility reports a SIC code of 3331 in its permit application. The search results on the OSHA website returns “Industry Group 333: Primary Smelting and Refining of Nonferrous Metals.” This corresponds to 40 CFR 421 for Nonferrous Metals Manufacturing.

2.2.2.3 Identify the Applicable Effluent Guideline Subcategories

Regulation of an industrial category using subcategories allows each subcategory to have a uniform set of requirements that takes into account technological achievability and economic impacts unique to that subcategory. Grouping similar facilities into subcategories increases the likelihood that the regulations are practicable and diminishes the need to address variations between facilities within a category through a variance process.

Subcategories cover a wide range of industrial activities. In some cases, a facility may fall under multiple subcategories, each with different effluent limits. Each subcategory contains an applicability section that provides a detailed explanation of the types of facilities and processes covered by the subcategory, which DEQ will carefully review to ensure properly derived TBELs. DEQ will notify each user of their coverage under 40 CFR 405-471 categories and subcategories as applicable.

2.2.2.4 Determine whether Existing or New Source Standards Apply

The type of control technology selected for each facility depends, in part, on whether the facility is a new or existing discharger or source. Table 7 defines the control technology that applies to each type of discharger (see also Figure 3). New and existing sources and new dischargers are defined in IDAPA 58.01.25.010. An *existing discharger* is one that has previously or is currently permitted to discharge pollutants, or did not previously require authorization to discharge.

Table 7. Technology levels of control for new and existing dischargers.

Pollutants Regulated	BPT	BCT	BAT	NSPS
Existing direct discharger	✓	✓	✓	
New direct discharger				✓

A *new discharger* is any building, structure, facility, or installation from which there is or may be a discharge of pollutants that did not commence the discharge of pollutants at a particular site prior to August 13, 1979, which is not a new source, and which never received a finally effective NPDES or IPDES permit.

Additional criteria for determining whether a discharge is a new source are defined in IDAPA 58.01.25.120:

- Is constructed at a site at which no other source is located;
- Totally replaces the process causing the discharge from an existing source;
- Uses processes that are substantially independent of an existing source at the same site.

Some 40 CFR 405-471 categories include additional criteria for making new source determinations.

Note that new dischargers are required to meet the requirements of their applicable technology-based guidelines *before* they begin discharging. This is because the facility has the opportunity to install the best and newest technology prior to commencing operations.

The most stringent level of control for each pollutant as specified in the subcategory for the facility will be used to derive the facility's TBELs.

2.2.2.5 Calculate TBELs from the Effluent Guidelines

IDAPA 58.01.25.303.06.a stipulates that all pollutants limited in permits must have limits, standards, or prohibitions expressed in terms of mass except under any of the following conditions:

- For pH, temperature, radiation, or other pollutants that cannot appropriately be expressed by mass limits.
- When applicable standards or limits are expressed in terms of other units of measure (e.g. concentration [mg/L]).
- If in establishing technology-based permit limits on a case-by-case basis, limits based on mass are infeasible because the mass or pollutant cannot be related to a measure of production (e.g., discharges of TSS from certain mining operations). The permit conditions must ensure that dilution will not be used as a substitute for treatment.

Thus, the type of limit (i.e., mass, concentration, or other units) calculated for a specific pollutant at a facility will depend on the type of pollutant and the way limits are expressed in the applicable effluent guideline. Generally, effluent guidelines include both maximum daily and monthly average limits for most pollutants. Though the effluent guidelines use different terms for monthly effluent limits (e.g., monthly average, maximum for monthly average, average of daily values for 30 consecutive days), the requirements are expressed in IPDES permits as average monthly limits as defined in IDAPA 58.01.25.010.06.

When calculating numeric limits from effluent guidelines, the permit writer will include all pollutants regulated by an effluent guideline and will include both maximum daily and average monthly effluent limits expressed as mass limits unless the guideline allows or requires concentration limits.

2.2.2.5.1 Calculating Mass-Based TBELs from Production-Normalized Effluent Guidelines

Production-normalized effluent guidelines are established using the past 3 to 5 years of facility data. The production rate used in the production-normalized TBEL calculation should be representative of the actual production likely to prevail during the next term of the permit and should account for any planned changes at the facility, such as an increase or decrease in production.

Consider the following example:

A facility that processes raw milk into cheese has applied for a permit. The permit writer has determined that the facility falls under 40 CFR 405 – Dairy Products Processing, Subpart F – Natural and Processed Cheese. The facility processes approximately 3,800,000 lbs of raw milk per day and is subject to BPT controls based on information from the subcategory. Calculate the

BPT Average Monthly Limits (AMLs) for BOD₅, TSS, and pH using Table 8 and the following example equations (Equation 3–Equation 5).

Table 8. BPT limits for 40 CFR 405 Subpart F.^a

Effluent Characteristic	Effluent Limits	
	Maximum for any 1 day	Average of Daily Values for 30-Consecutive Days shall not exceed the values below:
		English units (pounds per 100 lb of BOD ₅ input) except pH
BOD ₅	0.073	0.029
TSS	0.109	0.044
pH	6.0-9.0	6.0-9.0

a. For plants processing more than 100,000 lb/day of milk equivalent (more than 10,390 lb/day of BOD₅ input).

$$BOD_5 \text{ Conversion Factor} = \frac{10,390 \frac{\text{lb}}{\text{day}} BOD_5}{100,000 \frac{\text{lb}}{\text{day}} \text{ raw material equivalent}}$$

Equation 3. BOD₅ conversion factor.

$$\text{Production Rate} \times BOD_5 \text{ Conversion Factor} = \text{Milk to } BOD_5 \text{ Equivalent}$$

Equation 4. Milk to BOD₅ equivalent.

$$\text{Convert Milk to } BOD_5: \frac{3,800,000 \text{ lb raw milk}}{\text{day}} \times \frac{10,390 \text{ lb } BOD_5}{100,000 \text{ lb raw milk}} = 394,820 \frac{\text{lb } BOD_5}{\text{day}}$$

$$\text{Milk to } BOD_5 \text{ Equivalent} \times \text{Effluent Limit} = \text{lb/day}$$

Equation 5. Final calculation for BOD₅ and TSS.

$$BOD_5: \frac{394,820 \text{ lb } BOD_5}{\text{day}} \times \frac{0.029 \text{ lb}}{100 \text{ lb } BOD_5} = 110 \text{ lb/day}$$

$$TSS: \frac{394,820 \text{ lb } BOD_5}{\text{day}} \times \frac{0.044 \text{ lb}}{100 \text{ lb } BOD_5} = 170 \text{ lb/day}$$

pH: Within the range of 6.0 to 9.0 standard units

2.2.2.5.2 Calculating Mass-Based TBELs from Flow-Normalized Effluent Guidelines

The process for calculating mass-based TBELs from flow-normalized effluent guidelines is similar to the process used with production-normalized effluent guidelines, but rather than using a reasonable measure of the actual daily production, the permit writer will use a reasonable measure of the actual daily flow rate as the basis for calculating the TBELs.

As with estimating production to calculate TBELs, the objective in determining a flow estimate for a facility is to develop a single estimate of the actual daily flow rate (in terms of volume of

process wastewater per day), which can reasonably be expected to prevail during the next term of the permit (not the design flow rate). Use of design flow rates in these calculations result in increasingly relaxed discharge requirements for facilities whose average daily flow is well below design flow rate. The permit writer may use the past 3 to 5 years of facility data to assist in developing an appropriate estimate, but should account for planned changes over the next permit term. For example, the permit writer may use the highest average daily flow rate from the average daily flows of the last 3 to 5 years of facility data.

The example and equations presented in Table 9 and Equation 6 assess an organic chemical processing facility that must comply with the effluent guidelines in 40 CFR 414, Organic Chemicals, Plastics, and Synthetic Fibers. Assume that a reasonable estimate of the production flow is 16,000 gpd, based on the past three years of production history, and the facility does not anticipate any significant change from the flow rate over the next five years.

Table 9. BPT Limits for 40 CFR 414, Subpart G (bulk organic chemicals).

Effluent Characteristic	BPT Effluent Limits	
	Maximum for any 1 day	Maximum for monthly average
	All units except pH are milligrams per liter (mg/L)	
BOD ₅	92	34
TSS	159	49
pH	6.0–9.0	6.0–9.0

$$\text{Gallons per day} \times \frac{10^{-6} \text{ mgd}}{\text{gpd}} = \text{Flow Conversion to mgd}$$

Equation 6. Conversion of gallons per day (gpd) to million gallons per day (mgd).

$$\text{Flow conversion: } 16,000 \text{ gpd} \times \frac{10^{-6} \text{ mgd}}{\text{gpd}} = 0.016 \text{ mgd}$$

Maximum Daily Limit (using Equation 1):

$$\text{BOD}_5: 0.016 \text{ mgd} \times 92 \frac{\text{mg}}{\text{L}} \times 8.34 \frac{\text{lb} \times \text{L}}{\text{mg} \times \text{MG}} = 12 \text{ lb/day}$$

$$\text{TSS: } 0.016 \text{ mgd} \times 159 \frac{\text{mg}}{\text{L}} \times 8.34 \frac{\text{lb} \times \text{L}}{\text{mg} \times \text{MG}} = 21.2 \text{ lb/day}$$

pH: Within the range of 6.0 to 9.0 standard units

Average Monthly Limit:

$$\text{BOD}_5: 0.016 \text{ mgd} \times 34 \frac{\text{mg}}{\text{L}} \times 8.34 \frac{\text{lb} \times \text{L}}{\text{mg} \times \text{MG}} = 4.5 \text{ lb/day}$$

$$\text{TSS: } 0.016 \text{ mgd} \times 49 \frac{\text{mg}}{\text{L}} \times 8.34 \frac{\text{lb} \times \text{L}}{\text{mg} \times \text{MG}} = 6.5 \text{ lb/day}$$

pH: Within the range of 6.0 to 9.0 standard units

2.2.2.5.3 Calculating Mass-Based TBELs from Concentration-based Effluent Guidelines

In some cases, the permit writer will develop mass-based TBELs for facilities with concentration-based effluent guidelines (e.g., if a facility does not have adequate water conservation practices). Mass-based permit effluent limits encourage water conservation (e.g., minimize the potential for diluting process wastewaters by non-process wastewater, more efficient use of water) and pollution prevention (e.g., reduce waste loads to wastewater treatment facilities by physically collecting solid materials before using water to clean equipment and facilities). Additionally, for facilities with on-site wastewater treatment systems, the combination of water-reduction technologies and practices and well-operated wastewater treatment will reduce the volume and mass of discharged wastewater pollution (i.e., after treatment). Another benefit of mass-based permit effluent limits is that they provide the permittee with more flexibility. Permittees may elect to control their wastewater discharges through more efficient wastewater control technologies and pollution-prevention practices that result in lower pollutant concentrations in the discharged wastewater, or more efficient water conservation practices that result in less wastewater volume discharged from industrial operations), or both.

Consider the example and equations presented in Table 10:

A facility covered under 40 CFR 413, Subpart D (Anodizing) is subject to PSES limitations and discharges 8,000 gpd.

What is the mass-based calculation for the facility's lead effluent?

Table 10. PSES limitations for anodizing facilities discharging less than 38,000 liters per day.

Pollutant or Pollutant Property	Maximum for any 1 day (mg/L)	Average of Daily Values for 4 Consecutive Monitoring days shall not exceed (mg/L)
CN, A	5.0	2.7
Pb	0.6	0.4
Cd	1.2	0.7

Flow conversion (using Equation 6): $8,000 \text{ gpd} \times \frac{10^{-6} \text{ MGD}}{\text{gpd}} = 0.008 \text{ mgd}$

Maximum Daily Limit for lead (using Equation 1): $0.6 \left(\frac{\text{mg}}{\text{L}} \right) \times 0.008 \text{ (mgd)} \times 8.34 = 0.04 \frac{\text{lb}}{\text{day}}$

2.2.2.5.4 Supplementing Mass-Based TBELs with Concentration Limits

Even where effluent guidelines require mass-based TBEL calculations, the permit writer may determine that it is beneficial to include concentration-based limits to supplement the mass-based limits. Where limits are expressed in more than one unit, the facility must comply with both. Expressing limits in terms of both concentration and mass encourages the proper operation of a treatment facility at all times.

Supplementing mass-based limits with concentration-based limits may be especially appropriate where the requirements in the effluent guidelines are flow-normalized. This helps the permit

writer account for changes in a facility's discharge during low flow periods while encouraging persistent treatment efficiency throughout the discharge season.

2.2.2.5.5 Incorporating Narrative Requirements from Effluent Guidelines

In some cases, DEQ may include narrative effluent guideline controls, which EPA has developed and included the 40 CFR 405-471 subcategories. When numeric effluent limits are infeasible, IDAPA 58.01.25.302.13 authorizes DEQ to include BMPs in IPDES permits to control or abate the discharge of pollutants. In some cases, *only* narrative guidelines will be provided in the applicable subcategory. For example, the effluent guidelines for CAAP facilities (40 CFR 451) consist of narrative requirements implemented through BMPs. Another example, related to monitoring and compliance rather than effluent limits, is found in the Metal Finishing (40 CFR 433) effluent guidelines. The guideline allows a facility to implement a toxic organic management plan along with a certifying statement in reports in lieu of routine total toxic organic monitoring. The plan assures the control authority that no toxics will be discharged by the permittee through good housekeeping and spill response measures. These narrative requirements may include BMPs, treatment practices, and monitoring, reporting, and compliance requirements.

2.2.2.6 Account for Overlapping or Multiple Effluent Guidelines Requirements

There are cases when a facility may be subject to overlapping or multiple effluent guidelines due to both new and existing sources at the facility, multiple products or services provided by the same facility, or a facility with processes subject to multiple subcategories. In such cases, the permit writer will examine the applicable effluent guidelines to ensure that (1) one guideline does not supersede another; and (2) the effluent guidelines are properly applied.

2.2.2.6.1 Superseding Effluent Guidelines

EPA minimizes the impact of overlapping effluent guidelines as much as possible during the development of effluent guidelines for point source categories by providing exclusions in the applicability sections. The permit writer will minimize the overlap of different effluent guidelines as much as possible by careful review of the facility's applicable subcategories.

In cases where a facility is subject to multiple subcategories, the limits from one may be more stringent than the other, requiring the more stringent limit to be selected. EPA has provided direction in the preamble of the ELG or provided specific direction in the affected ELG when a subcategory must comply with more than one ELG.

Consider the following example:

Several 400 series categories supersede the limits in 40 CFR 433, *Metal Finishing Point Source Category*. When one of the following industrial categories is effective, limits from 40 CFR 433 will not apply.

- Iron and steel (40 CFR 420)
- Nonferrous metal smelting and refining (40 CFR 421)
- Battery manufacturing (40 CFR 461)
- Plastic molding and forming (40 CFR 463)
- Metal casting foundries (40 CFR 464)

- Coil coating (40 CFR 465)
- Porcelain enameling (40 CFR 466)
- Aluminum forming (40 CFR 467)
- Copper forming (40 CFR 468)
- Electrical and electronic components (40 CFR 469)
- Nonferrous forming (40 CFR 471)

2.2.2.6.2 Multiple Effluent Guidelines Requirements

When a facility is subject to effluent guidelines for two or more processes in a subcategory or to effluent guidelines from two or more categories or subcategories, each of the applicable effluent guidelines will be used individually to derive TBELs, which will then be combined. In applying multiple effluent guidelines, the permit writer will use measures of production or flow that are reasonable with respect to the operation of multiple processes at the same time and the overall production or flow of the facility for the next term of the permit.

Most commonly, wastewater streams regulated by effluent guidelines are combined during or before treatment. In such a case, the permit writer will combine the calculated allowable pollutant loadings from each set of requirements or from each set of effluent guidelines to arrive at a single TBEL for the facility using a building block approach. The following example presents the building block approach, as applied to a facility with multiple processes in the Primary Tungsten subcategory of the Primary Nonferrous Metals Manufacturing point source category (40 CFR 421, Subpart J). The same principles illustrated in this example would apply to a facility with processes subject to requirements from multiple subcategories or categories that are combined before or during treatment.

Example

A facility is subject to 40 CFR 421, Subpart J (Primary Tungsten). The facility uses a tungstic acid rinse, an acid leach wet air pollution control system, and an alkali leach wash in its manufacturing process (Table 11, Table 12, and Table 13).

The maximum daily production rate for the facility is:

- 4.7 million pounds per day of Tungstic Acid (as W)
- 3.5 million pounds per day of Sodium Tungstate (as W)

Given the information above, what is the technology-based effluent limit for lead at the facility?

BPT calculation for lead (40 CFR 421.102):

Table 11. BPT effluent limitations for tungstic acid rinse, 40 CFR 421, Subpart J (Primary Tungsten).

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of tungstic acid (as W) produced	
Lead	17.230	8.205
Zinc	59.900	25.030
Ammonia (as N)	5,469.000	2,404.00
Total suspended solids	1,682.000	800.000
pH	7.0–10.0	7.0–10.0

Table 12. BPT effluent limitations for acid leach wet air pollution control, 40 CFR 421, Subpart J (Primary Tungsten)

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of tungstic acid (as W) produced	
Lead	15.040	7.162
Zinc	52.280	21.840
Ammonia (as N)	4,773.000	2,098.000
Total suspended solids	1,468.000	698.300
pH	7.0–10.0	7.0–10.0

Table 13. BPT effluent limitations for alkali leach wash, 40 CFR 421, Subpart J (Primary Tungsten)

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of sodium tungstate (as W) produced	
Lead	0.000	0.000
Zinc	0.000	0.000
Ammonia (as N)	0.000	0.000
Total suspended solids	0.000	0.000
pH	(¹)	(¹)

BPT Maximum Daily Limit (Equation 7):

$$\text{Production Rate} \times \text{Effluent Limit Guideline} = \text{lb/day}$$

Equation 7. Building block approach maximum daily limit calculation

Tungstic acid rinse (daily maximum):

$$(4.7 \text{ million lbs per day}) \times (17.230 \text{ lbs per million lbs}) = 80.981 \text{ lbs/day}$$

Acid leach wet air pollution control (daily maximum):

$$(4.7 \text{ million lbs per day}) \times (15.040 \text{ lbs per million lbs}) = 70.688 \text{ lbs/day}$$

Alkali leach wash (daily maximum):

$$(3.5 \text{ million lbs per day}) \times (0.000 \text{ lbs per million lbs}) = 0 \text{ lbs/day}$$

Total allowable discharge (daily maximum):

$$(80.981 \text{ lbs/day}) + (70.688 \text{ lbs/day}) + (0.000 \text{ lbs/day}) = 151.669 \text{ lbs/day}$$

The resulting daily maximum discharge under BPT is 151.669 lbs/day after accounting for significant digits.

Similarly, calculations using BPT maximum monthly average values (Table 11, Table 12, and Table 13) yields an average monthly maximum value of 72.225 (rounded from 72.2249) lbs/day.

BAT calculation for lead (40 CFR 421.103) (Table 14, Table 15, and Table 16):

Table 14. BAT effluent limitations for tungstic acid rinse, 40 CFR 421, Subpart J (Primary Tungsten).

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of tungstic acid (as W) produced	
Lead	11.490	5.333
Zinc	41.850	17.230
Ammonia (as N)	5,469.000	2,404.000

Table 15. BAT effluent limitations for acid leach wet air pollution control, 40 CFR 421, Subpart J (Primary Tungsten).

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of tungstic acid (as W) produced	
Lead	1.003	0.466
Zinc	3.653	1.504
Ammonia (as N)	477.400	209.900

Table 16. BAT effluent limitations for alkali leach wash, 40 CFR 21, Subpart J (Primary Tungsten).

Pollutant or Pollutant Property	Maximum for any 1 day	Maximum for Monthly Average
	mg/kg (pounds per million pounds) of sodium tungstate (as W) produced	
Lead	0.000	0.000
Zinc	0.000	0.000
Ammonia (as N)	0.000	0.000

BAT Maximum Daily Limit (using Equation 7):

Tungstic acid rinse:

$$(4.7 \text{ million lbs per day}) \times (11.490 \text{ lbs per million lbs}) = 54.003 \text{ lbs/day}$$

Acid leach wet air pollution control:

$$(4.7 \text{ million lbs per day}) \times (1.003 \text{ lbs per million lbs}) = 4.714 \text{ lbs/day}$$

Alkali leach wash:

$$(3.5 \text{ million lbs per day}) \times (0.000 \text{ lbs per million lbs}) = 0 \text{ lbs/day}$$

Total allowable discharge:

$$(54.003 \text{ lbs/day}) + (4.714 \text{ lbs/day}) + (0.000 \text{ lbs/day}) = 58.717 \text{ lbs/day}$$

The resulting daily maximum discharge under BAT is 58.717 lbs/day after accounting for significant digits.

Therefore, the technology-based maximum daily limit for lead at the facility is the more stringent BAT limit of 58.717 lbs/day.

Similarly, calculations using BAT maximum monthly average values (Table 14, Table 15, and Table 16) yield an average monthly maximum value of 27.255 (rounded from 27.2553) lbs/day.

Compare the results and select the more stringent daily maximum and monthly average for inclusion in the permit.

The permit writer may apply the building block approach in other circumstances as well, such as:

- **Mixture of mass-based and concentration-based requirements:** The limits in effluent guidelines for some pollutants are mass-based, production-normalized limits in some subparts and concentration-based limits in other subparts. When all the wastewater streams go to the same treatment system, the permit writer will convert the concentration-based limits to mass-based limits. This will allow the permit writer to combine the results with the mass-based, production-normalized limits and apply the limit to the combined wastewater stream.
- **Mixture of different concentration-based requirements:** Some facilities could have multiple operations that are each subject to different concentration-based requirements for the same pollutant but with wastewater streams that combine before treatment. In such a case, the permit writer will establish a flow-weighted concentration-based limit as the TBEL for the combined wastewater streams. Alternatively, the permit writer may convert the concentration-based requirements to equivalent mass-based requirements using flow data and then combine the mass-based requirements into a single limit for the combined wastewater stream.
- **Mixture of regulated and unregulated wastewater streams:** In some cases, wastewater streams containing a pollutant regulated by the applicable effluent guidelines requirements can combine with other wastewater streams that do not have effluent guideline requirements that regulate the pollutant. In such a case, the permit writer will use BPJ to establish a TBEL for the unregulated wastewater stream(s) and, as appropriate, calculate a final TBEL for the combined wastewater streams. For example, if one of the wastewater streams contributing to an industrial facility's discharge is sanitary wastewater, then the permit writer would use BPJ to apply the treatment standards for domestic wastewater and calculate BOD₅ limits for that wastewater stream. The secondary treatment standards would be used to calculate mass-based limits for the sanitary wastewater using the concentration-based requirements and an estimate of flow rate that is expected to represent the flow rate during the proposed permit term. A final TBEL for BOD₅ could be calculated for the combined sanitary and process wastewater streams by combining the two mass limits using the building block approach.
- **Mixture of wastewater streams containing a pollutant with wastewater streams not containing the pollutant:** If a wastewater stream that does not contain a pollutant is combined with another wastewater stream that contains the pollutant (and has applicable requirements in the effluent guidelines or requirements determined by the permit writer using BPJ), the permit writer must ensure that the non-regulated waste stream does not dilute the regulated waste stream to the point where the pollutant is not analytically detectable. If that occurs, the permit writer will establish internal outfalls, as allowed under IDAPA 58.01.25.303.08.

2.2.2.7 Apply Additional Regulatory Considerations in Calculating TBELs

Several additional factors must be considered when deriving TBELs from effluent guidelines. Additional requirements consist of evaluating or accounting for the following:

- Expected significant increases or decreases in production during the permit term for tiered discharger limits.
- Internal outfalls.
- Request(s) for a variance from effluent guidelines.

The following sections provide an overview of these considerations.

2.2.2.7.1 Tiered Discharge Limits

If production rates are expected to change significantly during the life of the permit the use of tiered TBELs may be included in the permit, or a reopener clause may be included, depending upon the facility and/or the receiving water conditions. If tiered TBELs are incorporated into the permit they would apply to mass-based effluent limits and would become effective when production or flow (or some other measure of production) exceed a threshold value, such as during seasonal production variations. Generally, up to 20% fluctuation in production is considered to be within the range of normal variation, while increases or decreases higher than 20% could warrant consideration of tiered limits.

Consider the following example:

Over the previous 5 years, Plant B produced approximately 40 tons per day of product during spring and summer months (i.e., March through August) and 280 tons per day during fall and winter months. Production during the fall and winter months is significantly higher than during the off-season, and the discharger has made a plausible argument that production is expected to continue at that level over the next 5 years. The effluent guideline requirements for Pollutant Z are 0.08 lbs/1,000 lbs for the average monthly limit and 0.14 lbs/1,000 lbs for the maximum daily limit.

What are the appropriate tiered effluent limits for Plant B?

Tier 1:

The first tier, or lower limit, would be based on a production rate of 40 tons per day. The limits would apply between March and August (Equation 8).

$$\text{Production Rate} \times 2,000 \frac{\text{lbs}}{\text{ton}} \times \text{Effluent Limit Guideline} = \text{lbs/day}$$

Equation 8. Calculation for tiered limits.

Monthly average limit:

$$40 \text{ tons/day} \times 2,000 \text{ lbs/ton} \times 0.08 \text{ lbs/1,000 lbs} = 6 \text{ lbs/day}$$

Daily maximum limit:

$$40 \text{ tons/day} \times 2,000 \text{ lbs/ton} \times 0.14 \text{ lbs/1,000 lbs} = 11 \text{ lbs/day}$$

Tier 2:

The second tier, or higher limit, would be based on a production rate of 280 tons per day. Those limits would apply between September and February.

Using Equation 8:

Monthly average limit:

$$280 \text{ tons/day} \times 2,000 \text{ lbs/ton} \times 0.08 \text{ lbs/1,000 lbs} = 50 \text{ lbs/day}$$

Daily maximum limit:

$$280 \text{ tons/day} \times 2,000 \text{ lbs/ton} \times 0.14 \text{ lbs/1,000 lbs} = 78 \text{ lbs/day}$$

The permit writer should include tiered limits in a permit after careful consideration of production data, and when a substantial increase or decrease in production is likely to occur. In the example above, the lower limits would be in effect when production was at low levels (March through August). During periods of significantly higher production (September through February), the higher limits would be in effect. In addition, a tiered or alternate set of limits might be appropriate in the case of special processes or product lines that operate during certain times.

The permit writer may also base thresholds for tiered limits on an expected increase in production during the term of the permit that will continue through the duration of the permit term. For example, if a facility plans to add a process line and significantly expand production in year 3 of the permit term, the permit could specify a higher tier of limits that go into effect when the facility reports reaching a production level specified in the permit. Alternatively, if the production increase changes the subcategory, or other considerations may need to be addressed, the permit writer may modify the permit as allowed in IDAPA 58.01.25.201.02.c.

The permit will detail thresholds and periods when each tier applies, measures of production, and special reporting requirements. Special reporting requirements may include the following:

- Facility notification to DEQ a specified number of business days before the month it expects to be operating at a higher level of production and the duration of this level of production.
- Facility reporting, in the DMR, the level of production and the limits and standards applicable to that level.

A detailed discussion of the rationale and requirements for any tiered limits will be provided in the fact sheet for the permit.

2.2.2.7.2 Internal Outfalls

IDAPA 58.01.25.303.08 authorizes DEQ to identify internal outfalls when effluent limits or standards at the point of discharge are impractical or infeasible. Limits on internal waste streams, frequency of and locations for monitoring, and analytical methods will be described in the fact sheet. Examples of circumstances include: when the final discharge point is inaccessible (impacted by receiving water flow or surcharge), the wastes at the point of discharge are so diluted as to make monitoring impracticable, or the interferences among pollutants at the outfall would make detection or analysis impracticable. Some effluent guidelines may require the use of internal outfalls unless the effluent limits are adjusted based on the dilution ratio of the process

wastewater to the wastewater flow at the compliance point. Any internal outfall monitoring that might be required by the applicable effluent guidelines will be clearly identified in the final permit. Examples of effluent guidelines with required internal compliance points include the Metal Finishing effluent guidelines (40 CFR 433) and the Pulp, Paper, and Paperboard effluent guidelines (40 CFR 430).

2.2.2.7.3 Effluent Guidelines Variances, Waivers, and Intake Credits

The CWA and state regulations provide limited mechanisms for variances, waivers, and intake credits from requirements in effluent guidelines. An IPDES permit applicant must meet very specific data and application deadline requirements before a variance, waiver, or intake credit may be granted. These mechanisms provide a unique exception to particular requirements, and no expectation to receive a similar permit condition should be assumed by the permittee or applicant.

Table 17 explains the available variances, waivers, and intake credits from TBEL for non-POTW dischargers.

Table 17. Available variances, waivers, and intake credits for IPDES permits.

Request Type	Eligible	CWA	Regulation	Application Deadline ^a	Granting Authority ^b
Economic	Non-POTWs	301(c)	IDAPA 58.01.25.310 40 CFR 122.21(m)	Initial request to DEQ < 270 days after promulgation of effluent limit guideline. A completed request by close of the draft permit comment period.	EPA ^c
Nonconventional pollutant	Non-POTWs	301(g)	IDAPA 58.01.25.310 40 CFR 122.21(m)	Initial request to DEQ < 270 days after promulgation of effluent limit guideline. A completed request by close of the draft permit comment period.	EPA ^c
Fundamentally different factors (FDF)	Non-POTWs	301(n)	IDAPA 58.01.25.310 40 CFR 125.30–32	For BPT a request by the close of the public comment period. For BAT or BCT a request by no later than 180 days after an effluent limit guideline is published in the Federal Register.	EPA ^c
Thermal discharge	All	316(a)	IDAPA 58.01.25.310 40 CFR 125.70–73	With a permit application if based on an effluent guideline.	DEQ
Waivers	All	N/A	IDAPA 58.01.25.105 58.01.25.106 58.01.25.302.03	With a permit application.	DEQ
Intake credits	All	N/A	IDAPA 58.01.25.303.07	By close of the draft permit comment period.	DEQ

a. Permittees are advised to contact DEQ 1 year in advance if considering applying for a variance. The 180-day requirement to submit a complete application for a new permit or permit renewal may not be sufficient to also complete a variance and receive EPA approval. Dischargers must submit all requests to DEQ.

b. Any approved variance, waiver, or intake credit is effective for up to 5 years or the life of the IPDES permit. After 5 years or the permit expiration, the discharger must meet the standard or must reapply for the variance, waiver, or intake credit. In considering a reapplication, DEQ requires the discharger to demonstrate reasonable progress toward meeting the standard. DEQ’s decisions may be appealed to the Board of Environmental Quality.

c. CWA §§301(c), 301(g), and 301(n) variances—If DEQ concurs with the variance request, the request must be forwarded with written concurrence to EPA for review and approval.

The options listed in Table 17 and the factors considered in a technical review are explained in the IPDES User's Guide, Volume 1, Section 8 (DEQ 2016).

2.2.2.8 Apply Additional Requirements in Effluent Guidelines

Industrial storm water, specific analytical methods for measuring compliance with TBELs, and documentation and recordkeeping requirements are additional areas which need evaluation and incorporation into permit provisions, if necessary.

Industrial storm water sometimes falls under regulations by effluent guidelines when there is an opportunity for unsheltered industrial operations to come into contact with and contaminate storm water. Examples of categories which fall under effluent guideline regulations are Concentrated Animal Feeding Operations (40 CFR 412), Fertilizer Manufacturing (40 CFR 418), Petroleum Refining (40 CFR 419), and Pulp, Paper, and Paperboard (40 CFR 430). Storm water that is commingled with process wastewater will require the adjustment of the effluent guidelines to account for overlapping or multiple effluent guideline requirements, discussed in section 2.2.2.6.

When more than one analytical method is available in 40 CFR 136 for analysis of a parameter, the permit writer may need to determine the appropriate ML necessary to maintain permit compliance using EPA's sufficiently sensitive test method (*IPDES User's Guide to Permitting and Compliance Volume 1 (DEQ 2017)*). When permit conditions require specific analytical methods to determine compliance with TBELs, the permit will clearly state which analytical method to use for a particular pollutant(s).

Documentation and recordkeeping are mandatory components for permit compliance, and submission schedules will be included for each of the required plans (e.g., solvent management plans, BMP plans, and alternative monitoring requirements).

2.2.2.9 Document the Application of Effluent Guidelines in the Fact Sheet

The IPDES permit fact sheet will document the data and information used to determine applicable effluent guidelines, how the effluent limits were derived and the final permit effluent limits. The fact sheet will clearly explain all considerations of applicable TBELs and variance, waiver, and intake credit requests.

2.2.3 Case-by-Case TBELs for Industrial Dischargers

40 CFR 125.3 states that technology-based treatment requirements under the CWA §301(b) represent the minimum level of control that must be imposed in an IPDES permit. Where EPA-promulgated effluent guidelines are not applicable to a non-POTW discharge, such requirements are established on a case by case basis using BPJ.

2.2.3.1 Legal Authority to Establish Case-by-Case TBELs

Case-by-case TBELs are developed pursuant to CWA §402(a)(1) and IDAPA 58.01.25.302.03, which authorizes the permit writer to issue a permit that will meet either all applicable requirements developed under the authority of other sections of the CWA (e.g., technology-based treatment standards or water quality standards) or, before taking the necessary implementing actions related to those requirements, that the permit writer determines are

necessary to carry out the provisions of the CWA. Further, 40 CFR 125.3(c)(3) states that technology based treatment requirements may be imposed through one of the following three methods:

1. Application of EPA-promulgated effluent limits developed under CWA 304 to dischargers by category or subcategory.
2. On a case-by-case basis under CWA 402, to the extent that EPA-promulgated effluent limits are inapplicable.
3. Through a combination of the methods in 1 and 2.

When establishing case-by-case effluent limits using BPJ, the approach selected and how the limit upholds CWA and IPDES regulations will be clearly documented in the fact sheet.

2.2.3.2 Identify Need for Case-by-Case TBELs

As noted above, case-by-case TBELs are established in situations where EPA-promulgated effluent guidelines are inapplicable. That includes situations such as the following:

- When EPA has not yet promulgated effluent guidelines for the point source category to which a facility belongs (e.g., a facility that produced distilled and blended liquors [SIC code 2085] and is part of the miscellaneous foods and beverages category, which does not have any applicable effluent guidelines).
- When effluent guidelines are available for the industry category, but no effluent guidelines are available for the facility subcategory (e.g., discharges from coalbed methane wells are not now regulated by effluent guidelines; however, EPA considers the coalbed methane industrial sector as a potential new subcategory of the existing Oil and Gas Extraction point source category [Part 435] because of the similar industrial operations performed [i.e., drilling for natural gas extraction]).
- When effluent guidelines are available for the industry category but are not applicable to the IPDES permit applicant (e.g., facilities that do not perform the industrial operation triggering applicability of the effluent guidelines or do not meet the production or wastewater flow cutoff applicability thresholds of the effluent guidelines).
- When effluent guidelines are available for the industry category, but no effluent guidelines requirements are available for the pollutant of concern (e.g., a facility is regulated by the effluent guidelines for Pesticide Chemicals [Part 455] but discharges a pesticide that is not regulated by these effluent guidelines). The permit writer will make sure that the pollutant of concern is not already controlled by the effluent guidelines and was not considered by EPA when they developed the effluent guidelines.

Generally, case-by-case limits are appropriate when at least one of the conditions listed above applies and the pollutant is present, or expected to be present, in the discharge in amounts that can be treated or otherwise removed (e.g., implementation of pollution prevention measures).

EPA periodically reviews existing and develops new effluent guidelines. EPA's effluent guidelines planning support documents are located on EPA's Effluent Guidelines Plan Website <<https://www.epa.gov/eg/effluent-guidelines-plan>>.

2.2.3.3 Factors Considered when Developing Case-by-Case TBELs

The regulations at 40 CFR 125.3(c)(2) establish the appropriate level of performance on a case-by-case basis considering:

- The appropriate technology for the category or class of point sources of which the applicant is a member, based on all available information.
- Any unique factors relating to the facility.

An evaluation for case-by-case limits, conducted by the permit writer, will consider the factors specified in 40 CFR 125.3(d), based on BPT, BCT, and BAT. The most stringent technology level of control will be selected for each pollutant of concern and incorporated into the permit.

Technical criteria for BPT, BCT, and BAT:

- Age of equipment and facilities involved
- Process(es) employed
- Engineering aspects of the application of various types of control techniques
- Process changes
- Non-water quality environmental impact including energy requirements

Economic criteria:

- BPT – The total cost of application of technology in relation to the effluent reduction benefits to be achieved from such application
- BCT – The reasonableness of the relationship between the costs of attaining a reduction in effluent and the derived effluent reduction benefits, and the comparison of the cost and level of reduction of such pollutants from the discharge of POTWs to the cost and level of reduction of such pollutants from a class or category of industrial sources
- BAT – The cost of achieving such effluent reduction

Example

Privately-owned treatment works treating domestic sewage

Problem: Private facility discharges to surface water. The facility is privately owned and does not qualify for POTW limits. Discharge contains pollutants (BOD₅, TSS, pH) from domestic sources that are equivalent to influent received in a small municipal wastewater treatment facility. There are no effluent guidelines for privately-owned treatment works treating domestic sewage.

Solution: Case-by-case assessment using BPJ identifies equivalence with POTW secondary treatment standards or performance requirements derived from submitted data (IDAPA 58.01.16.455.04). Establishing appropriate limits for BOD₅, TSS, and pH are done by evaluating the facility's performance level using technical and economic criteria found above for BPT and BCT. The BPJ analysis will reasonably defend the documentation through inclusion of statutory/regulatory citation, identification of which pollutants were assessed and by what TBEL, and how the technical/economic criteria influenced the final permit limit, if any.

As previously stated, technology-based controls in IPDES permits are performance-based measures. DEQ incorporates technology-based controls in IPDES permits that correspond to the application of an identified technology (including process changes) but does not require

dischargers to install the identified technology. Therefore, DEQ leaves to each facility the discretion to select the technology design or process changes necessary to meet the TBELs specified in the IPDES permit.

The permit may also establish a monitoring-only requirement in the current IPDES permit to identify pollutants of concern and potential case-by-case limits for the subsequent IPDES permit renewal.

2.2.3.4 Resources for Developing Case-by-Case TBELs

There are numerous resources for identifying candidates for model technologies or process changes and developing case-by-case TBELs using BPJ. The following references may be used to derive such limits:

Permit file information

- Current and previous IPDES application forms
- Previous permit and fact sheets
- DMRs
- Compliance inspection reports

Information from existing facilities and permits

- Individual and General Permits issued to facilities in the same region, or that include case-by-case limits for the same pollutants
- Toxicity reduction evaluations for selected industries
- Other media permit files (e.g., Resource Conservation and Recovery Act permit applications and Spill Prevention Countermeasure and Control plans)
- ICIS-NPDES data <https://www3.epa.gov/enviro/facts/pes-icis/search.html>
- Literature (e.g., technical journals and books)

Effluent guidelines development and planning information

- EPA's Effluent Guidelines <https://www.epa.gov/eg>
- EPA's Effluent Guidelines Plan <https://www.epa.gov/eg/effluent-guidelines-plan>
- EPA's Effluent Guidelines Program Contacts <http://www.epa.gov/eg/forms/contact-us-about-effluent-guidelines>

Economics guidance

- Protocol and Workbook for Determining Economic Achievability for NPDES Permits
BCT Cost Test Guidance

Guidance for BMP-based limitations

- Guidance Manual for Developing Best Management Practices (BMP)
- Storm Water Management for Industrial Activities: Developing Pollution Prevention Plans and BMPs (EPA 1993)
- National Menu of Best Management Practices (BMPs) for Stormwater
<https://www.epa.gov/npdes/national-menu-best-management-practices-bmps-stormwater#edu>

2.2.3.5 Statistical Considerations when Establishing Case-by-Case TBELs

The quality of the effluent from a treatment facility will normally vary over time. If, for example, BOD₅ data for a typical treatment plant were plotted against time, one would observe day-to-day variations of effluent concentrations. Some of that behavior can be described by constructing a frequency-concentration plot. From the plot, one could observe that for most of the time, BOD₅ concentrations are near some average value. Any treatment system can be described using the mean concentration of the parameter of interest (i.e., the long-term average [LTA]) and the variance (or coefficient of variation) and by assuming a particular statistical distribution (usually lognormal).

When developing a case-by-case limit, the permit writer will use an approach consistent with the statistical approach in EPA's analysis for developing national standards but performed by the permit writer for a single facility. EPA's Technical Support Document (TSD) may be used to provide statistical approaches for setting maximum daily limit and AML at an appropriate performance level based on expected LTA performance. Specifically, the maximum daily limit could be calculated by multiplying the LTA achievable by implementation of the model technology or process change by a daily variability factor determined from the statistical properties of a lognormal distribution. The AML can be calculated similarly except that the variability factor corresponds to the distribution of monthly averages instead of daily concentration measurements. The daily variability factor is a statistical factor defined as the ratio of the estimated 99th percentile of a distribution of daily values divided by the mean of the distribution. Similarly, the monthly variability factor is typically defined as the estimated 95th percentile of the distribution of monthly averages divided by the mean of the distribution of monthly averages.

For more details on EPA's use of statistical methods for developing effluent guidelines, refer to EPA's Effluent Guidelines website: <https://www.epa.gov/eg>.

2.2.3.6 Document Case-by-Case TBELs in the Fact Sheet

The case-by-case using BPJ determination should be defensible and reasonable. The reasonableness is demonstrated by documentation that:

- Identifies statutory and regulatory citations
- Establishes that case-by-case limits are appropriate and why effluent guidelines do not apply
- Identifies pollutant(s) for BPJ analysis and the performance level required by the CWA (i.e., BPT, BCT, or BAT)
- Lists each of the applicable criteria from 40 CFR125.3 and provide an explanation of how each was considered in the BPJ analysis

The information in the fact sheet will clearly state the rationale for a defensible description of how the BPJ limits comply with CWA and IPDES regulations.

3 Determining Water Quality-Based Effluent Limits (WQBELs)

Periodically, changes are proposed to Idaho's WQS. These changes must be approved by the Idaho Legislature and EPA. Therefore, it is critical that the permit writer understand when standards and regulations are applicable for use in composing a permit. The IPDES program will only use standards, regulations, and other surface water criteria (e.g. TMDLs) after they have received EPA approval.

WQBELs help meet the CWA objective of restoring and maintaining the chemical, physical, and biological integrity of the state's water and provide for the protection and propagation of fish, shellfish, and wildlife and recreation in and on the water (fishable/swimmable goal). When drafting an IPDES permit, a permit writer must consider the impact of the proposed discharge on the quality of the receiving water. Water quality goals for a water body are defined by Idaho WQS, which support the CWA. When analyzing the effect of a discharge on the receiving water, a permit writer may determine that TBELs alone will not prevent violations of applicable WQS. In such cases, 40 CFR 122.44(d) requires development of more stringent WQBELs.

3.1 Characterize the Effluent

The permit writer uses information from the permit application to identify pollutants that may be discharged by the facility and impact the receiving water. The permit writer then determines whether WQBELs are required, and if so, calculate WQBELs.

3.1.1 Identify Pollutants of Concern in the Effluent

There are several sources of information and methods of identifying pollutants of concern for WQBEL development that might result in a Reasonable Potential to Exceed (RPTE) a WQS (i.e., site visit, communication with facility staff, review monitoring history). Pollutants of concern are any pollutants or pollutant parameters that the permit writer has reason to believe are or may be discharged by the facility or could affect or alter the physical, chemical, or biological condition of the receiving water. These pollutants may not necessarily receive an effluent limit in an IPDES permit but do go through a RPA, described in Section 3.4.4. Pollutants of concern are not limited to those parameters covered by technology standards. The permit writer should consider the impact of the treatment processes and operations of the facility on the nature and variability of the effluent. Determining which pollutants are pollutants of concern is an iterative process; additional pollutants of concern may be identified during a review of applicable WQS and receiving water characterization. The following subsections identify the categories of pollutants of concern for WQBEL development.

3.1.1.1 Pollutants with Applicable TBELs

One category of pollutants of concern includes those pollutants for which the permit writer has developed TBELs based on national technology standards or on a case-by-case basis using BPJ. By developing TBELs for a pollutant, the permit writer has already determined that there will be some type of final limit for that pollutant in the permit and must then determine whether more stringent limits than the applicable TBELs are needed to prevent an excursion above WQS in the

receiving water. A permit writer can determine whether the TBELs are sufficiently protective by completing a RPA.

3.1.1.2 Pollutants with a TMDL WLA

Pollutants of concern include those pollutants for which a TMDL WLA has been assigned to a discharge, or any discharge containing the identified pollutant but that was erroneously omitted from the TMDL. A TMDL WLA, as applied here, refers to the portion of the receiving water body loading capacity that is allocated to one of its existing or future pollutant point sources. The TMDL WLA could be allocated through an EPA-approved TMDL or an EPA or state watershed loading analysis. The regulations at IDAPA 58.01.25.302.06.a.vii.2 require that permits include effluent limits developed consistent with the assumptions and requirements of any TMDL WLA.

A TMDL is a calculation of the maximum amount of a single pollutant that a water body can receive and still meet water quality standards. The TMDL may allocate an amount of the pollutant to the various pollutant sources discharging to the water body. These portions of the TMDL assigned to point sources are WLAs, and the portions assigned to nonpoint sources and background concentrations of the pollutant are called load allocations (LAs). The calculation must include a margin of safety to ensure that the water body can be used for the purposes designated in the WQS, to provide for the uncertainty in predicting how well pollutant reduction will result in meeting WQS, and to account for seasonal variations. A TMDL might also include a reserve capacity to accommodate expanded or new discharges in the future.

3.1.1.3 Pollutants Identified as Needing WQBELs in the Previous Permit

Another category of pollutants of concern includes those pollutants that were identified as needing WQBELs in the discharger's previous permit. Permit writers must determine whether the conditions leading to a decision to include WQBELs for the pollutant in the previous permit continue to apply. Where those conditions no longer apply, the permit writer would need to complete an anti-backsliding analysis to determine whether to make the WQBELs less stringent than the previous permit. Section XX illustrates how anti-backsliding requirements are applied to the permit development process.

3.1.1.4 Pollutants Identified as Present in the Effluent through Monitoring

Pollutants of concern also include any pollutants detected in the effluent. Effluent monitoring data are reported in the discharger's IPDES permit application, DMRs, annual reports, and special studies. Whole effluent toxicity (WET) testing and expanded effluent monitoring may be required of POTWs to determine effluent toxicity or pollutants of concern. Additionally, DEQ may collect data through compliance biomonitoring and/or sampling inspections or other special studies. Permit writers can match information on which pollutants are present in the effluent to the applicable WQS to identify parameters that are candidates for WQBELs.

3.1.1.5 Pollutants Otherwise Expected to be Present in the Discharge

Another category of concern includes those pollutants that are not in one of the other categories but are otherwise expected to be present in the discharge. There might be pollutants for which neither the discharger nor DEQ have monitoring data, but because of raw materials stored or used, products or by-products of the facility operation, or available data on similar facilities, the permit writer has a strong basis for expecting the pollutant to be present in the discharge. The

permit writer should require the discharger to provide effluent monitoring data, or base the determination for WQBELS on other information, such as effluent characteristics of a similar discharge. Further detail on what to do if data is not available is discussed in Section 3.4.4.1.

3.1.2 Identify Effluent Critical Conditions

Identifying the right effluent critical conditions is important for appropriately applying a water quality model to assess the need for WQBELs and to calculate WQBELs. The process to determine the appropriate water quality model and the variables associated with the calculation are presented in Section 3.4.3.13. The effluent critical conditions, which will be used in the calculation, are summarized in Sections 3.1.2.1 and 3.1.2.2. Receiving water critical conditions are presented in Section 3.2.

3.1.2.1 Effluent Flow

Effluent flow is a critical design condition used when modeling the discharge's impact on receiving water. A permit writer can obtain effluent flow data from DMRs or a permit application. IDAPA 58.01.25 specifies which flow measurement(s) to use as the critical effluent flow value(s) in various water quality-based permitting calculations (e.g., the facility design flow, the maximum daily flow reported on the permit application, or the maximum of the monthly average flows from DMRs for the past 3 years). The calculations will use either the production flow or the design flow rate.

3.1.2.2 Effluent Pollutant Concentration

Permit writers can determine the pollutant of concern's critical effluent concentration by gathering effluent data representative of the discharge. In most cases, permit writers have a limited effluent data set and no definitive way to determine that the data actually include the pollutant of concern's maximum potential effluent concentration. EPA's TSD provides guidance on how to statistically characterize pollutant concentrations for toxic pollutants from a limited data set and appropriately account for variability.

From studies of effluent data from numerous facilities, EPA determined that daily pollutant measurements follow a lognormal distribution. The TSD procedures allow permit writers to project a critical effluent concentration from a limited dataset using statistical procedures based on the characteristics of the lognormal distribution ([see the User's Guide Volume 1 – section 12](#)). These procedures use the number of effluent data points for the measured concentration of the pollutant and coefficient of variation (CV) of the data set, which is a measure of the variability of data around the average, to predict the critical pollutant concentration in the effluent.

The TSD recommends a CV of 0.6 for data sets with fewer than 10 data points. Data sets of more than 10 data points provide a sufficient level of certainty to calculate a standard deviation and mean with confidence. The resulting CV may be different from the 0.6 default recommended in the TSD (Equation 9).

$$CV = \frac{\text{Standard Deviation}}{\text{Mean}}$$

Equation 9. CV calculation.

3.2 Characterize Receiving Water Critical Conditions

After identifying pollutants of concern in effluent critical conditions, a permit writer should characterize the receiving water. The permit writer uses the information from those characterizations and the WQS in Section 3.3 to determine whether WQBELs are required and, if so, to calculate WQBELs (Section 3.4).

3.2.1 Receiving Water Upstream Flow

For rivers and streams, an important critical condition is the stream flow upstream of the discharge. The applicable critical flow statistic is specified in the WQS and reflects the duration and frequency components of the water quality criterion that is being addressed. WQBELs and mixing zones for toxic substances are based on the receiving water low flow conditions identified in Table 18.

Table 18. Receiving water low flow design conditions for reasonable potential analysis and effluent limit development.

Criteria Type	Use Designation	Flow Statistic	Flow Description
Acute	Aquatic Life	1Q10	Lowest one-day flow with an average recurrence frequency of once in 10 years
		1B3	Biologically based flow indicating an allowable exceedance once every 3 years
Chronic	Aquatic Life	7Q10	Lowest seven consecutive day low flow with an average recurrence frequency of once in 10 years
		4B3	Biologically based flow indicating an allowable exceedance for 4 consecutive days once every 3 years
Human Health (carcinogens)	Contact Recreation Domestic Water Supply	Harmonic Mean Flow	Long term mean flow value calculated by dividing the number of daily flows analyzed by the sum of the reciprocals of those daily flows
Human Health (noncarcinogens) ^a	Contact Recreation Domestic Water Supply	30Q5	Lowest 30 consecutive day low flow with an average recurrence frequency of once in 5 years
		Or Harmonic Mean Flow	Long term mean flow value calculated by dividing the number of daily flows analyzed by the sum of the reciprocals of those daily flows (If the effects from certain noncarcinogens are manifested after a lifetime of exposure, then a harmonic mean flow may be appropriate.)

a. The 30Q5 low flow is specified in IDAPA 58.01.02.210.03.b. However as of October 2016, this element of Idaho's water quality standards was removed and replaced with the harmonic mean flow, this change has not been approved by EPA for Clean Water Act purposes.

The permit writer might examine hydrologic stream flow data from the U.S. Geological Survey (USGS) or other credible flow measurements to determine the critical flow at a point upstream of the discharge. Other methods to estimate low flow at ungauged locations may be used, such as USGS StreamStats <http://water.usgs.gov/osw/streamstats/>. The permit writer might also account for any additional sources of flow or diversions between the point where a critical low flow has been calculated and the point of discharge. EPA also has developed a biologically based flow method that directly uses the durations and frequencies specified in the water quality criteria (e.g., 1B3 and 4B3).

For most pollutants and criteria, the critical flow in rivers and streams is some measure of the low flow of that river or stream; however, the critical condition could be different (for example, a high flow, where wet weather sources are a major problem). If a discharge is controlled so that it does not cause water quality criteria to be exceeded in the receiving water at the critical flow condition, the discharge controls should be protective and ensure that water quality criteria, and thus designated uses, are attained under all receiving water flow conditions.

The water body will be considered non-flowing when the receiving water body has a mean detention time longer than 15 days. DEQ will assess non-flowing water bodies on a case-by-case basis. Volume 2 of the User's Guide provides additional information on situations where the receiving water body is designated non-flowing.

3.2.2 Receiving Water Upstream Pollutant Concentration

DEQ also needs the critical upstream concentration in the receiving water to ensure that any pollutant limits derived protect the beneficial uses and support the antidegradation policy and implementation. When available, ambient data provide the most reliable receiving water background pollutant characterization. When data are not available, DEQ may include ambient monitoring requirements in the permit conditions, along with a reopener clause. When data are not available but are being collected, ambient monitoring requirements and the availability of mixing would be determined on a case-by-case basis dependent on the potential risk to beneficial uses (sensitivity of uses and quality of effluent).

3.2.3 Other Receiving Water Characteristics

For water bodies other than free-flowing rivers and streams, there might be critical environmental conditions that apply rather than flow (e.g., water level fluctuation, temperature). In addition, depending on the pollutant of concern, the effects of biological activity and reaction chemistry might be important in assessing the impact of a discharge on the receiving water. In such situations, additional critical receiving water conditions consistent with WQS are used in a water quality model including conditions such as pH, temperature, hardness, or reaction rates, and the presence or absence of certain fish species or life stages of aquatic organisms. Section 3.4.3.13 provides further discussion of how critical conditions are applied in a water quality model to determine the need for and calculate WQBELs.

3.3 Determine Applicable Water Quality Standards (WQS)

The CWA requires states to develop and, from time to time, revise WQS. The Idaho Water Quality Standards Program is a joint effort between DEQ and EPA. EPA develops recommended criteria, regulations, policies, and guidance consistent with the requirements of the CWA. DEQ

may adopt and enforce EPA's recommendations directly or modify them to fit state-specific conditions to protect beneficial uses. EPA has authority to review, and approve or disapprove state standards, and to promulgate federal water quality rules if it finds the state is not meeting the requirements of the CWA.

WQS define water quality goals and pollutant limits that support propagation of fish, shellfish and wildlife, and recreation in and on the water. In establishing standards, DEQ must consider the use and value of waters for public water supplies, propagation of fish and wildlife, recreation, agriculture, industry, and navigation.

DEQ's WQS are published in IDAPA 58.01.02. The WQS designate the uses that are protected for each water body. These standards are the basis for restrictions placed on the discharge of wastewater and on human activities that may adversely affect public health and water quality. When developing an IPDES permit, the permit writer must identify and use EPA-approved WQS applicable to the receiving water body.

WQS are comprised of three components:

- Beneficial uses—ways in which humans and animals use the water
- Water quality criteria—specify the water quality required to protect beneficial uses (numeric or narrative)
- Antidegradation—a policy designed to maintain and protect water quality

These components are described in the sections that follow.

3.3.1 Beneficial Uses

Water bodies are assigned beneficial uses based on their expected or current uses. From IDAPA 58.01.02.100, beneficial uses are any of the various uses for which citizens utilize the state's waters, including, but not limited to:

- Aquatic life
- Recreation (primary contact, secondary contact)
- Water supply (domestic, agricultural, and industrial)
- Wildlife habitats
- Aesthetics

The CWA also requires Idaho to recognize existing uses, which are uses attained in a water body on or after November 28, 1975, whether or not they are designated uses. While a water body may have competing beneficial uses, the CWA requires DEQ to protect the most sensitive use.

In some cases, a water body does not have designated uses. For these water bodies, DEQ applies a presumed use protection, meaning the water body will be protected for cold water aquatic life and contact recreation. DEQ must also consider and ensure the attainment and maintenance of the water quality standards of downstream waters when establishing designated uses. Designated and presumed uses apply unless a use attainability analysis (UAA) is conducted by DEQ and approved by EPA. Existing uses cannot be removed.

Permit writers should consider whether a water body is supporting its designated beneficial uses when identifying any additional pollutants of concern in the effluent. Permit writers will check the most current Integrated Report and confer with the regional office assessment coordinators to

determine the beneficial use support status of the receiving water and any downstream assessment units that may be impacted by the discharge. DEQ may consider monitoring requirements to collect additional data related to the presence or absence of the impairing pollutant in a specific discharge to provide information for further analyses.

Under CWA section 303(d), states are required to develop lists of impaired waters. Impaired waters are those that do not meet the WQS set for them, even after point sources of pollution have installed the minimum required levels of pollution control technology. The law requires that those jurisdictions establish priority rankings for water on their CWA section 303(d) list and develop TMDLs for those waters.

DEQ may consider any pollutant associated with an impairment (DEQ 2015) of the receiving water a pollutant of concern in permit development, regardless of whether an approved TMDL has been developed for that pollutant, a TMDL WLA has been assigned to the facility, or the permitted facility has demonstrated that the pollutant is present in its effluent.

3.3.2 Water Quality Criteria

Water quality criteria are scientifically determined parameters or pollutants that are sufficiently supportive of the water body's designated uses. These can include both numeric and narrative criteria. Numeric water quality criteria are developed for specific parameters to protect wildlife, aquatic life, and human health from pollutants' deleterious effects. DEQ has established narrative criteria where numeric criteria cannot be established or to supplement numeric criteria. As new or revised numeric and narrative criteria are developed the RPA and effluent limit development will comply with EPA-approved criteria. Criteria and calculations identified below are examples based on WQS effective in 2017. **Please reference current WQS to ensure calculations are using the most current criteria.**

3.3.2.1 Numeric Criteria—Aquatic Life

Numeric criteria for aquatic life use designations are designed to protect aquatic organisms, including both plants and animals. Aquatic life criteria address both short-term (acute) and long-term (chronic) effects on species. Each of these criteria typically consists of three components:

- **Magnitude:** The level of pollutant or pollutant parameter, usually expressed as a concentration, that is allowable.
- **Duration:** The period (averaging period) over which the in-stream concentration is averaged for comparison with criteria concentrations.
- **Frequency:** How often criteria may be exceeded.

Most Idaho numeric criteria developed to support aquatic life use the 1-hour duration for criterion maximum concentrations (CMC – acute) and the 4-day duration for criterion continuous concentrations (CCC – chronic). An exception is ammonia. Ammonia criteria use 1-hour CMC and 30-day CCC durations.

Below is an example of freshwater aquatic life criteria for chlorine (IDAPA 58.01.02.210):

- CMC—The maximum instantaneous or one (1) hour average concentration of total residual chlorine (TRC) may not exceed 19 µg/L more than once every three (3) years.
- CCC—The four (4) day average concentration of TRC may not exceed 11 µg/L more than once every three (3) years.

Idaho WQS also include aquatic life criteria for parameters such as temperature, pH, and dissolved oxygen that differ from other chemical pollutants. Temperature criteria are expressed as both absolute temperature values (e.g., temperature may not exceed 22 degrees Celsius [$^{\circ}\text{C}$]) and restrictions on causing changes in temperature in the water body (e.g., temperatures in lakes shall have no measureable change from natural background conditions). Criteria for pH are expressed as an acceptable pH range (6.5-9.0 s.u.) in the water body. DEQ's dissolved oxygen WQS include both minimum concentrations and percent oxygen saturation that must be maintained.

Where no specific numeric aquatic life criteria have been established for a pollutant, permit writers should address the pollutant using narrative criteria for hazardous materials and toxics from IDAPA 58.01.02.200. This includes performing an RPA for whole effluent toxicity (WET). Subsequently, WET monitoring and development of appropriate WET effluent limits will appear in the permit, if appropriate, and be documented in the fact sheet.

3.3.2.1.1 Calculating Metals and Ammonia Criteria

Several commonly monitored metals and ammonia have criteria that are expressed as equations which account for the effects of other environmental conditions on toxicity. To determine whether a criterion is met, the permit writer must not only have the results of ambient and/or effluent monitoring for the pollutant of concern, but must also have access to information specific to the monitoring site and period. Criteria and calculations identified below are examples based on WQS effective in 2017. **Please reference current WQS to ensure calculations are using the most current criteria.**

Calculation spreadsheets are available on the DEQ web page to calculate criteria values for metals and ammonia; <http://www.deq.idaho.gov/water-quality/surface-water/water-quality-criteria/>.

If concurrent hardness, pH, or temperatures are not available, the permit writer may use typical values, if known, for the water body in question for the period of interest. Whether or not typical values are used or monitoring data is used, the assumptions concerning these values must be documented in the fact sheet.

Metals

One factor which impacts metal criteria is known as the water effects ratio (WER). The WER is the ratio of the WET test toxicity to aquatic life when solutions composed with receiving water are compared to solutions of laboratory dilution water. The WER has a value of 1 unless a site-specific criterion has been developed **by DEQ and submitted to** and approved by EPA. Arsenic and chromium VI have modifying coefficients listed in the table at IDAPA 58.01.02.210.01.

Also consider hardness dependent metals (cadmium, chromium (III), copper, lead, nickel, silver, and zinc), which are calculated using hardness, standard coefficients, and conversion factors, and the WER. The aquatic life criteria are a function of total hardness (mg/L as calcium carbonate), the pollutants' WER (IDAPA 58.01.02.210.03.c.iii) and are multiplied by an appropriate conversion factor as defined in IDAPA 58.01.02.210.02. The WQS (IDAPA 58.01.02.210.02) includes a table with coefficients and conversion factors. Hardness dependent metals criteria are calculated using values from this table using Equation 10 and Equation 11:

$$\text{CMC} = \text{WER} \exp(mA[\ln(\text{hardness})] + bA) \times \text{Acute Conversion Factor}$$

Equation 10. Calculation for hardness dependent metals criteria (acute).

$$\text{CCC} = \text{WER} \exp(mc[\ln(\text{hardness})] + bc) \times \text{Chronic Conversion Factor}$$

Equation 11. Calculation for hardness dependent metals criteria (chronic).

Where:

WER = Water Effects Ratio (IDAPA 58.01.02.210.03.c.iii)

exp = base e exponential function

mA = slope of the acute regression line

ln hardness = natural log of total hardness (mg/L as calcium carbonate)

bA = y-intercept of the acute regression line

Acute Conversion Factor = total to dissolved conversion factor

mc = slope of the chronic regression line

bc = y-intercept of the chronic regression line

Chronic Conversion Factor = total to dissolved conversion factor

The acute and chronic conversion factors for cadmium and lead need to be calculated with Equation 12–Equation 14:

$$\text{Cadmium Acute CF} = 1.136672 - [(\ln \text{hardness})(0.041838)]$$

Equation 12. Acute conversion factor calculation for cadmium.

$$\text{Cadmium Chronic CF} = 1.101672 - [(\ln \text{hardness})(0.041838)]$$

Equation 13. Chronic conversion factor calculation for cadmium.

$$\text{Lead (acute and chronic) CF} = 1.46203 - [(\ln \text{hardness})(0.415712)]$$

Equation 14. Acute and chronic conversion factor calculation for lead.

Hardness dependent metal calculation considerations:

- Hardness used for metals criteria calculation must not be less than 25 mg/L as calcium carbonate (IDAPA 58.01.02.210.03.c.i) for metals other than cadmium.
- For cadmium, hardness used for criteria calculation must not be less than 10 mg/L as calcium carbonate, except as specified in 210.03.c.ii and 210.03.c.iii (IDAPA 58.01.02.210.03.c.i).
- Maximum hardness allowed in criterion calculation equations shall not be greater than 400 mg/L as calcium carbonate, except as specified in 210.03.c.ii and 210.03.c.iii (IDAPA 58.01.02.210.03.c.i).

The cold water aquatic life for cadmium, with a receiving water hardness of 10 mg/L calcium carbonate use Equation 10 and Equation 11, respectively:

$$\text{CMC} = \text{WER} \exp(mA[\ln \text{hardness}] + bA) \times 1.136672 - [(\ln \text{hardness})(0.041838)] = 0.20 \mu\text{g/L}$$

$$\text{CCC} = \text{WER} \exp(mc[\ln \text{hardness}] + bc) \times 1.101672 - [(\ln \text{hardness})(0.041838)] = 0.15 \mu\text{g/L}$$

There may also be site-specific criteria (see section 3.3.2.4) that apply to select water bodies. The permit writer needs to work closely with the WQS staff to make sure that applicable criteria are being used in the analysis and calculations.

Ammonia

The magnitude of other aquatic life criteria can vary according to other conditions in the water or even based on the presence or absence of certain aquatic life. For example, Idaho's ammonia criteria address magnitude, frequency, and duration as well as variation due to pH, temperature, the presence or absence of salmonid species, and the presence or absence of early life stages of fish. Below are the IDAPA 58.01.02.250.02.d criteria for ammonia to support cold water aquatic life with and without fish early life stages present:

- CMC—The one (1) hour average concentration of total ammonia nitrogen (in mg N/L) is not to exceed the value calculated using Equation 15 **more than once every three (3) years**:

$$\text{CMC} = \frac{0.275}{1+10^{7.204-pH}} + \frac{39.0}{1+10^{pH-7.204}} \quad \text{Equation 15. Calculation for ammonia criteria (acute).}$$

Where: pH = 95th percentile of pH in the receiving water upstream from the discharge.

- CCC—The thirty (30) day average concentration of total ammonia nitrogen (in mg N/L) is not to exceed the value calculated using Equation 16 and Equation 17 more than once every three (3) years:

When fish early life stages are likely present:

$$\text{CCC} = \left(\frac{0.0577}{1+10^{7.688-pH}} + \frac{2.487}{1+10^{pH-7.688}} \right) \times \text{MIN} (2.85, 1.45 \times 10^{0.028 \times (25-T)})$$

Equation 16. Calculation for ammonia criteria (chronic, early life stages present).

Where:

pH = 95th percentile of pH in the receiving water upstream from the discharge

T = 95th Percentile of the ambient upstream receiving water temperature

MIN = the smallest value from the data set

When fish early life stages are likely absent:

$$CCC = \left(\frac{0.0577}{1+10^{7.688-pH}} + \frac{2.487}{1+10^{pH-7.688}} \right) \times (1.45 \times 10^{0.028 \times (25-T)})$$

Equation 17. Calculation for ammonia criteria (chronic, early life stages absent).

Where:

pH = 95th percentile of pH in the receiving water upstream from the discharge

T = 95th Percentile of the ambient upstream receiving water temperature

For example, using Equation 15, where pH is 7.0 and temperature is 10.0°C, the cold water aquatic life ammonia criteria are:

$$CMC = \frac{0.275}{1+10^{7.204-7.0}} + \frac{39.0}{1+10^{7.0-7.204}} = 24 \text{ mg N/L}$$

Using Equation 16, when early life stages are likely present:

$$CCC = \left(\frac{0.0577}{1+10^{7.688-7.0}} + \frac{2.487}{1+10^{7.0-7.688}} \right) \times \text{MIN} (2.85, 1.45 \times 10^{0.028 \times (25-10)}) = 5.9 \text{ mg N/L}$$

Using Equation 17, when early life stages are likely absent:

$$CCC = \left(\frac{0.0577}{1+10^{7.688-7.0}} + \frac{2.487}{1+10^{7.0-7.688}} \right) \times (1.45 \times 10^{0.028 \times (25-10)}) = 7.9 \text{ mg N/L}$$

3.3.2.1.2 Special Considerations for Temperature Numeric Criteria

Idaho revised its WQS Point Source Wastewater Treatment Requirements (IDAPA 58.01.02.401) in 2012 to remove the numeric limits on point source induced changes in receiving water temperature unless more stringent limits are necessary to meet the applicable requirements of IDAPA 58.01.02.200 through 300, or unless specific exemptions are made pursuant to IDAPA 58.01.02.080.02. EPA has not yet approved or disapproved this WQS revision. Until EPA’s final decision, prior EPA-approved treatment requirements apply.

Water Quality Standards. 2011. IDAPA 58.01.02.401:

- 01. Temperature.** The wastewater must not affect the receiving water outside the mixing zone so that: (7-1-93)
 - a.** The temperature of the receiving water or of downstream waters will interfere with designated beneficial uses. (7-1-93)
 - b.** Daily and seasonal temperature cycles characteristic of the water body are not maintained. (7-1-93)
 - c.** If the water is designated for warm water aquatic life, the induced variation is more than plus two (+2) degrees C. (3-15-02)
 - d.** If the water is designated for cold water aquatic life, seasonal cold water aquatic life, or salmonid spawning, the induced variation is more than plus one (+1) degree C. (3-15-02)
 - e.** If temperature criteria for the designated aquatic life use are exceeded in the receiving waters upstream of the discharge due to natural background conditions, then Subsections 401.01.c. and 401.01.d. do not apply and instead wastewater must not raise the receiving water temperatures by more than three tenths (0.3) degrees C. (4-11-06)

3.3.2.2 Numeric Criteria—Human Health

Human health criteria for toxic pollutants are designed to protect people from exposure due to consumption of fish or other aquatic organisms, or from consumption of both water and aquatic

organisms. Human health chronic criteria are based on lifetime exposure and express the highest concentrations of a pollutant that are not expected to pose significant long-term risk to human health. Other criteria for human health protection (e.g., bacteria criteria) consider a shorter-term exposure through water body use such as contact recreation. All Idaho human health numeric chemical criteria are based on an annual harmonic mean and are not to be exceeded.

Human health criteria for toxic pollutants are derived by considering the dose of a pollutant that is ingested by humans. The criteria are based on a human health reference dose; a relative source contribution; a human body weight (BW) (for adults); a drinking water volume of 2.4 L/day; and a fish consumption rate for the target population.

Not all toxic substances have acute, chronic, and human health criteria. Furthermore, many toxic substances do not have numeric criteria. Where no specific numeric human health criteria have been established for a pollutant, permit writers should address the pollutant using narrative criteria for hazardous materials and toxics from IDAPA 58.01.02.200.

3.3.2.3 Narrative Criteria

DEQ WQS also include narrative water quality criteria to supplement numeric criteria. Narrative criteria are statements that describe the desired water quality goal for a water body. Narrative criteria, for example, require that surface water be “free from hazardous materials in concentrations found to be of public health significance or to impair designated beneficial uses” or “free from toxic substances in concentrations that impair designated beneficial uses.” DEQ’s narrative criteria are outlined in 58.01.02.200 – General Surface Water Quality Criteria.

Considerations for WET

WET tests are used to determine compliance with the narrative criteria for hazardous and toxic substances (IDAPA 58.01.02.200.01 and 200.02, respectively). If the facility meets at least one of the following conditions they are required to implement WET testing:

- The facility is a POTW with a flow greater than or equal to 1 mgd;
- The facility is a POTW that receives effluent from any industry identified in 40 CFR 403;
- The facility uses, stores, produces, or transfers any hazardous substance listed in 40 CFR 302.4 with a statutory code of 1 (CWA 311(b)(2)) or 2 (CWA 307(a));
- The facility’s effluent contains any toxic pollutant listed in Appendix D of 40 CFR Part 122 for which there are no water quality criteria for aquatic life protection listed in 40 CFR 131.36(b)(1);
- The facility belongs to an industrial category identified in 40 CFR 122, Appendix A (NPDES Primary Industry Categories);
- The facility exceeded acute or chronic WET standards within the last 5 years;
- The facility’s effluent is suspected to be toxic because of apparent damage to aquatic life in the receiving water; or
- DEQ determines that the facility has the potential to discharge toxics in toxic amounts.

If it is necessary to include WET effluent limitations or monitoring requirements in a permit, WET will be quantified using toxic units. A toxic unit (TU) is the reciprocal of the percentage of effluent that causes a specific measured acute or chronic endpoint. Acute toxic units (TU_a) and chronic toxic units (TU_c) can be calculated as follows:

$$TU_a = 100/LC_{50}$$

$$TU_c = 100/NOEC, 100/IC_{25}, \text{ or } 100/LOEC$$

WET tests account for the toxicity of unknown pollutants as well as synergistic or antagonistic effects among the pollutants. These laboratory tests involve exposing representative aquatic organisms to various dilutions of effluent under specific conditions. The response of these organisms is used to quantify the toxicity of the aggregate effluent. Various responses, or endpoints, can be used to quantify toxicity, all based on the WET test dilution series (Section 3.6.1.1). For example, the lethal effluent dilution concentration in-at which 50% of the test organisms die, known as lethal concentration 50, or LC₅₀, is a commonly used endpoint for acute toxicity. Commonly used endpoints for chronic toxicity tests include the no observed effects concentration (NOEC), the lowest observed effects concentration (LOEC), and the inhibition concentration (IC_x).

If it is necessary to include WET effluent limitations or monitoring requirements in a permit, WET will be quantified using toxic units. A toxic unit (TU) is the reciprocal of the percentage of effluent that causes a specific measured acute or chronic endpoint. Acute toxic units (TU_a) and chronic toxic units (TU_c) can be calculated as follows:

$$TU_a = 100/LC_{50}$$

$$TU_c = 100/NOEC, 100/IC_{25}, \text{ or } 100/LOEC$$

Typically, Idaho's narrative criterion for toxics is interpreted to mean TU_a = 0.3 and TU_c = 1, where LC₅₀ is expressed as a percentage of effluent used in the WET test. For example, in the case of acute testing, if a solution using 50% of the effluent causes half (or 50%) of the tested organisms to die (LC₅₀) then TU_a = 100/50 = 2. The numeric interpretations are used in the RPA and in developing WQBELs when necessary.

Considerations for Dissolved Oxygen

Narrative criteria for dissolved oxygen require that surface waters be free from oxygen demanding materials in concentrations that would result in anaerobic water conditions. The narrative criteria are addressed in unison with numeric dissolved oxygen criteria by modeling dissolved oxygen concentrations and limiting discharges of oxygen-demanding pollutants such as BOD, COD, and nutrients (phosphorus and nitrogen).

Considerations for Nutrients

DEQ has not adopted numeric criteria for nutrients as part of its WQS. Therefore, DEQ needs to determine appropriate nutrient effluent concentrations based on the assimilative capacity of the receiving water and may consider use of criteria recommended by EPA or used in states with similar environmental conditions in RPA evaluations.

3.3.2.4 Site-Specific Water Quality Criteria Implementation

DEQ's water quality criteria may not always reflect the toxicity of a pollutant in a specific water body. Therefore, IDAPA 58.01.02.275 allows development of new water quality criteria or

modification of existing criteria that will effectively protect designated and existing beneficial uses in certain water bodies as a result of site-specific analyses. As with all water quality criteria, site-specific criteria must be based on sound scientific principles to protect the beneficial use. Site-specific criteria are subject to EPA review and approval prior to use for CWA purposes, including IPDES permits.

A permit writer should review IDAPA 58.01.02.276-299 for site specific criteria applicable to the receiving water and verify that the applicable standard has been approved by EPA. Site specific criteria supersede IDAPA 58.01.02.210, 250, 251, 252, and 253 for water bodies and pollutants specified in these sections. Site specific criteria in the WQS that are approved by EPA include dissolved oxygen standards for waters discharged from dams, reservoirs and hydroelectric facilities, and metals, WER, ammonia, dissolved oxygen, and temperature criteria for specified water bodies in Idaho.

3.3.2.5 Variances and Intake Credits

The CWA and state regulations provide limited mechanisms for variances, waivers, and intake credits from requirements. An IPDES permit applicant must meet very specific data and application deadline requirements before a variance, waiver, or intake credit may be granted. These mechanisms provide a unique exception to particular requirements, and no expectation to receive a similar permit condition should be assumed by the permittee or applicant. Table 19 explains the available variances and intake credits for dischargers.

Table 19. Available variances and intake credits for IPDES permits.

Request Type	Eligible	CWA	Regulation	Application Deadline ^a	Granting Authority ^b
Thermal discharge	All	316(a)	IDAPA 58.01.25.310 40 CFR 125.70–73	By close of the draft permit comment period if based on a WQBEL.	DEQ
Water quality standards	All	N/A	IDAPA 58.01.02.260 40 CFR 131.10(g)(1)–(6)	With a permit application (not specified in rules, necessary to ensure timely permit issuance).	DEQ ^c
Intake credits	All	N/A	IDAPA 58.01.25.303.07	By close of the draft permit comment period.	DEQ

a. Permittees are advised to contact DEQ 1 year in advance if considering applying for a variance. The 180-day requirement to submit a complete application for a new permit or permit renewal may not be sufficient to also complete a variance and receive EPA approval. Dischargers must submit all requests to DEQ.

b. Any approved variance or intake credit is effective for up to 5 years or the life of the IPDES permit. After 5 years or the permit expiration, the discharger must meet the standard or must reapply for the variance or intake credit. In considering a reapplication, DEQ requires the discharger to demonstrate reasonable progress toward meeting the standard. DEQ’s decisions may be appealed to the Board of Environmental Quality.

c. Variance from water quality standards—EPA must approve all changes to water quality standards, including variances from water quality standards.

The options listed above and the factors considered in a technical review are explained in the IPDES User’s Guide Volume 1, Section 8 (DEQ 2016).

3.3.3 Antidegradation

Maintaining water quality above the minimums set by water quality criteria is a primary objective of the CWA. Each state is required to adopt an antidegradation policy as part of its WQS. DEQ's antidegradation policy is defined at IDAPA 58.01.02.051 and outlines the framework to be used in making decisions about proposed activities that will result in changes to water quality. The draft Idaho Antidegradation Implementation Procedures (DEQ draft 2017) are aimed at maintaining the existing quality of Idaho waters.

Effluent limits included in IPDES permits must be consistent with Idaho's antidegradation policy, which establishes three tiers of water quality protection. DEQ's antidegradation policy provides three levels of protection from degradation of existing water quality:

- **Maintenance of Existing Uses for All Waters (Tier I Protection)**—Existing instream water uses and the level of water quality necessary to protect the existing uses shall be maintained and protected in all water bodies (IDAPA 58.01.02.051.01). Where an existing use is established, it must be protected even if it is not listed in the WQS as a designated use. Tier I requirements apply to all surface waters.
- **High Quality Waters (Tier II Protection)**—Where the quality of the water exceeds levels necessary to support propagation of fish, shellfish and wildlife and recreation in and on the water, that quality shall be maintained and protected. Water quality may be lowered in Tier II waters but only after public review of the necessity for degradation based on the social and economic importance of the activity. In no case may water quality be lowered to a level that would interfere with existing or designated uses. (IDAPA 58.01.02.051.02).
- **Outstanding Resource Waters (Tier III Protection)**—Where an outstanding resource water has been designated by the legislature, that water quality shall be maintained and protected from the impacts of point and nonpoint source activities. Idaho does not currently have any designated outstanding resource waters. (IDAPA 58.01.02.051.03).

The objective of antidegradation is achieved by reviewing discharge permits for their effect on water quality. If the water receiving the discharge is Tier II, proposed degradation in water quality is evaluated closely to determine if it can be minimized or avoided. If significant degradation cannot be avoided, then the activity is evaluated to determine if the activity is necessary and important to the social or economic health of the affected public.

3.4 Determine the Need for WQBELs

After characterizing the effluent and receiving water and determining the applicable WQS, the permit writer determines whether WQBELs are needed. When DEQ determines whether a discharge causes, has the reasonable potential to cause, or contributes to an in-stream excursion above WQS criteria (numeric or narrative), the permit writer develops WQBELs. These limits account for existing controls on pollution, the variability of the pollutants in the effluent, the sensitivity of species to toxicity, and the dilution of the effluent in the receiving water.

In developing WQBELs, permit writers should check to see if DEQ has developed guidance for the pollutants. They should also consider the appropriate tools to use for the pollutants and site-specific conditions (e.g., simple mass balance equation, Streeter-Phelps equation, a mixing zone model, water quality model, etc.).

3.4.1 Define Reasonable Potential

IPDES regulations require permit writers to assess the impact of discharges to evaluate downstream water quality. The permit must contain effluent limits in order to control all pollutants that have a reasonable potential to exceed water quality criteria. IDAPA 58.01.25.302.06.i states:

Effluent limitations in a permit must control all pollutants or pollutant parameters (either conventional, nonconventional, or toxic pollutants) which the Department determines are or may be discharged at a level which will cause, have the reasonable potential to cause, or contribute to an excursion above any water quality standard, including narrative criteria for water quality.

The regulation also specifies that the reasonable potential determination must apply not only to numeric criteria, but also to narrative criteria (e.g., no toxics in toxic amounts, presence of pollutants or pollutant parameters in amounts that would result in algal blooms).

An RPA is used to determine whether a discharge, alone or in combination with other sources of pollutants to a water body and under a set of conditions estimated through a series of reasonable assumptions, could lead to an excursion above applicable WQS. A permit writer can conduct RPA using effluent and receiving water data and modeling techniques, or using a non-quantitative approach. Both approaches are discussed below. The quantitative approach is discussed in the sections below. The non-quantitative approach is discussed in Section 3.4.4.1.

RPA is the basis for determining the need for and subsequently establishing WQBELs, which protect the receiving water and prevent violations of WQS. After completion, the RPA defines whether a pollutant has the reasonable potential to cause or contribute to an excursion above water quality standards.

3.4.2 Assess Critical Conditions

Before performing the RPA, the permit writer must compile data that reflects the critical conditions at the point of discharge. These include:

- Effluent critical conditions
 - Flow
 - Concentration of pollutant(s) of concern
- Appropriate mixing zone
- Receiving water critical conditions
 - Flow
 - Upstream pollutant concentration
 - Other receiving water characteristics as needed, including temperature, pH, or hardness

The effluent and receiving water critical conditions addressed in Sections 3.1 and 3.2 provide the background on how to select critical condition inputs and sources of information. After identifying the critical values, they will be used as inputs into the model to identify whether a RPTE exists for each of the pollutants at critical conditions.

Compounding conservative assumptions with each selection can result in critical conditions with a probability that it is unlikely or impossible to ever occur. Critical conditions should be carefully defined to examine a scenario that has reasonable potential to occur.

- Consider probabilistic approaches to evaluating RPA and calculating limits if needed. The TSD (EPA 1991) notes that this is a viable and in some situations preferable approach to the steady state approach, Monte Carlo modeling is one example.
- Use appropriate tools for evaluation (e.g., BLM for copper) and consider the differences in metals (dissolved and total) versus organics.

3.4.3 Establish an Appropriate Mixing Zone

Mixing zones may be considered when DEQ determines through the IPDES permitting process that WQBELs are necessary because a discharge does not meet WQS at end of pipe. Idaho WQS define a mixing zone as (IDAPA 58.01.02.010.61):

A defined area or volume of the receiving water surrounding or adjacent to a wastewater discharge where the receiving water, as a result of the discharge, may not meet all applicable water quality criteria or standards. It is considered a place where wastewater mixes with receiving water and not as a place where effluents are treated.

A mixing zone allows pollutants originating in the discharge to become diluted by the receiving water to ensure support of the water body's beneficial uses. The RPA must demonstrate reasonable potential for a discharge to cause or contribute to an exceedance of water quality criteria for the pollutant to be eligible for a mixing zone. In addition, the receiving water must have available assimilative capacity. Mixing zone configuration and terms are presented in Figure 4.

Mixing zones in non-flowing waters must be authorized using the percentage of the receiving water body's surface area. For new discharges the linear distance from the outfall must also be taken into account. DEQ has experience making this type of determination although the majority of discharges in Idaho are to flowing waters. Authorizing a new or expanded mixing zone in non-flowing waters will require careful consideration of the discharge, bathymetry, retention time, localized currents, receiving water beneficial uses, and other currently unidentified factors that may be uncovered.




Figure 4. Examples of mixing zones in flowing (top) and non-flowing (bottom) waters. ZID indicates the zone of initial dilution.

Where DEQ proposes to re-issue an IPDES permit with an existing mixing zone, the permit writer must determine whether the current mixing zone is the appropriate size. DEQ considers, at a minimum, the previous 5 years of effluent monitoring data to determine whether the existing mixing zone is still the appropriate size. The preferred approach is for DEQ to statistically evaluate facility performance data. The 95th percentile of the effluent data should be used to evaluate the appropriate mixing zone percentage. The mixing zone should be optimized to establish the minimum surface water volume and stream width or non-flowing water area, accompanied by an adjusted dilution factor. These parameters are optimized to the lowest percentage of dilution that would not result in RPTE at the edge of the mixing zone. At that point, the mixing zone may be authorized. Mixing zone percentages are rounded up to the

nearest whole number (e.g., analysis demonstrates a 9.05% mixing zone is necessary, the percent authorized should be 10%).

A larger mixing zone may be authorized where the discharger and DEQ agree after careful consideration of siting, technological, and managerial options available. These options include site-specific conditions, flexibility in treatment unit process options, other options the discharger may have, facility modification costs, and operational alternatives. Availability of funds will also be considered.

Because mixing zone modeling is typically based on a series of assumptions that are often tested and refined with water body specific data, DEQ may request the discharger provide additional information to assist in reviewing the appropriateness of the existing mixing zone. New mixing zone calculations are necessary if:

- Water quality criteria have been revised.
- Additional data is available for
 - Effluent quality or flow
 - Background water quality
 - Receiving water hydrodynamics

For mixing zones based on aquatic life criteria, DEQ will consider any biological data collected for the mixing zone to verify there are no adverse impacts on aquatic life outside the mixing zone.

The process for new permit development is shown in Figure 5.




Figure 5. Mixing zone process for new or reissued permit applications.

Federal regulations implementing the CWA and EPA guidance largely defer to the states in establishing specific requirements of mixing zone regulations. This section summarizes Idaho’s mixing zone rules. Table 20 is a cross-reference of where the mixing zone rules (IDAPA 58.01.02.060) and other mixing zone related sections of Idaho’s WQS are discussed in this guidance. Please see IDAPA 58.01.02.060 for mixing zone rule language.

To protect beneficial uses of a receiving water body, IDAPA 58.01.02.060 requires DEQ to determine on a case-by-case basis whether a mixing zone is authorized and, if applicable, a mixing zone’s size, configuration, and location.

Table 20. Cross-reference of IDAPA mixing zone rules and ELDG sections.

IDAPA Section	Regulatory Requirement	ELDG Guidance Section
58.01.02.010.61	Defines a mixing zone	3.4.3
58.01.02.060.01	Establishes that DEQ may authorize a mixing zone on a case-by-case basis when a permit is issued, renewed, or materially modified	Throughout the document, specifically 3.4.3–3.4.3.1.2
58.01.02.060.01.a	Indicates when a pollutant in a receiving water does not meet water quality criteria but may receive a mixing zone	3.4.3.7.1
58.01.02.060.01.b	Allows water quality exceedance of chronic water quality criteria within zone of initial dilution	Throughout the document, specifically 3.4.3–3.4.3.1.2
58.01.02.060.01.c	Indicates a mixing zone is evaluated on permitted design flow and must not be larger than necessary	3.4.3.4
58.01.02.060.01.d	Establishes mixing zones must not cause unreasonable interference with or danger to beneficial uses	3.4.3–3.4.3.1.2
58.01.02.060.01.e.i	Allows multiple nested mixing zones for a single point of discharge	3.4.3.4.3
58.01.02.060.01.f	Establishes multiple mixing zones for a single activity with multiple points of discharge	3.4.3.4.3
58.01.02.060.01.g	Indicates adjacent mixing zones from independent activities shall not overlap	3.4.3.4.3
58.01.02.060.01.h.i	Indicates that the width of a mixing zone in flowing waters should not exceed 25% of the stream width or 25% of low-flow design discharge conditions	3.4.3.4.1
58.01.02.060.01.h.ii	Indicates requirements for new discharges to nonflowing waters	3.4.3.4.2
58.01.02.060.01.h.iii	Indicates requirement for existing discharges to nonflowing waters	3.4.3.4.2
58.01.02.060.01.h.iv	Defines which lakes and reservoirs are considered nonflowing waters	3.4.3.4.2
58.01.02.060.01.i	Describes when a mixing zone may vary from subsection 060.01.h	3.4.3.6
58.01.02.060.01.j	Indicates outfall design criteria	0
58.01.02.060.02	Establishes points of compliance as alternatives to mixing zones	3.4.3.7.3
58.01.02.210.01	Includes criteria for toxic substances for aquatic life, recreation, and domestic water supply uses	3.4.3.1, 3.4.3.2, 3.4.3.3
58.01.02.210.03.a	Indicates that criteria apply at the appropriate locations specified within or at the mixing zone boundary	3.4.3
58.01.02.210.03.b	Defines the flow values (e.g., 7Q10 and harmonic mean flow) to be used in mixing zone analyses based on the designated use and type of criteria	3.4.3.4.1, Table 23
58.01.02.250	Includes aquatic life criteria for other pollutants, including ammonia, pH, temperature, dissolved oxygen, turbidity, and dissolved gas	3.4.3.1, 3.4.3.2
58.01.02.251.01	Defines the bacteria criteria that apply for protection of recreation uses	3.4.3.3.2
58.01.02.401.01 through 401.03	Includes criteria for temperature, turbidity, and chlorine that apply to wastewater discharges	3.4.3–3.4.3.1.2

As stated previously, TBELs are the minimum level of pollutant controls for point source discharges and are based on technology and cost considerations, effluent limitation guidelines, best professional judgment, or other federal regulations and must be achieved at the end-of-pipe. Therefore, mixing zones do not apply to TBELs.

In determining whether a mixing zone will be authorized, DEQ considers the following:

- Quality of the effluent
- The assimilative capacity of the receiving water
- Potential impacts of the mixing zone on the beneficial uses of the receiving water body

For DEQ to authorize a mixing zone, the receiving water must possess the capacity to assimilate the discharged pollutant. Assimilative capacity exists when the quality of the receiving water is better than criteria necessary to support beneficial uses. In this evaluation, DEQ also considers upstream permitted dischargers who may not be discharging at their permitted maximum loads. Except when TMDL WLAs or other water quality plans demonstrate there is assimilative capacity, mixing zones shall not be considered for any pollutant when the receiving water does not meet criteria for that pollutant.

Mixing zone evaluations should consider the potential impacts of the mixing zone on the beneficial uses of the receiving water, including an evaluation of effects on aquatic organisms and human health. Idaho's mixing zone rules stipulate that the location of a mixing zone should not cause unreasonable interference with, or danger to, beneficial uses (IDAPA 58.01.02.060.01.d).

Unreasonable interference with, or danger to, beneficial uses includes, but is not limited to, the following:

- Impairment to the integrity of the aquatic community;
- Thermal shock, lethality, or loss of cold water refugia due to heat in a discharge;
- Bioaccumulation of pollutants exceeding levels protective of human health or aquatic life;
- Lethality to aquatic life as a result of passage through the mixing zone;
- Exceedance of maximum contaminant levels at drinking water intakes; or
- Creating conditions that impede or prohibit recreation.

"Whether a mixing zone is authorized, and its size, configuration, and location, is determined by the Department on a case-by-case basis. This determination is made in accordance with the provisions of Section 060 at the time a permit is issued, renewed, or materially modified and is in effect as long as the permit remains in effect. Such an authorization is required before a mixing zone can be used to determine the need for, or level of, effluent limits for a particular pollutant." (IDAPA 58.01.02.060)

Table 21 includes a summary of the considerations to be addressed in mixing zone evaluations.

Table 21. Summary of key considerations for mixing zone evaluations.

Key Mixing Zone Considerations	Direction
Can water quality criteria be met at end-of-pipe?	If yes, then a mixing zone is not applicable; however, Idaho's Antidegradation Policy (IDAPA 58.01.02.051) must be considered. If not, a mixing zone analysis must be performed and a mixing zone may be authorized by DEQ.
What is the assimilative capacity of the receiving water body for the pollutants of concern in the proposed discharge?	A mixing zone is not allowed where assimilative capacity does not exist (with certain exceptions per IDAPA 58.01.02.060.01.a.). The mixing zone authorization must be consistent with Idaho's Antidegradation Policy.
What is the aquatic life beneficial use(s) of the water body?	Describe the aquatic life use(s) and list the appropriate aquatic life numeric criteria for all pollutants in the effluent for which a mixing zone is proposed. If an aquatic life use is not designated, DEQ generally protects the water body for cold water aquatic life.
Is salmonid spawning a beneficial use within the proposed mixing zone area?	If yes, evaluate the proposed mixing zone potential to adversely impact salmonid spawning. An appropriate mixing zone may need to be smaller. Another option to allow mixing is relocation of the outfall.
Does effluent contain substances known to be toxic to aquatic life?	If yes, describe all potential toxic substances, predicted concentrations within the mixing zone, and the sensitivity of the aquatic community to the toxins in the vicinity of the mixing zone (especially species and/or life stages of greatest conservation need).
Are acute water quality criteria predicted to be exceeded in the mixing zone?	If yes, describe the spatial extent of such exceedances and evaluate the potential for acutely toxic conditions.
Will the mixing zone contain any pollutants known to elicit an avoidance behavior?	If yes, list these pollutants and the species that will potentially be affected. Describe the spatial and temporal extent of the mixing zone and extent of the zone of passage. If no, provide a basis for this conclusion.
Will the mixing zone contain any pollutants known to attract aquatic life?	If yes, list these pollutants and the species that will potentially be affected. Describe the spatial and temporal extent of the mixing zone. If no, provide a basis for this conclusion.
Will the effluent include pollutants known or predicted to bioaccumulate or bioconcentrate? Are fish likely to be harvested from the water body in the vicinity of the mixing zone area?	If yes, list these pollutants and describe their predicted concentration in the mixing zone and the potential impact on the food web. In addition, discuss the assimilative capacity of the receiving system and all proposed monitoring efforts for assessing the impacts of such pollutants.
What is the contact recreation beneficial use of the water body?	Describe the public access to the mixing zone area and the seasonality of public use. Also list the human health-based numeric criteria for consumption of organisms for all pollutants in the effluent for which a mixing zone is proposed. Note: where contact recreation is not designated, DEQ presumes the water body will support either primary or secondary contact recreation.
Is the water body designated as a domestic water supply?	If yes, list the human health-based numeric criteria for consumption of water and organisms for all pollutants in the effluent for which a mixing zone is proposed.
What is the extent of the mixing zone?	Describe the proposed mixing zone's spatial and temporal characteristics.
For existing dischargers, is there an established or proposed monitoring plan that will adequately characterize the physical, chemical, and biological conditions of the water body upstream and downstream from the proposed mixing zone?	If yes, describe the monitoring plan in detail, including all spatial and temporal aspects of the monitoring and quality assurance/quality control (QA/QC) procedures. If no, sufficient information should be submitted that describes why monitoring is not needed.

Key Mixing Zone Considerations	Direction
For new dischargers, is there a proposed monitoring plan that will adequately characterize the pre-discharge physical, chemical, and biological condition of the water body and all post-discharge impacts from the proposed mixing zone?	

When establishing the appropriate size of a mixing zone, the permit writer performs an iterative series of RPAs, adjusting the mixing zone as necessary until RPTE is no longer demonstrated. IDAPA 58.01.02.118 requires that the mixing zone be no larger than necessary and will not exceed 25% of the low-flow volume of the receiving water for flowing water bodies. For non-flowing waters, the mixing zone will not exceed 10% of the total horizontal area of the water body for existing discharges and 5% of the area or 100 meters in length (whichever is smaller) for new discharges.

3.4.3.1 Water Quality Standards

3.4.3.1.1 Numeric Criteria

Numeric criteria are specific to beneficial uses of a receiving water body and are used to appropriately evaluate a mixing zone. The most stringent of all applicable use-specific criteria will drive the mixing zone analysis.

Acute criteria should be met at the boundary of an area within the mixing zone known as the zone of initial dilution (ZID); chronic and narrative criteria must be met at the boundary of the mixing zone (IDAPA 58.01.02.060.01.b) (Figure 4).

Zone of initial dilution (ZID) is “an area within a Department authorized mixing zone where acute criteria may be exceeded. This area shall be no larger than necessary and shall be sized to prevent lethality to swimming or drifting organisms by ensuring that organisms are not exposed to concentrations exceeding acute criteria for more than one (1) hour more than once in three (3) years. The actual size of the ZID will be determined by the Department for a discharge on a case-by-case basis, taking into consideration mixing zone modeling and associated size recommendations and any other pertinent chemical, physical, and biological data available” (IDAPA 58.01.02.010.117).

3.4.3.1.2 Narrative Criteria

Water quality must meet WQS, including the narrative criteria, at the edge of the mixing zone. However, when natural background conditions exceed any water quality criteria (other than temperature, IDAPA 58.01.02.401.01.c), no lowering of water quality from natural background conditions is allowed.

Mixing zones may be authorized for numeric interpretations of narrative criteria where assimilative capacity is available and no unreasonable interference with, or danger to, beneficial uses of the water body occurs.

3.4.3.2 Effects on Aquatic Life

Mixing zones have the potential to unreasonably interfere with aquatic life (e.g., fish, benthic macroinvertebrates, and diatoms) by impairing the integrity of the aquatic community, including spawning, egg incubation, rearing, or passage; adding heat that causes thermal shock, lethality,

or loss of cold water refugia; bioaccumulation of pollutants; and, lethality to aquatic life passing through the mixing zone (IDAPA 58.01.02.60.01.d). As a result, mixing zones are authorized based on a case-by-case analysis to ensure sufficient stream area and volume for protecting aquatic life beneficial uses.

Evaluation of an existing or proposed mixing zone must consider the following:

- Composition of the aquatic community, including any ecologically or economically important species
- Seasonal dynamics of the water body (both physical dynamics such as snowmelt runoff and ecological dynamics such as migrating fish)
- Physical impacts the discharge may cause
- Concentrations and nature of pollutants that may interfere with the beneficial aquatic life uses of that water body

In general, the risk of any mixing zone to aquatic life increases with the magnitude, duration, and frequency of pollutant exposure and the extent of the mixing zone. Therefore, it is critical to determine the concentration of a pollutant in the mixing zone and all expected physical and chemical habitat changes that would be associated with it. It is also important to evaluate how frequently and how long the aquatic community will be exposed to the discharge.

The biological community should be characterized before a mixing zone is authorized. Mixing zone requests for discharges to receiving waters that support sensitive species near the discharge will be reviewed with a higher degree of scrutiny. Similarly, the seasonal sensitivity of an aquatic community (e.g., during spawning runs or when vulnerable life stages are present) should also be evaluated regarding the potential impacts from the discharge on spawning.

Information regarding the aquatic communities expected to be present in Idaho waters is available in the Idaho Department of Fish and Game's (IDFG's) current *Fisheries Management Plan* and *Idaho Comprehensive Wildlife Conservation Strategy*. These plans, including lists of Idaho species of greatest conservation need (e.g., Bull Trout, Snake River physa) and critical habitat designations (see Section 3.4.3.2.6), should be consulted early in the mixing zone evaluation process.

Critical habitat is identified for salmon and steelhead in the Federal Register (2005, see reference list). Bull Trout recovery plans, critical habitat, and other information are available from the US Fish and Wildlife Service (USFWS). Coordination with USFWS (for threatened species such as Bull Trout) and the National Marine Fisheries Service (NMFS) (for anadromous fish such as Chinook Salmon) may be advisable when species of greatest conservation need may occur in the area of the proposed mixing zone. Additional information on the location of these species' critical habitat can be found on EPA, USFWS, and NMFS websites (e.g., <http://www.nmfs.noaa.gov/pr/species/criticalhabitat.htm>). DEQ will also coordinate with the Idaho Office of Species Conservation when appropriate and refer to Idaho's Bull Trout Conservation Plan (Batt 1996).

The beneficial use of a water body (e.g., cold water aquatic life) may be a significant factor in determining the type of biological community present (including any species of greatest conservation need) and whether a mixing zone is appropriate. While state water quality criteria for toxics do not vary for the aquatic life beneficial use, dissolved oxygen, temperature, and

ammonia numeric criteria do. Thus, beneficial uses of a water body play an important role when evaluating and establishing such criteria in a mixing zone.

While protecting beneficial uses is imperative, aquatic life protection includes paying attention to individual species that make up an aquatic community. The loss of individual species in certain circumstances may have a significant impact on the aquatic community as a whole. This may be the case with respect to particular species in the community that are of ecological or economic importance, as well as species more sensitive to added impact due to depressed populations.

3.4.3.2.1 Toxicity to Aquatic Organisms

Idaho water quality standards include narrative water quality criteria (IDAPA 58.01.02.60.01.d) and numeric water quality criteria (IDAPA 58.01.02.210) that address the effects of toxic pollutants on aquatic life. Further toxicity data can be found in EPA's ECOTOX databases. Using these resources and information provided by the discharger, DEQ must determine if acutely toxic conditions will not occur outside the ZID and if chronic water quality criteria will be met at the boundary of the proposed mixing zone (Figure 4).

Acutely toxic conditions are those conditions that cause lethality after short-term exposure (e.g., 1 hour or less). These conditions can be avoided by limiting the magnitude of pollutant concentrations as well as ensuring the frequency and duration of exposure to elevated concentrations is limited. Acute lethality is generally not expected when an organism, drifting through the mixing zone along the path of maximum exposure would, not be exposed to concentrations exceeding the acute criteria when averaged over a one-hour period. It can also be assumed that no lethality to passing organisms will occur in the following four scenarios (EPA 1991):

1. The acute criteria are met at end-of-pipe.
2. The discharge is of high velocity (≥ 3 meters/second) and the ZID is less than 50 times the discharge length scale in any direction.
3. The discharge is of low velocity (< 3 meters/second) and the most restrictive of the following conditions is met:
 - a. The acute criterion will be met within 10% of the distance from the edge of the outfall to the boundary of the mixing zone (when the acute-to-chronic ratio is equal to 10 or more) in any spatial direction.
 - b. The ZID will be less than 50 times the discharge length scale in any spatial direction (this requirement must be met for each port in a multiport diffuser).
 - c. The acute criterion will be met within a distance of 5 times the local water depth in any horizontal direction from the outfall.
4. A drifting organism, when traveling through the path of maximum exposure, would pass through the acute mixing zone within 15 minutes.

3.4.3.2.2 Whole Effluent Toxicity

Mixing zones can be authorized for both acute and chronic WET effluent limitations. When authorized, the acute and chronic WET limits should be based on the instream concentration of effluent at the boundary of the ZID (acute) or boundary of the mixing zone (chronic). It is

The **Discharge Length Scale** is the square root of the cross-sectional areas of the discharge pipe (or port) at its outlet.

preferable that acute WET limits (e.g., no significant difference between the control and 100% effluent using hypothesis testing) be met at the end of the discharge pipe; however, DEQ may allow numeric interpretations of narrative toxics criterion for WET to be met at the edge of the ZID, as long as lethality does not occur to organisms passing through the ZID.

3.4.3.2.3 Zone of Passage

The extent of the mixing zone may be restricted to ensure sufficient stream area and volume for a zone of passage for aquatic life. Many salmonids migrate downstream as juveniles then upstream to spawn as adults; therefore, adequate zones of passage are necessary to maintain the biological integrity of the water body. Any authorized mixing zone for waters with established aquatic life beneficial uses must provide an adequate zone of passage to satisfy the requirement that the mixing zone will not unreasonably interfere with, or endanger, established beneficial uses.

Of primary concern in evaluating the zone of passage are concentrations of various pollutants known to elicit an avoidance behavior and the location of the mixing zone relative to suitable stream velocities and depths for aquatic life passage. Since aquatic life have been shown to have their upstream passage blocked when encountering elevated concentrations of pollutants, any permitted mixing zone must provide a sufficient zone of passage such that the allowable mixing zone does not unreasonably interfere or endanger movement of aquatic life.

A comprehensive review of the scientific literature on fish avoidance was conducted by DEQ (2000). This review included fish avoidance thresholds for cadmium, copper, chromium, nickel, lead, mercury, and zinc (Table 22). Newer literature suggests that many of the threshold concentrations listed in Table 22 are still accurate, with a few exceptions. Copper toxicity and avoidance response may occur at lower concentrations than the listed 3 micrograms per liter ($\mu\text{g/L}$); avoidance has been observed at concentrations approaching 1 $\mu\text{g/L}$. Sublethal effects of copper can be less in waters with greater concentrations of dissolved organic carbon; pH may also influence copper toxicity. Literature published since 2000 includes observations of avoidance response of cadmium at levels lower than 8 $\mu\text{g/L}$; avoidance has been observed at concentrations as low as 0.5 $\mu\text{g/L}$. Alternative avoidance threshold values, supported by adequate and appropriate scientific literature or based upon site-specific information, may be presented by the permit applicant.

Table 22. Threshold concentrations observed to elicit avoidance responses in salmonids (DEQ 2000).

Selected Avoidance Thresholds	Cadmium	Copper	Chromium	Nickel	Lead	Mercury	Zinc
	(micrograms per liter)						
Lab	8	3	10	24	14	0.2	14
Field	16	3	20	48	28	0.4	28

Note: Except for copper, lab avoidance thresholds from the studies reviewed were calculated by multiplying the lowest lab-to-field response ratio by two in order to obtain field avoidance thresholds. Because of ambiguity with the threshold avoidance response of juvenile Chinook Salmon to copper, the recommended avoidance threshold is 3 $\mu\text{g/L}$, without multiplication by the lab-to-field response ratio.

From a physical perspective, the mixing zone size limitations as described in Section 3.4.3.4 have historically been presumed to provide an adequate zone of passage. However, to ensure that the mixing zone “shall not cause unreasonable interference with, or danger to, existing beneficial

uses” (IDAPA 58.01.02.060.01.d), site-specific considerations of both channel morphology and species of greatest conservation need should be considered, especially for discharges with small dilution factors. A dilution factor represents the ratio of the receiving water body low flow (i.e., the low-flow design discharge conditions) and the effluent discharge (Section 0). Channel morphology could be evaluated in conjunction with modeling efforts, as these efforts may involve detailed description of the receiving water.

Of particular concern are instances in which a mixing zone is proposed for stream channels that contain a limited percentage of stream width with characteristics (e.g., depth or flow volume) capable of supporting aquatic life passage. For example, it is not unusual for limited areas of some streams to contain areas with a well-defined thalweg adjacent to a comparatively large gravel bar over which only shallow, diffuse flow travels. In such situations, a mixing zone could occupy less than 25% of the stream width, or even less than 25% of the streamflow, but close to 100% of the useable area of the stream for fish passage. In such cases, a site-specific determination of the appropriate physical extent of a mixing zone must be made. As indicated, such considerations must take into account requirements of species of greatest conservation need (e.g., migrating Chinook Salmon or sessile aquatic invertebrates). In 2014, the National Marine Fisheries Service issued a toxics substances biological opinion that provides significant guidance regarding salmonids and zone of passage considerations (specifically, Appendix F: Salmonid Zone of Passage Considerations). This publication can be accessed through DEQ’s website on toxics substances criteria: <http://www.deq.idaho.gov/water-quality/surface-water/water-quality-criteria/toxic-substances-criteria/>.

3.4.3.2.4 Attraction

Discharges that attract free-swimming organisms have the potential to adversely affect aquatic life because free-swimming organisms may remain within the mixing zone area for longer periods of time extending the organisms’ exposure to pollutants. DEQ may consider restricting or denying mixing zones for discharges that attract free-swimming organisms. According to the *Water Quality Standards Handbook* (EPA 2014), most toxicants elicit a neutral or avoidance response; there are some situations in which aquatic life are attracted to a toxic discharge (ref., <http://www2.epa.gov/wqs-tech/water-quality-standards-handbook-chapters>). For example, the temperature of or organic matter (as a food source) in a toxic effluent may be an attractive force to aquatic organisms. Innate behavior such as migration may also counter an avoidance response; in this instance, passage of aquatic life should be evaluated. Review of scientific literature (e.g., EPA’s 1991 TSD) or other peer-reviewed documentation may be necessary where attraction is a concern.

3.4.3.2.5 Spawning

Of particular concern in Idaho is protecting the spawning activities of salmonids (trout and salmon). *Oncorhynchus* spp. spawn by depositing eggs and sperm in a depression (known as a redd) cut into the stream bottom of shallow, silt-free riffle/run habitats from large rivers to headwater streams. In general, salmon and trout typically choose to spawn in streams that are shallow, clear, and cold with a strong upwelling of water through the gravel. Discharges containing elevated suspended solids, for example, may clog these critical gravel beds. Sockeye Salmon spawning occurs almost exclusively in lakes or streams that connect to lakes. The female Sockeye most often selects a redd site in an area of the stream with fine gravels. Detailed descriptions of Chinook Salmon, steelhead, and Bull Trout spawning preferences and habitat

needs by life stage are described within documents and links available from the Salmon Recovery Federal Caucus (http://www.westcoast.fisheries.noaa.gov/protected_species/salmon_steelhead/salmon_and_steelhead.html). Information on Sockeye Salmon habitat requirements can be obtained from the IDFG (<http://fishandgame.idaho.gov/public/fish/?getPage=36>). Any discharge that significantly alters habitat, lowers dissolved oxygen, or increases the temperature of a water body has the potential to impact spawning activities.

To adequately protect vulnerable fish communities, mixing zones may be prohibited during certain times of the year or within areas of the receiving water body that provide spawning and rearing habitat. The spawning periods for salmonids occur in seasonal blocks. During late winter and spring, Cutthroat Trout, Rainbow Trout, and steelhead move into spawning habitats. Anadromous and landlocked salmon (Coho, Chinook, Sockeye, and Kokanee) spawn during late summer and fall. Brown Trout, Brook Trout, and Bull Trout will typically spawn in the fall and early winter. For a mixing zone to be allowed in any spawning area, the applicant must demonstrate that the discharge will not unreasonably interfere with the capability of the receiving water body to support ongoing and future spawning, incubation, and rearing activities. Whether or not the mixing zone is to be authorized during fish spawning seasons should be carefully evaluated. Specifically, discharges with a thermal mixing zone should not cause unreasonable interference, or danger to, the impairment of the integrity of the aquatic community (e.g., impairing cold water refugia by overlapping the confluence of a smaller stream).

When a discharge is located near spawning areas, the applicant for a mixing zone should provide documentation that the pollutants discharged do not have the potential to unreasonably interfere with present or future salmonid spawning, incubation, or rearing activities in the water body. Further discussions with NMFS, USFWS, and IDFG may be necessary to determine potential impacts on spawning areas of sensitive species.

3.4.3.2.6 Species of Greatest Conservation Need

Of particular concern in evaluating potential and existing mixing zones are a small group of aquatic species designated by the state as “species of greatest conservation need” because of their limited range in Idaho, low or declining populations, or threats to their existence. These species for Idaho’s fisheries are of particular ecological, social, and economic importance and include Cutthroat Trout, Bull Trout, Steelhead, Chinook Salmon, Kokanee, and White Sturgeon (all native fish). Other aquatic organisms of greatest conservation need include several species of snails found in tributaries and the main stem of the Snake River: Snake River physa, Banbury Springs lanx, Bruneau hot spring snail, and the Bliss Rapids snail.

A mixing zone will not be granted if the mixing zone impairs the integrity of the aquatic community. When there are species of greatest conservation need, the impact of a mixing zone to the integrity of the aquatic community may be significant due to, for example, the depressed population of a species. Mixing zone evaluations, therefore, should include an analysis of the potential for impacts to habitat used for spawning by endangered or threatened species or species of greatest conservation need. To be adequately protective of vulnerable aquatic communities, mixing zones for Idaho’s streams and rivers may not be allowed within **all** areas during any time of the year that the area provides **critical necessary** habitat for any life stage of Sockeye Salmon, Chinook Salmon, Steelhead, Kootenai River population of White Sturgeon, or Bull Trout.

Furthermore, mixing zones may be very limited or prohibited within the habitat of Idaho's special status snails.

3.4.3.2.7 Bioaccumulation

Bioaccumulation is the elevation in concentration of substances in an organism relative to the concentration in the environment (e.g., food, water, sediment). The process involves uptake of the substance and an inability to break it down or excrete it, which leads to the organism having a higher internal concentration of the substance than its surrounding environment. Though similar to bioaccumulation, bioconcentration involves uptake from water only. In general, substances that are more lipid soluble and less water soluble are more likely to bioaccumulate. A general discussion of these properties is available through the US Geological Survey (USGS) Toxic Substances Hydrology Program website: <http://toxics.usgs.gov>. More information on and examples of bioaccumulative pollutants can be found at TRI Program website: <https://www.epa.gov/toxics-release-inventory-tri-program/persistent-bioaccumulative-toxic-pbt-chemicals-covered-tri>

The Idaho WQS specifically state that mixing zones shall not cause unreasonable interference, or danger to, beneficial uses.

The bioaccumulation of pollutants (as defined in IPDAPA 58.01.02.010) resulting in tissue levels in aquatic organisms that exceed levels protective of human health or aquatic life would constitute such interference or danger. Thus, DEQ will closely evaluate mixing zones for pollutants with a high potential to bioaccumulate to ensure such mixing zones will not lead to harmful tissue concentrations in fish, benthic macroinvertebrates, or other organisms.

Examples of pollutants with a moderate to high potential to bioaccumulate that are

currently present in some discharges throughout Idaho include selenium, arsenic, PCBs, and methylmercury. Of the 121 toxic substances included in Idaho WQS (96 of which have criteria), 36 are currently defined as bioaccumulative. Substances are considered bioaccumulative if they have a bioaccumulation factor (BAF) or bioconcentration factor (BCF) exceeding 1000 liters per kilogram (L/kg)ⁱ. This value is a threshold for high risk of harm through bioaccumulation.

Bioaccumulation intensity varies with site-specific conditions; therefore, a discharger requesting a mixing zone for bioaccumulative pollutants may be required to provide information (e.g., expected fate and transport of the substance) regarding the potential for such substances to bioaccumulate or bioconcentrate in organisms residing in the receiving water body. In addition, the discharger may be required to conduct upstream and downstream monitoring of the tissue,

For more information on bioaccumulation:

List of Bioaccumulative Pollutants (DEQ)

www.deq.idaho.gov/media/60160659/bioaccumulative-pollutants.pdf

US EPA Water Data and Tools

www.epa.gov/waterscience/gli/mixingzones

US EPA Bioaccumulative Toxic (BPT) Chemicals Covered by the TRI Program

<https://www.epa.gov/toxics-release-inventory-tri-program/persistent-bioaccumulative-toxic-pbt-chemicals-covered-tri>

ⁱ The 1000 L/kg threshold is used by EPA in determining if a chemical is bioaccumulative under the Emergency Planning and Community Right-to-Know Act (EPCRA) of 1986. The value 1000 L/kg is based on a combination of science and policy and does not imply that chemicals with lower BAF values do not bioaccumulate or are incapable of causing harm to beneficial uses.

sediment, and/or water column concentrations for the bioaccumulative substance before (where possible) and after establishment of the discharge. This monitoring will provide insight into the potential impacts of the discharge on species present in the receiving water body and may be included as a requirement in an IPDES permit.

Within Idaho's mixing zone rule, mixing zones are prohibited from causing bioaccumulation of pollutants that results "in tissue levels in aquatic organisms that exceed levels protective of human health or aquatic life" (IDAPA 58.01.02.060.01.d.iii).

3.4.3.3 Effects on Human Health

In determining whether to allow a mixing zone or the best manner in which to monitor a mixing zone, the impacts of that mixing zone on human health must be considered. Specifically, mixing zones are not to cause unreasonable interference with beneficial uses including: bioaccumulation of pollutants (IDAPA 58.01.02.010) resulting in tissue levels in aquatic organisms that exceed levels protective of human health or aquatic life; concentrations of pollutants that exceed Maximum Contaminant Levels (MCL) at drinking water intake structures; and conditions which impede or prohibit recreation in or on the water body (IDAPA 58.01.02.60.01.d). Potential impacts can be evaluated through water quality criteria associated with ingestion of water (domestic water supply uses) and consumption of fish (recreational uses). In determining whether human health-based criteria should be considered, the beneficial uses of the water body in question must be known. IDAPA 58.01.02 Sections 100 through 160 identify the designated beneficial uses of Idaho's water bodies.

The following three subsections address water quality criteria developed to protect domestic water supply, contact recreation, and fish consumption.

3.4.3.3.1 Domestic Water Supply

Those water bodies designated for domestic water supply (in IDAPA 58.01.02.100.03.a) should have water quality appropriate for use as drinking water. Thus, any mixing zone must not interfere with this beneficial use.

Water quality criteria designed to protect human health can be more restrictive (i.e., allowable concentrations are lower) than corresponding water quality criteria designed to protect aquatic life. An example of this is arsenic, for which the current human health-based criterion is 10 µg/L to protect for both consumption of water and organisms and consumption of organisms only, while aquatic life-based criteria are 150 µg/L (chronic concentration) and 340 µg/L (acute concentration). Another example is the organochlorine pesticide Aldrin, for which the human health-based criterion is 0.0000025 µg/L, while the aquatic life-based criterion maximum concentration (CMC) is 3 µg/L. More information regarding applicable human health-based (and aquatic life-based) water quality criteria is given in IDAPA 58.01.02.210.

When evaluating any proposed mixing zone, its proximity to existing and/or proposed domestic water intakes will be considered. DEQ will not authorize a mixing zone that will cause concentrations above a drinking water maximum contaminant level at a surface water supply intake. Dilution models should be used to determine the potential proximity of the intake and mixing zone under various flow conditions (such as low [e.g., 7Q10] and high [e.g., maximum monthly average] flow). The discharger should work with DEQ in determining the most appropriate flow regimes to use in the mixing zone model. Using these data, best professional

judgment should be used in determining whether the mixing zone has the potential to interfere with the domestic water supply beneficial use.

3.4.3.3.2 Primary and Secondary Contact Recreation

Most waters in the state are presumed to support primary or secondary contact recreation uses. Thus, any mixing zone must generally protect these uses. Idaho's WQS prohibit authorizing a mixing zone for *E. coli* and any condition that impedes or prohibits recreation in and on the water body (IDAPA 58.01.02.60.01.d.vi).

When considering whether to authorize a mixing zone in an area designated or presumed for contact recreation uses, specific information is needed regarding the ability of the public to access the area affected and seasonality of use (e.g., swimming during late summer or whitewater rafting or kayaking during spring high flows). Additional information may be requested from the discharger regarding these uses when evaluating potential impacts of mixing zones.

3.4.3.3.3 Consumption of Aquatic Organisms

Although consumption of aquatic organisms (e.g., fish, mussels, crawdads) is not a distinct beneficial use in Idaho, it is considered to be part of recreation use through the activity of fishing in Idaho waters. Consumption of fish and other aquatic organisms is an important exposure pathway that is incorporated into the human health criteria applied to waters protected for either domestic water supply or recreational uses. Application of these criteria is based on the opportunity for exposure, not the actual occurrence of exposure. Evaluating existing or proposed mixing zones to determine whether there is unreasonable interference with the recreational beneficial use should consider the following:

1. Whether the discharge contains bioaccumulative pollutants;
2. Whether the harvest and consumption of aquatic organisms will be impeded by the mixing zone; and
3. The frequency with which organisms are harvested in the vicinity of the mixing zone.

Thus, the evaluation will consider the potential for harvest and consumption of exposed aquatic organisms within the mixing zone and downstream. The discharger may be required to submit information regarding the frequency of such activities or access points for such activities in the vicinity of the mixing zone. Using this and other information, DEQ staff will use best professional judgment in determining the appropriateness of a mixing zone for the pollutants of concern.

3.4.3.4 General Size and Location Requirements to Consider

Mixing zones must be sized and located so as to maintain protection of beneficial uses in the water body as a whole. Idaho's mixing zone policy lists specific requirements for the size and location of a mixing zone. However, DEQ has the discretion to depart from these requirements in certain circumstances. The following subsections discuss each of the size and location requirements for flowing and non-flowing waters.

3.4.3.4.1 Flowing Waters

Flow Requirement

As described in IDAPA 58.01.02.060.01.h, the size of a mixing zone should not exceed 25% of streamflow volume of the low-flow design discharge conditions (Table 23). DEQ permit writers use 25% of low-flow design discharge conditions to establish a dilution factor when conducting an RPA, and evaluate whether a mixing zone will be authorized consistent with WQS by adjusting the percentage of low flow down from 25% until RPTE is demonstrated. The percentage is then raised to the next whole number at which RPTE is not demonstrated to occur.

This size determination is accomplished through RPA and WQBEL back-calculations. Historical effluent data demonstrating a smaller mixing zone is achievable should be considered when lowering the mixing percentage. For example, if a discharge has no RPTE with a criterion using 10% mixing, DEQ may authorize a mixing zone using 10% of the receiving water low-flow condition for that parameter. Section 3.4.3 provides further guidance on establishing an appropriate mixing zone percentage.

DEQ may authorize a mixing zone that includes more than 25% of the receiving water low-flow condition, provided the discharger demonstrates this larger mixing zone is needed and submits sufficient information illustrating the increased mixing zone size will not unreasonably interfere with, or cause danger to, the beneficial uses of the receiving water body (see Section 3.4.3.6). Table 23 lists the receiving water low-flow criteria that apply to mixing zones, as described in IDAPA 58.01.02.210.03.

Table 23. Low-flow design discharge conditions to use in mixing zone evaluations.

Criteria	Low Flow Design Condition	Explanation
Aquatic Life—Toxics		
Acute toxic criteria (CMC) ^a	1Q10 or 1B3	1Q10: lowest 1-day flow with an average recurrence frequency of 10 years 1B3: biologically based low flow which indicates an allowable exceedance of once every 3 years
Chronic toxic criteria (CCC) ^b	7Q10 or 4B3	7Q10: lowest 7-day average flow with an average recurrence frequency of 10 years 4B3: biologically based low flow which indicates an allowable exceedance for 4 consecutive days once every 3 years
Aquatic Life—Nonconventionals^c		
Temperature ^d	7Q10 or 4B3	7Q10: lowest 7-day average flow with an average recurrence frequency of 10 years 4B3: biologically based low flow which indicates an allowable exceedance for 4 consecutive days once every 3 years
Ammonia – Acute Criterion (CMC) ^a	1Q10 or 1B3	1Q10: lowest 1-day flow with an average recurrence frequency of 10 years 1B3: biologically based low flow which indicates an allowable exceedance of once every 3 years
Ammonia – Chronic Criterion (CCC) ^b	7Q10 or 4B3	7Q10: lowest 7-day average flow with an average recurrence frequency of 10 years 4B3: biologically based low flow which indicates an allowable exceedance for 4 consecutive days once every 3 years
Phosphorus^e		
Human Health—carcinogen	Harmonic mean flow	Harmonic mean flow: long-term mean flow value calculated by dividing the number of daily flows by the sum of the reciprocals of those daily flows
Human Health—noncarcinogen^f	Harmonic mean flow Or 30Q5	Harmonic mean flow: long-term mean flow value calculated by dividing the number of daily flows by the sum of the reciprocals of those daily flows (if the effects from certain noncarcinogens are manifested after a lifetime of exposure, then a harmonic mean flow may be appropriate) Lowest 30 consecutive day low flow with an average recurrence frequency of once in 5 years.

a. These low flows are specified in IDAPA 58.01.02.210.03.b. However as of October 2016, this element of Idaho's water quality standards has not been approved by EPA for Clean Water Act purposes.

a. CMC: criterion maximum concentration

b. CCC: criterion continuous concentration

c. These low flows are not specified in Idaho WQS, and DEQ may use alternative flows as appropriate.

d. Low flows for the salmonid spawning beneficial use should be determined for the time period during which spawning and egg incubation occurs.

e. DEQ will evaluate low flows for nutrients on a case-by-case basis. In total maximum daily loads, DEQ has used various estimates of low flows, including a seasonal average flow representative of the growing season (i.e., May to September) or an annual average flow.

f. The 30Q5 low flow is specified in IDAPA 58.01.02.210.03.b. However as of October 2016, this element of Idaho's water quality standards was removed and replaced with the harmonic mean flow, this change has not been approved by EPA for Clean Water Act purposes.

Low stream flows are determined based on hydrologic records, often USGS flow records at a nearby gaging station. Other methods to estimate low flow at ungauged locations may be used, such as USGS StreamStats <http://water.usgs.gov/osw/streamstats/>.

In some instances a discharger may request DEQ consider alternative streamflow estimates in calculating the reasonable potential to exceed and any associated mixing zone authorization. DEQ would consider these requests in cases where it is clear that differing sets of circumstances exist which should be considered when developing effluent limits (e.g., different effluent flows, receiving water flows, hydrologic or climatic conditions). These requests must contain information sufficient to show that use of these alternatives do not impact beneficial uses of the water body. Sufficient information would likely include an extensive flow record and monitoring data of both the receiving water body and the effluent.

One possible approach to using alternative streamflow estimates includes calculating effluent limits and mixing zone size based on seasonal flows. This approach provides for tiered effluent limits based on an empirical data record for the receiving water body and effluent discharge. The use of seasonal limits in calculating has been sanctioned and employed in EPA permits over the years (EPA, 1996). However, this tiered approach would require dynamic modeling of the receiving water body and the effluent discharge to ensure that duration and frequency components of an associated criterion continue to be met. It would also require an extensive data record to model seasonal flows in the receiving water body.

Idaho WQSs allow for the flexibility of incorporating seasonal or tiered effluent limits in discharge permits. Authorization of multiple mixing zones associated with these seasonal or tiered effluent limits requires the same calculations using the appropriate seasonal flows. For example, dilution ratios for tiers may be calculated and analyzed to determine critical periods in a case where high seasonal flows associated with run-off cause significant variability both in the receiving water body and the effluent flow. Critical dilution ratios may be calculated as the highest ratio expected to occur in a 4 day period once every 4 years corresponding to the biologically based water quality critical flows. These critical dilution ratios would then be incorporated into the effluent limit calculation to ensure compliance with duration and frequency components of the water quality criteria.

Width Requirement

A mixing zone should be sized such that the concentration of the pollutant(s) being discharged should not exceed the applicable chronic criteria at greater than 25% of the stream width (IDAPA 58.01.02.060.01.h.i). A higher level of analysis should be used where this is a concern (see Section 3.4.3.9). The relevant width of the stream is the wetted width of the water flowing in the channel. Wetted width is a dynamic parameter that varies with flow. Additionally, at any given streamflow, channel widths and wetted widths naturally change based on upstream or downstream location. As channel gradients become steeper, flow often becomes more constricted and velocities increase. Likewise, channels tend to spread out and widen with decreasing gradients and lower flow velocities.

It is important, therefore, to define the flow regime (i.e., the water level) and the channel cross-section downstream where pollutant concentrations meet the chronic criteria. At any given streamflow, channel widths and wetted widths naturally vary upstream and downstream of an outfall. Open channel hydraulics models such as the Hydrologic Engineering Centers River

Analysis System (HEC-RAS) may be used to define the wetted width and shoreline of the 7Q10 low flow. Mixing zone models, such as CORMIX, can be used to compare different levels of flow, the width and length of the effluent plume, and the appropriate cross-section where the low-flow wetted width would be established as a compliance point. Where aquatic life toxics criteria are considered, DEQ generally uses the 7Q10 to define the low-flow wetted-width and the location of the compliance cross-section. This value ensures the mixing of effluent plumes meets chronic criteria prior to becoming wider than 25% of the stream width at all flow conditions.

However, there may be instances where streamflow and velocity increases cause the effluent plume to travel greater distances before sufficient mixing occurs to meet criteria. Additionally, wider plumes may be observed at higher flows. Where the required mixing zone to meet chronic criteria approaches 25% of the stream width, additional studies and modeling may be necessary to predict the length, width, and amount of mixing at higher flow conditions.

Shore-Hugging Plumes

While DEQ understands EPA's position (1994) that shore-hugging plumes be avoided, Idaho WQS do not specifically prohibit shore-hugging plumes in flowing waters. However, in some cases, DEQ may significantly limit or even prohibit mixing zones to prevent adverse impacts to the environment and human health consistent with IDAPA 58.01.01.060.01.b. and 060.01.d. Additionally, IDAPA 58.01.02.060.01.j.ii instructs outfall design to consider avoiding shore-hugging plumes where the littoral zone is a major supply of food and cover for migrating or rearing fish and other aquatic life or where recreational activities are impacted by the plume's contact with the shore.

Outfalls constructed on the bank generally result in shore-hugging plumes; most dischargers in Idaho have outfall structures located on the bank, perpendicular to streamflow. DEQ encourages, but does not require, diffusers for discharges to flowing waters. While DEQ recognizes there may be instances where installing a diffuser results in more harm than good, or does not result in any added environmental benefits, diffusers generally result in more rapid mixing, decreasing the area containing elevated concentrations and thus minimizing effects on beneficial uses. Mixing zone models such as CORMIX may be used to determine the likelihood of a mixing zone hugging a shoreline. For example, where beneficial uses like a domestic water supply intake structure or primary contact recreational area has the potential to encounter a proposed mixing zone.

3.4.3.4.2 Non-flowing Waters

Water bodies with a mean detention time of 15 days or greater are considered non-flowing. Detention time is calculated by dividing the mean annual storage volume by the mean annual flow rate out of the impoundment for the same time period. Non-flowing waters like lakes and reservoirs offer less mixing potential than streams or rivers and are at greater risk for some pollutants to interfere with the beneficial uses of a water body, including bioaccumulative pollutants and nutrients. As such, DEQ will review mixing zones within non-flowing waters with respect to effluent attributes (e.g., flow volume, velocity, buoyancy, etc.), mixing conditions, and bioaccumulative pollutants.

Horizontal Area Requirement

For existing discharges to non-flowing waters authorized prior to July 1, 2015, the size of the mixing zone is not to exceed 10% of the non-flowing water body's surface area (IDAPA 58.01.02.060.01.h.iii). For all new discharges to non-flowing waters authorized after July 1, 2015, the size of the mixing zone is not to exceed 5% of the total surface area of the water body or 100 meters from the point of discharge, whichever is smaller (IDAPA 58.01.02.060.01.h.ii).

The discharger should provide an estimate of a non-flowing water body's minimum surface area during low-pool conditions (maximum drawdown). The horizontal (surface) area of the water body may be estimated by interpolating low-pool elevations with USGS topographic maps and/or other maps that delineate the water body's boundaries.

Additional Requirements for New Dischargers to Non-flowing Waters

New dischargers to non-flowing waters are required to use diffusers and design the outfall such that the plume is not shore-hugging (IDAPA 58.01.02.060.01.h.ii.2).

3.4.3.4.3 Multiple Mixing Zones

IDAPA 58.01.02.060.01.e states multiple nested mixing zones may be established for a single discharge (a single outfall), each being specific for one or more pollutants contained within the discharge. For example, DEQ may authorize a mixing zone for zinc that uses 25% of the low-flow design discharge conditions and for the same outfall authorize a mixing zone for copper that uses 15% of the low-flow design discharge conditions.

When multiple points of discharge for a single activity (discharge facility) are evaluated, DEQ will consider the treatment processes, concentrations of the pollutants of concern, and the locations of the outfalls. Where these individual mixing zones overlap or merge, the sum of the (multiple) mixing zones from those discharge points must not exceed the area and volume that would be allowed for a single point of discharge (IDAPA 58.01.02.060.01.f).

When these individual mixing zones do not overlap or merge, DEQ may authorize individual mixing zones. The cumulative impact of these discharges should not cause unreasonable interference with the beneficial uses of the receiving water body. Additionally, adjacent mixing zones from independent activities are not permitted to overlap (IDAPA 58.01.02.060.01.g).

The mixing zone area and volume are generally determined through modeling, as discussed in Section 3.4.3.11.

3.4.3.5 Requirements for Submerged Discharges

Idaho WQS do not require a submerged discharge point for new or existing discharges into flowing waters. However, a submerged discharge is preferable because it enhances hydrodynamic mixing. For new discharges into non-flowing waters, diffusers are required (IDAPA 58.01.02.060.01.h.ii.3). A description of the discharge location and depth should be provided by the applicant when mixing zones are being considered.

3.4.3.6 Varied Mixing Zone Sizes

IDAPA 58.01.02.060.01.i allows mixing zones to vary from the limits of subsection 060.01.h. A smaller mixing zone may be needed to avoid an unreasonable interference with, or danger to, a beneficial use. Conversely, a larger mixing zone that does not interfere with beneficial uses and meets the other requirements of section 060 may be authorized when the discharger provides an analysis that demonstrates a need given siting, technological, and managerial options.

Siting options include the location point of discharge, which receiving water body as well as where in the receiving waterbody. While this is typically an option for new discharges, it may be a consideration during facility upgrades. For example, a discharger may choose the use of diffusers or a longer pipe to discharge to a larger receiving water body rather than discharge to the water body adjacent to the treatment facility.

Technological considerations include treatment types and process alternatives that would improve effluent quality. For example, a treatment option may be to switch from chlorination to UV disinfection; a process alternative may be the use of a less toxic chemical.

Managerial options typically involve water management such that a lesser volume of effluent is discharged, levels of treatment, or improving process efficiency so that less waste is generated per unit of production.

3.4.3.7 Other Considerations

3.4.3.7.1 Assimilative Capacity

Mixing zones will not be authorized for pollutants for which a water body is considered impaired unless there are available wasteload allocations (e.g., specifically allocated for a discharger or included in a reserve for growth) in an approved total maximum daily load (TMDL) or other applicable plans or analyses (such as 4b implementation plans, watershed loading analyses, or facility-specific water quality pollutant management plans) that demonstrate that there is available assimilative capacity. The most current EPA-approved Integrated Report should be used to determine the beneficial use support status of the receiving water body (see www.deq.idaho.gov/integrated-report).

In assessing assimilative capacity, it is also prudent to consider upstream permitted discharges, which may not yet be discharging at their permitted maximum loads. If this is the case, basing assimilative capacity on what is presently or recently observed is likely to result in overshooting assimilative capacity when all discharges in a watershed reach their permit limits. This broader look at assimilative capacity is known as a watershed-based approach to permitting and its application can avoid future impairment, the need to develop a TMDL, and future cut backs in permitted effluent limits.

One example of a watershed-based approach to permitting was a metals analysis included in an NPDES Fact Sheet for several wastewater discharges to the Spokane River. EPA performed a separate analysis to determine if the combined discharges of zinc from the City of Coeur d'Alene, the City of Post Falls, and the Hayden Area Regional Sewer Board have the reasonable potential to cause or contribute to excursions above Washington's water quality criteria for zinc at the State line.

Zinc excursions would still exist at the State line even if the Idaho dischargers ceased discharging entirely, or discharged no zinc. However, the water quality criteria for zinc become less stringent with increasing hardness. Because the effluents from the three point sources to the Spokane River in Idaho are harder than the receiving water, the Idaho dischargers create loading capacity for zinc (by raising the hardness and in turn the water quality criteria) at the State line. Using available information and conservative assumptions, EPA determined that, by discharging relatively hard water, the three Idaho point sources reduce the magnitude of excursions above zinc water quality standards at the State line. In other words, the Idaho point sources' discharges of relatively hard water to the Spokane River create more zinc loading capacity than they use by discharging zinc. Therefore, the Idaho dischargers do not have the reasonable potential to cause or contribute to excursions above Washington's water quality standards for zinc at the State line, and it is therefore not necessary to impose zinc effluent limits on the Idaho point sources that are more stringent than those necessary to meet Idaho water quality standards at the end-of-pipe (Nickel, 2007a).

3.4.3.7.2 Temperature

When evaluating thermal plumes, DEQ will consider whether the heat in the discharge will cause unreasonable interference with, or danger to, beneficial uses as well as, the limitations expressed in *EPA Region 10 Guidance for Pacific Northwest State and Tribal Temperature Water Quality Standards* (EPA 2003). Thermal plumes should not cause: impairment to the integrity of the aquatic community, including interfering with successful spawning, egg incubation, rearing, or passage of aquatic life; and, thermal shock, lethality, or loss of cold water refugia (IDAPA 58.01.02.060.01.d). To minimize or avoid these types of unreasonable interference, the following will be considered when conducting a mixing zone analysis (EPA 2003):

- Within 2 seconds of plume travel from the point of discharge, maximum temperatures should not exceed 32°C.
- The cross-sectional area of the receiving water body exceeding 25°C should be limited to less than 5%.
- The cross-sectional area of the receiving water body exceeding 21°C should be limited to less than 25%, or if upstream temperatures exceed 21°C, then at least 75% of the receiving water body should not have temperature increases of more than 0.3°C.
- In spawning and egg incubation areas, the maximum weekly maximum stream temperatures should not exceed 13°C, or the temperatures should not be increased by more than 0.3°C above ambient stream temperatures during times when spawning and incubation occur.

3.4.3.7.3 Points of Compliance as Alternatives to Mixing Zones

DEQ may establish points for monitoring compliance with ambient water quality criteria when the nature of the discharges precludes a mixing zone analysis, such as with storm water discharges which are intermittent and diffuse. For these types of discharges, a point of compliance may be established at a reasonable distance from the discharge.

For flowing waters, a down current point of compliance should be less than or approximately equivalent to the width of the receiving water body. For non-flowing waters, a point of compliance should ensure no unreasonable interference, or danger to, the beneficial uses of the

receiving water body; it should be established at a site-specific radial distance from the activity and based on the magnitude, frequency, and duration of the discharge.

3.4.3.7.4 Effluent-Dominated Waters

In some cases, the volume of discharge may provide a benefit (e.g., flow augmentation) to the beneficial uses of the receiving water body, and this benefit would be lost if the discharge were to cease. In these instances, DEQ may authorize mixing zones that use more than 25% of the stream volume at low flow as long as the mixing zone does not unreasonably interfere with the beneficial uses of the receiving water body.

3.4.3.8 Mixing Zone Approval Assessment Process

The following process will be followed when determining whether to authorize a regulatory mixing zone for pollutants in IPDES permits:

1. DEQ performs an RPA using 25% of the low-flow receiving water volume for dilution (i.e., a 25% mixing zone). The low-flow statistic used can vary, but is usually a 1Q10 for the CMC and a 7Q10 for the CCC. DEQ develops effluent limits for pollutants that exceed water quality criteria.

When establishing assessing the appropriate mixing zone size of a mixing zone in non-flowing waters the volume of a the receiving water body must be determined-based on the allowed surface area a percentage of the water body's surface area at the point of discharge must be determined and the depth at the point of discharge. This will require that the receiving water body's bottom slope bathymetry be assessed in order to calculate the volume of water available for dilution.

2. DEQ adjusts the size of the regulatory mixing zone so that it is no larger than necessary considering siting, technological, and managerial options available to the discharger. The mixing zone size may be reduced if a smaller mixing zone is shown to not yield an RPTE.
3. Additionally, DEQ performs a mixing zone analysis to determine the size of the plume and its effects on the receiving water body.
4. Once acceptable regulatory mixing zones are defined, DEQ drafts the permit using these mixing zone sizes for dilution.

The permit writer will document, in the fact sheet, the end of pipe pollutant concentration and low flow criteria used in the mixing zone analysis, affiliated with the mixing zone sizing, so that the concentration, mixing zone size, and receiving water low flow attributes are all documented in the permit. This concentration will be called a notification level and will require the permittee to notify DEQ when concentrations exceeding this level are discharged to the receiving water. A notification level is not an enforceable limit.

When the discharger needs a mixing zone that is larger than 25% or the maximum area allowed for a non-flowing receiving water, the process will evaluate the siting, technological, and managerial options provided by the discharger. The assessment will weigh the impact of increasing the volume of water used to dilute pollutants versus the ability to reduce the quantity of pollutants discharged.

Conversely, if the percentage of upstream critical flow is small in order to meet WQS, then DEQ and the discharger should investigate the feasibility of treatment upgrades at the facility to achieve better effluent quality. Adding a negotiated compliance schedule item addressing facility upgrades and documenting an appropriate timeline may be necessary.

3.4.3.9 Mixing Zone Analysis Level of Effort

DEQ recognizes that not all discharges merit the same level of concern. Some discharges will demand an extensive mixing zone analysis to evaluate the potential for chemical, physical, and biological impacts. Furthermore, not all discharges require complex modeling to determine the size, configuration, and location of the mixing zone. Rather, the intent of Idaho's mixing zone policy can be met through various levels of effort depending on the nature of the discharge and the characteristics of the receiving water. These conditions are described in further detail in Section 3.4.3.9.1. DEQ has identified three levels of analysis involved in mixing zone analysis:

- Level 1—Simple
- Level 2—Moderate
- Level 3—Complex

Figure 6 depicts the process for determining the appropriate level of analysis. The data requirements for each level of analysis are presented in Table 24. DEQ retains discretion in departing from these guidelines.




Figure 6. Decision flow chart for determining level of analysis.

3.4.3.9.1 Determining Level of Analysis

The level of analysis is determined by looking at the potential for unreasonable interference with, or danger to, beneficial uses, the dilution factor, and the type of discharge facility.

Unreasonable Interference with, or Danger to, Beneficial Uses

There may be situations where a discharge has the potential for unreasonable interference with, or danger to, the beneficial uses of a water body. Such situations may include, but are not limited to, the following:

1. Areas used for spawning when those areas are considered to be necessary for the overall success of the population in that water body

2. Pollutants significant to human health with the potential to impinge on a drinking water intake
3. Areas heavily used for contact recreation purposes (e.g., public swimming beaches) where discharges occur during the recreation season
4. Areas supporting species of greatest conservation need
5. Priority persistent bioaccumulative pollutants (see Section 3.4.3.2.7 and www.deq.idaho.gov/media/60160659/bioaccumulative-pollutants.pdf)
6. When dilution is severely limited (e.g., a dilution ratio <1)

Situations with a potential for unreasonable interference or danger to beneficial uses necessitate a level 3 mixing zone analysis.

Dilution Factor

A dilution factor represents the ratio of the receiving water body low flow percentage (i.e., the low-flow design discharge conditions) to the effluent discharge volume (Equation 18).

$$\text{Dilution Factor} = \frac{(Q_s \times P + Q_e)}{Q_e}$$

Equation 18. Dilution factor calculation.

Where:

- Q_s = receiving water low-flow design conditions (in cubic feet per second)
- P = mixing zone percentage (25% may be used initially to determine the level of analysis required)
- Q_e = discharge flow (in cubic feet per second)

If the dilution factor is equal to or greater than 20, a level 2 or 3 mixing zone analysis may not be required (depending on other site-specific factors), and the appropriate percentage of the low flow may be automatically used in the permitting process.

The dilution factor calculated using 25% of the low-flow design will only be used to determine the appropriate level of effort that should be conducted. If a level 1 analysis is sufficient, then the appropriate proportion of streamflow according to the “Flow Requirement” discussion in Section 3.4.3.4.1 must be used in the evaluation of RPTE and subsequent calculation of WQBELs. However, if a level 2 or 3 analysis is appropriate, then the dilution factor that is modeled at the edge of the mixing zone must be used in the RPA and, when appropriate, in calculating WQBELs.

Type of Facility

DEQ classifies facilities as major or minor. Facility design flow is the primary consideration in this classification scheme for POTWs. If the design flow is greater than or equal to 1 mgd, or poses a potential or actual threat to human health or the environment, the POTW is a major facility. Industrial facilities are classified as major or minor based on a scoring system that considers a variety of factors including standard industrial classification code, type of effluent pollutants (e.g., toxics), and available dilution. DEQ uses the IPDES Permit Rating Worksheet for industrial users.

3.4.3.9.2 Level 1—Simple

The simple (or mass balance equation) approach represents the simplest form of calculating an appropriate dilution factor for the RPA and WQBEL calculations. This level of analysis is appropriate when the following conditions are met:

- There is no known potential for unreasonable interference with, or danger to, beneficial uses or lowering of water quality.
- The discharger is considered minor.
- The dilution factor is greater than or equal to 20.

Limited data are needed for this analysis, and no modeling is required. In most situations, pre-discharge biological data will not be required, and although ambient water quality data are desirable, DEQ recognizes that they may not be available and may require ambient monitoring during the permit cycle.

For minor dischargers with a dilution factor greater than 20, the mixing zone percentage may be adjusted to no larger than necessary by back calculating downwards from the value of 25.

3.4.3.9.3 Level 2—Moderate

The moderate mixing zone analysis may be used when there is a low level of risk to the public and aquatic environment. This level of analysis is appropriate when there is no known potential for unreasonable interference with beneficial uses and one of the following conditions are met:

- The dilution factor is greater than or equal to 20, and the discharger is considered major.
- The dilution factor is less than 20, and the discharger is considered minor.

Although level 2 analysis is more extensive than the level 1 analysis, this level has relatively minimal data needs. Modeling is necessary to understand the location and configuration of the mixing zone, but some of the modeling inputs can be estimated rather than measured (Table 24). Similar to level 1, biological data and ambient water quality data may not be required.

3.4.3.9.4 Level 3—Complex

This level of analysis is appropriate when there is a moderate or high level of risk to the public and aquatic environment. This level of analysis is appropriate when one of the following conditions is met:

- There is potential for unreasonable interference with beneficial uses (e.g., a water body that is effluent dominated); or
- There is no known potential for unreasonable interference with beneficial uses, the dilution ratio is less than 20, and the discharger is considered major.

This level of analysis requires more of the model inputs to be measured rather than estimated (Table 24). Some flexibility does exist, depending on the situation and reliability of estimates. Some estimates may be based on a facility type (e.g., modeling for a new POTW with a pretreatment program), while other inputs may be specific to a facility and require measurement. For example, a receiving water body may become highly channelized during critical low flows, requiring the modeler to obtain numerous downstream bathymetric cross-sections. Pre-discharge (or upstream/downstream) biological and chemical data for the receiving stream will be required prior to authorizing a mixing zone for new discharges.

3.4.3.10 Mixing Zone Review and Approval

When mixing zones are proposed, DEQ staff will verify mixing zone percentages used in the dilution factor and/or modeling. After the mixing zone has been verified or calculated, staff will apply the appropriate dilution factor(s) to the RPA and, if necessary, calculate WQBELs.

The fact sheet will include DEQ's mixing zone decision. At a minimum, the fact sheet should include the dilution factor used; the size, configuration, and location of the mixing zone; and, where appropriate, calculations showing an analysis regarding the size considerations in IDAPA 58.01.02.060.01.h when a level 2 or 3 analysis is conducted. A three-dimensional representation overlaying the mixing zone with the receiving water may also be provided. Multiple mixing zones and ZIDs should be displayed, where appropriate.

The public will have an opportunity to comment on the authorized mixing zone during the public comment period(s) for the draft IPDES permit and its associated fact sheet. DEQ will address comments related to the authorized mixing zone(s) prior to issuing the final permit.

3.4.3.11 Mixing Zone Determinations

Mixing zone determinations, especially those requiring more complex levels of analysis, can be aided by the use of models and/or dye studies. Available models and associated inputs are discussed below.

3.4.3.12 Background on Mixing Zone Modeling

The hydrodynamics of mixing when two streams of water come together can be complex. How well waters mix largely depends on the forces governing water movement. An effluent discharged from a pipe or side channel will have jet forces associated with it created by the volume of water, the size of the pipe or channel opening, the angle or direction of flow, and the water's buoyancy (relative density). The receiving water also has its own forces: velocity and volume, gradient, and channel dimensions and characteristics.

Hydrodynamic models have been developed in an effort to characterize these forces and predict how the two water bodies will mix, the rate at which they will mix, and the size of the resulting plume in the receiving water (length, width, depth). Models help determine how fast pollutants dilute to specific levels and when and where certain concentrations exist. We can divide models into two basic categories: those that predict the results of immediate mixing (near-field mixing) where jet forces are at work and far-field mixing where more passive diffusion or ambient mixing occurs. Pollutants added to a receiving water through discharge may already exist as background concentrations in that receiving water. Once the discharge is completely mixed, there will be a new equilibrium or new concentration for the pollutants moving downstream.

The distinction between near-field and far-field is made purely on hydrodynamic grounds and is unrelated to any regulatory mixing zone definitions that address prescribed water quality criteria. In many practical cases, the regulatory mixing zone may include only near-field hydrodynamic mixing processes. However, in some instances, the mixing zone may extend into the far-field. For example, a small source in a strong cross flow may rapidly enter the far-field region well before the edge of a regulatory mixing zone. Thus, in principle, the entire gamut of mixing processes—ranging from the near-field to the far-field—should be considered for individual mixing zone analyses.

3.4.3.12.1 Near-Field Mixing

The first stage of mixing is achieved from the discharge's momentum and buoyancy. This stage is particularly important in lakes, impoundments, and slow-moving water bodies since mixing in those systems relies upon the effluent's momentum, buoyancy, and eventually simple diffusion. In the absence of receiving water turbulence, horizontal or nearly horizontal discharges will create a clearly defined jet in the water column. When the discharge flow encounters a boundary such as the surface, the bottom, or an internal ambient density stratification layer, the near-field region ends and the transition to the far-field begins. In simple terms, the near-field region is typically the region that is controlled by the characteristics of the discharge itself (discharge flow rate, momentum, etc.).

3.4.3.12.2 Far-Field Mixing

Beyond the near-field, mixing is controlled by passive diffusion and ambient turbulence (i.e., spatial variations in the water body's velocity field). If little discharge-induced mixing is associated with the jet action of the discharge, then continued mixing must be accomplished by ambient forces, which can result in much larger mixing zones. This situation is typical in non-flowing waters (lakes and reservoirs). Once the discharge interacts with a boundary such as the banks, the surface, or the bottom of the stream, the mixing processes are primarily a function of turbulence. The discharge in the far-field (see Figure 7) loses its "memory" of its initial conditions, and mixing is mainly a function of the ambient conditions (ambient velocity and density field, channel roughness and meanders, etc.).




Figure 7. Far-field plume, passive ambient diffusion processes (Jirka et al. 1996).

3.4.3.13 Available Models

A wide variety of mixing zone models exists for evaluating the mixing behavior and plume dynamics of a point source discharge. No single model is appropriate for every discharge situation. Each model has its own set of strengths and weaknesses. It may be appropriate to use more than one model to evaluate mixing and dilution if more than one is available to the

modeler. DEQ prefers EPA-supported models such as CORMIX; however, DEQ may consider other models (e.g., Visual Plumes) if they are more suitable for the site-specific conditions. If the applicant wants to use a model not discussed in this manual, it is highly recommended that the applicant discuss this with DEQ prior to modeling the discharge.

3.4.3.13.1 Near-Field Dilution Models

Buoyant jet models, such as those in CORMIX, predict dilution by stringing together a series of semi-empirical entrainment formulations. The region of applicability of the entrainment formulations is determined by various length scales including the buoyancy and momentum length scales. The entrainment formulations are referred to as semi-empirical since their general functional dependencies are derived theoretically but various coefficients must be determined from observations. A length scale is a scaling estimate based on dimensional analysis arguments that identify the region of influence of a particular physical process. Each length scale is a distance along the trajectory where one parameter predominates (i.e., controls the flow). Once strung together by this analysis, the length scales should describe the relative importance of all parameters—discharge volume flux, momentum flux, buoyancy flux, ambient cross flow, and density stratification—throughout the trajectory. For example, the solution for a pure jet can be applied as an approximate solution to that portion of a buoyant jet in a cross flow where jet momentum dominates the flow. Likewise, the results for a pure plume can be applied to the buoyancy-dominated regions for the buoyant jet. The length scales are linked by appropriate transition conditions to create a path for the trajectory through the completion of initial dilution.

CORMIX is a commercially available mixing zone model and decision support system for environmental impact assessment of regulatory mixing zones resulting from continuous point source discharges. CORMIX emphasizes the role of boundary interaction to predict steady-state mixing behavior and plume geometry. The CORMIX methodology contains systems to model single-port and multipoint diffuser discharges, as well as surface discharges of conventional or toxic pollutants. Effluents considered may be conservative, nonconservative, heated, or contain suspended sediments.

CORMIX is available for free testing and evaluation from Mixzon, Inc., at <http://www.mixzon.com/>.

CORMIX uses a data-driven approach to simulation model selection. It is comprised of about 50 flow modules, each with their own formulae or algorithms, and more than 100 possible distinct flow classifications. Based on the input data the user enters to describe the discharge and ambient environment, the system selects the proper choice of model to represent the physical mixing processes likely to occur within the mixing zone. The model selection procedure is both automated and fully documented by a rule-based system that screens the input data for internal consistency and compliance with model formulation assumptions. The system contains logic to reject cases where no reliable model exists for the given discharge situation and will warn the user in cases where the simulation occurs but results may be unreliable. The internal model selection procedure is fully documented by extensive, published, peer-reviewed scientific research. Statistical tools are readily available to evaluate model performance with available laboratory and field data on mixing predictions.

Visual Plumes (VP) (Baumgartner et al. 1994; Frick et al. 2003) is another initial dilution model available for analyzing mixing zones. It is freely available from the EPA Center for Exposure Assessment Modeling at www2.epa.gov/exposure-assessment-models/visual-plumes. VP can list

salinity, temperature, and current variations at different depths. VP simulates single and merging submerged plumes in arbitrarily stratified ambient flow and buoyant surface discharges. VP addresses the issue of model consistency in a unique way, by including other models in its suite of models. In this way, it promotes the idea that in the future, modeling consistency will be achieved by recommending particular models in selected flow categories. VP includes the following models:

- Davis, Kannberg, and Hirst model for Windows (DKHW) that is based on the universal Davis, Kannberg, and Hirst density model (UDKHDEN) (Muellenhoff et al. 1985)
- Prych, Davis, and Shirazi surface discharge model (PDS) (Davis 1999)
- Three-dimensional updated merge model (UM3) based on the updated merge model (UM)
- Near-field model (NRFIELD) based on the Roberts, Snyder, and Baumgartner length scale model (RSB)

3.4.3.13.2 Far-Field Modeling Frameworks

The far-field models are designed to track the contaminant concentration along the plume of the discharge in areas of the receiving water where mixing is dominated by ambient fluid turbulence. Where far-field mixing is a concern, cumulative discharge centerline (defining cumulative changes in water quality) may need to be established. The CORMIX model is recommended as a primary modeling framework for near-field analysis and far-field simulation since it has the capability of performing both near- and far-field mixing zone calculations (ref., http://www.mixzon.com/docs/UserManuals/FFL_UM/FFL_UserManual/).

3.4.3.14 Data and Information to Support Mixing Zone Analysis

The reliability of the predictions from any of the modeling techniques depends on the accuracy of the data used in the analysis. The minimum data required for model input include receiving water characteristics (flow, channel morphology, and background concentrations); effluent characteristics (flow and concentrations); and outfall design information. Table 24 lists the type of information needed for each level of analysis.

The discharger or DEQ may gather the necessary data, conduct the modeling, and prepare a summary of the modeling results. Where the discharger conducts the modeling, the discharger should include a map of the facility and its discharge point. At a minimum, the map should include other discharges within 0.5 mile, public access points, known spawning locations, drinking water intakes within 0.5 mile, and diversions. DEQ encourages gathering information from outside the 0.5 mile region if the modeled mixing zone extends further than 0.5 mile or contains a bioaccumulative pollutant. DEQ will review the information provided by the discharger and determine whether the resulting mixing zone complies with Idaho WQS. The discharger is encouraged to consult with DEQ early in the process to ensure that DEQ concurs with the modeling approach.

Table 24. Mixing zone level of analysis data inputs.

Data Description	Analysis Level ^a		
	1	2	3
Outfall Information			
Outfall location (Estimate from 1:24K topographic map or measure with a GPS receiver. When measured then provide the datum.)	E	M	M
Map	P	P	P
Photographs of the outfall and the vicinity of the outfall	O	O	P
Distance from nearest bank to discharge (m)	O	E	M
Height of outfall above stream bottom (m)	O	E	M
Diameter of port (m)	O	M	M
Discharge horizontal angle (σ)	O	M	M
Diffuser:			
Length of diffuser (m)		M	M
Distance from nearest bank to first port (m)		M	M
Distance from nearest bank to last port (m)		M	M
Total number of ports		M	M
Distance between ports (m)		M	M
Port vertical angle (θ)		M	M
Angle between diffuser line and ambient current (γ)		M	M
Angle between port centerline projection and diffuser axis (β)		M	M
Effluent Information			
Flow rate (MGD) and/or velocity (m/s)	E	E	M
Pollutant concentrations	P	P	P
Receiving Water Body Information			
Low flow (cfs) or velocity (f/s)	E	E	M
Channel depth (m)		E	M
Channel width (m)		E	M
Channel slope (degrees)		E	M
Manning's roughness coefficient		E	E
Ambient concentrations for pollutants in mixing zone		M	M
Model Information			
Model used		P	P
Basis for model selection		P	P
Mixing zone configuration/location		P	P
Model results table		P	P

a. P = provide; E = estimate; M = measure (field or engineering plans); O = optional

3.4.3.14.1 Analytical Methodologies

Where possible, analytical methods listed in 40 CFR Part 136 should be used to measure pollutants in the effluent and receiving water body. Further, the detection limits and reporting limits should be sufficiently low to ensure that concentrations of concern can actually be reliably measured. Of particular concern are chemicals with very low water quality criteria values such as cadmium. EPA's Office of Science and Technology is a good source for information regarding analytical methods and their detection limits.

3.4.3.14.2 Receiving Water Morphology/Hydrology

Receiving water data would ideally include the following:

- Bathymetry in the vicinity of the discharge site
- Seasonal water temperature ranges or vertical temperature profile information for deeper lakes and reservoirs
- Ambient low flows
- Current information from direct measurements or inferred from water body ambient discharge and cross-sectional area

In practice, existing ambient water data may be very limited. In some cases, estimated values for the data may be acceptable (e.g., measures of discharge and channel geometry could be used to estimate currents). If data are limited, DEQ may require field sampling to gather the necessary data for either conducting or verifying the mixing zone modeling analysis. The following paragraphs briefly describe sampling work that may be required to gather stream geometry and hydraulic data.

Channel Geometry

Channel geometry data are used to define the stream configurations, regardless of the particular model being used. The basic types of channel geometry data include the following:

1. Variation of channel width and cross-sectional area with depth
2. Bottom slope (or bed elevations)
3. Variation of wetted perimeter or hydraulic radius with depth
4. Bottom roughness coefficient (Manning's n)

Variation of water depth with flow will be discussed in the next subsection. The four parameters listed above may be assumed constant for the section of the river being modeled (i.e., the river is modeled as a rectangular box). However, these parameter values should be defined when low-flow conditions drastically change the receiving water body's channel geometry and its ability to assimilate the effluent. Length and average slope over long distances can be determined from topographic maps, while the other variables usually require field surveys. The level of detail required in describing the stream geometry depends on the amount of variability in the system and whether the mixing zone is expected to extend into the (hydrodynamic) far-field.

For streams with uniform slopes and cross-sections over the study area, only a few transects will be necessary. In areas where the channel geometry varies widely, the stream should be divided into a series of representative reaches, and sufficient transects should be measured along each reach to adequately characterize the geometry. Three to five cross-sections could be measured

along each reach, and the results could be averaged to define the reach characteristics for the channel. At a minimum, one representative cross-section should be measured in each reach. Some pool and riffle streams may require dye studies and measuring as many cross-sections as possible to obtain adequate stream geometry. Where modeling (e.g., CORMIX) demonstrates the mixing zone will extend into the far-field, a cumulative discharge centerline may need to be established.

Channel Hydrology

Hydraulic data are needed to define the velocities, flows, and water depths for mass transport calculations. As indicated in Section 3.4.3.4.1, mixing zone evaluations must consider low flows of the receiving water body. To determine low-flow values where an extended record of flow data at or near the discharge point is available, the EPA Office of Research and Development's DFLOW program, which can be downloaded free of charge, may be used. Alternatively, the USGS SWSTAT or Idaho StreamStats may be used. Other statistical methods can be proposed by dischargers in consultation with DEQ.

Both DFLOW and SWSTAT rely on the availability of long-term flow data. These models require at least 3 years, and preferably 10 years, of flow data to provide reliable statistical results. Such data may be independently collected by the discharger or another party within the watershed. Alternatively (as well as to verify discharger data), long-term flow data may be available if a nearby USGS stream gage is available.

For more information on flows (accessed February 4, 2014):

- DFLOW
<https://www.epa.gov/waterdata/dflow>
- SWSTAT Instructions
<http://water.usgs.gov/software/swstat.html>
- USGS Gage Information
<http://waterdata.usgs.gov/nwis/sw>
- StreamStats (USGS)
<http://water.usgs.gov/osw/streamstats>

3.4.3.14.3 Receiving Water Quality

Background water quality information is desirable to thoroughly evaluate mixing zones. Depending on the quantity of available background data, DEQ will generally use a conservative estimate (e.g., maximum or 95th percentile) of background pollutant concentrations when assessing mixing zones.

Some criteria are dependent on other water quality parameters (chemical or physical). For example, the ammonia criteria are dependent on temperature and pH. Criteria for seven metals (cadmium, chromium III, copper, lead, nickel, silver, and zinc) depend on water hardness. The hardness, pH, and temperature of water bodies will vary seasonally, and it is necessary to use conservative values for these parameters to ensure criteria are only rarely exceeded, after allowing for mixing. It may also be that critical temperatures, pH, or hardness do not correspond in time with critical low flows. This situation may call for a more sophisticated evaluation than simply using independently derived conservative values for each parameter. For example, the preferred approach may involve creating a time series of criteria values overlaying a time series of receiving stream flows to evaluate when assimilative capacity is at its minimum.

As discussed in Section 3.4.3.4.1, low-flow design discharge conditions for toxics criteria are specified in the WQS (IDAPA 58.01.02.210.03.b) and are based on the frequency component of the toxics criteria. Idaho WQS do not specify conservative estimates that should be used for hardness, pH, and temperature when evaluating the potential impact of a discharge on the receiving water body.

When evaluating mixing zones for criteria depending on hardness, pH, or temperature, DEQ believes that a conservative estimate of background concentrations of these three parameters should be used to calculate an applicable edge of mixing zone pollutant concentration in the following manner.

For effluent with greater or lower hardness, pH, or temperature than the receiving water body, use an estimate of the fully mixed conditions to calculate the applicable edge of mixing zone concentration. It has been general practice to use the 95th percentile of ambient pH and temperature data and the 5th percentile of ambient hardness data as conservative estimates of background concentrations to be used in the mixing zone evaluation. This approach is appropriate for pH and temperature; however, it may not always be appropriate for hardness. The following section discusses methods that can be used to select a conservative value of background hardness.

For purposes of calculating criteria that are applicable at the edge of the mixing zone, the minimum hardness concentration for metals other than cadmium that may be used is 25 mg/L; the maximum is 400 mg/L. For cadmium, the minimum hardness concentration that may be used is 10 mg/L (IDAPA 58.01.02.210.03.c.i).

3.4.3.14.4 Background Hardness

If data are available, DEQ's strongly suggests dischargers permit writers will examine the relation between flow and hardness if hardness influenced pollutants are present or may be present in the effluent.

- If the evaluation indicates that flow has a marked impact on hardness dependent pollutants in the effluent, then the permit writer may include flow based or seasonal limits for impacted pollutants.
- If hardness influenced pollutants are present in the effluent but hardness data is not available, then the permit should contain flow and stream quality monitoring requirements to collect data to assess the relationship between flow and hardness for the receiving water.
- If the data justify reopening the permit after the data has been evaluated, then the permit may be modified as allowed in IDAPA 58.01.25.201.02.c.ii.
- If hardness data does not exist and an hardness dependent metal criteria must be included in the permit prior to obtaining data identifying hardness response to stream flow rates, then the permit writer may select a hardness value, anticipated to occur in the receiving water, that will be used to establish the metal criterion until the permittee can supply the receiving water specific data. Upon receipt of the hardness data, the permit may be modified as allowed in IDAPA 58.01.25.201.02.c.ii.

DEQ plotted flow versus hardness data from 21 USGS gage sites and found most sites have an inverse relation between hardness and flow. Six examples are given in Figure 8. The relationship

between hardness and flow can be nonexistent (Figure 8-a) to intermediate (Figure 8-d) to strong (Figure 8-c) and very strong (Figure 8-b).




Figure 8. Example plots of water hardness versus flow.

An inverse relation between hardness and flow is problematic as it confounds conservative assumptions—low hardness and low flows do not co-occur. Taking a 5th percentile hardness value irrespective of flow and applying it at low flows could be overly conservative in many cases (e.g., Figure 8-b). If there is little relation between flow and hardness (Figure 8-a), then a 5th percentile of all hardness data will be representative of all flows, including low flows. But if an inverse relation exists, even if weak (Figure 8-d), then using all hardness data will not be representative of low-flow hardness.

Idaho WQS state the following:

The hardness values used for calculating aquatic life criteria for metals at design discharge conditions shall be representative of the ambient hardness for receiving water that occur at the [low-flow] design discharge conditions given in Subsection 210.03.b. (IDAPA 58.01.02.210.03.c.ii.)

Thus, the hardness data must be representative of low flows. However, DEQ recognizes that availability of hardness data during low flows (or during a restricted range of flows that are representative of low flows) is typically limited. For example, using or obtaining hardness data only at 7Q10 flow is impracticable as this flow is a rare occurrence and is usually not known until after the fact. A wider window of flows is likely to provide more data, and more data will give better statistical estimates of hardness values such as the 5th percentile. Therefore, when there is a relation between hardness and flow, which will most often be the case, DEQ suggests that the maximum window of flows acceptable for getting hardness data representative of low design flow is the 3 months that typically have the lowest flows in a year. Narrower windows are better, especially if the relation between hardness and flow is steep (e.g., Figure 8-b). Data from a broader window of flows are acceptable but will likely result in an overly conservative estimate of low-flow hardness.

In many situations, the hardness versus flow relation may be unknown. DEQ suggests that 30 samples are adequate to plot a relation between hardness and flow and recommends a minimum of 12 samples during the low-flow period as a basis for estimating the 5th percentile or other low exceedance probability hardness value. The narrower the window of flows sampled and the higher the number of samples, the more likely the estimate of the 5th percentile hardness at design flow will be accurate and not overly protective.

If sufficient data are available, an alternative would be to use the statistical relation (nonlinear regression) between hardness and flow to estimate the hardness at the design flow. In this case, DEQ recommends at least 30 paired samples of flow and hardness over a range of flows, and the lower 95th prediction limit on the regression estimate be used. Another option to approach the hardness versus flow relation and refine effluent limits accordingly is to employ flow-tiered effluent limits (see Section 3.4.3.4.1).

3.4.3.14.5 Effluent Characteristics

Both effluent quantity and quality information are needed to evaluate mixing zones. For POTWs, the facility design flow is used in the mixing zone analysis. For other types of dischargers (e.g., industrial), the maximum recorded flow during the previous 5-year permit term is typically used; facilities anticipating expansion may choose to use projected design flows. An exception would be where facility changes have occurred such that the maximum flow is highly unlikely to be reached in the future (e.g., permanent shutdown of a portion of an industrial facility). In such cases, the maximum flow observed (or anticipated) under the current or planned future operating conditions would be used.

When characterizing the quality of the effluent, DEQ follows the methodology described in the TSD (EPA 1991) to project the maximum possible effluent concentration from the maximum observed effluent concentration. For a new discharge, the pollutant concentration data may be obtained from the IPDES permit application. For a reissued permit, the maximum observed concentration is the highest level observed during the previous 5-year permit term. The discharger or DEQ should run the mixing zone model using the maximum projected effluent

concentration. In addition, the discharger should run a series of mixing zone analyses using a variety of potential effluent limitations to assess the potential mixing zone sizes under different effluent conditions. The discharger should work with DEQ in obtaining a series of possible effluent limitations under different dilution scenarios.

3.4.3.14.6 Outfall and Diffuser Information

Required information for single-port discharges and multipoint discharges (diffusers) includes the following:

1. Height of outfall or port above stream bottom
2. Port diameters(s)
3. Type of port mouth such as bell-mouthed or sharp-edged
4. Horizontal and vertical orientation of the port centerline for single-port discharge
5. Horizontal and vertical orientations and spacing of ports for multipoint diffusers
6. Distance from shoreline to port or first and last port of a multipoint diffuser
7. For side channel discharges, the channel's width, depth, bottom slope, and orientations
8. Photographs of the outfall structure or design plans for new discharges
9. Photographs of the receiving stream

3.4.3.15 Dye Studies

Field dilution measurement using dye or other tracers can be useful in mixing zone analysis. Measuring tracer concentration in the mixing zone and the effluent discharge allows the direct determination of dilution under the specific conditions of the measurements. If the measurements are taken under critical conditions corresponding to a specified low ambient flow and maximum permitted effluent discharge, and the dye or tracer has reached steady state concentration, the field results could be used as an alternative to modeling. In the event that conditions during the field study do not correspond to critical conditions, the results of the tracer or dye measurements can provide important data to validate a model. The use of preliminary modeling to design a dye or tracer study is highly recommended to ensure the use of adequate dye or tracer mass for detectable concentrations and the selection of spatial sampling locations. Chapter 4 of the EPA TSD (EPA 1991) provides a detailed discussion of dye studies.

3.4.4 Conduct a Reasonable Potential Analysis (RPA)

When determining the need for a WQBEL, a permit writer uses any available effluent and receiving water data as well as other information pertaining to the discharge and receiving water (e.g., type of industry, existing TBELs, compliance history, stream surveys), as the basis for a decision. The permit writer:

- Might already have data available from previous monitoring
- May work with the permittee to collect data before permit issuance
- May include data collection and reporting as a condition of the new permit

Whenever possible, DEQ will encourage new dischargers to collect monitoring data before effluent limit development. Monitoring should begin far enough in advance of permit development to allow sufficient time to conduct chemical analyses. Where monitoring is required as a condition of the permit for future RPA or mixing zone analyses, permittees must

adhere to monitoring and reporting conditions in the permit. DEQ will use collected data in a RPA and mixing zone analysis as appropriate. The permit may then be modified if a mixing zone is appropriate or a WQBEL is required.


To calculate the receiving water concentration downstream of the effluent discharge (Equation 19):

$$C_d = \frac{(C_e Q_e) + [C_u(Q_u \times \%MZ)]}{Q_e + (Q_u \times \%MZ)}$$

Equation 19. Simple mass-balance equation.

Where:

C_d = downstream receiving water concentration downstream	Calculated value
Q_e = critical effluent flow	From discharge flow data (design flow for POTW)
Q_u = critical stream flow for upstream flow (1Q10 acute criterion or 7Q10 chronic)	From water quality standards
%MZ = percent of critical low flow provided by mixing zone	From mixing zone analysis
Q_d = sum of critical stream flow and critical effluent flow	Calculated value
C_u = critical upstream pollutant concentration	From receiving water data
C_e = critical effluent pollutant concentration	Calculated value using Equation 20



The permit writer will analyze the previous effluent samples to determine the critical value for C_e . First, the permit writer will locate the sample with the maximum effluent concentration and use the processes provided in the TSD to convert this value to a critical effluent flow that accounts for day-to-day variability in effluent quality. This requires the use of a reasonable potential multiplying factor (RPMF), found in the current TSD on page 54 (EPA 1991) (Table 25, the 95th percentile RPMF, and Table 26, the 99th percentile RPMF, are provided here for the permit writer's convenience).

Table 25. Reasonable potential multiplying factors: 95% confidence level and 95% probability basis.

Number of Samples	Coefficient of Variation																			
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0
1	1.4	1.9	2.6	3.6	4.7	6.2	8.0	10.1	12.6	15.5	18.7	22.3	26.4	30.8	35.6	40.7	46.2	52.1	58.4	64.9
2	1.3	1.6	2.0	2.5	3.1	3.8	4.6	5.4	6.4	7.4	8.5	9.7	10.9	12.2	13.6	15.0	16.4	17.9	19.5	21.1
3	1.2	1.5	1.8	2.1	2.5	3.0	3.5	4.0	4.6	5.2	5.8	6.5	7.2	7.9	8.6	9.3	10.0	10.8	11.5	12.3
4	1.2	1.4	1.7	1.9	2.2	2.6	2.9	3.3	3.7	4.2	4.6	5.0	5.5	6.0	6.4	6.9	7.4	7.8	8.3	8.8
5	1.2	1.4	1.6	1.8	2.1	2.3	2.6	2.9	3.2	3.6	3.9	4.2	4.5	4.9	5.2	5.6	5.9	6.2	6.6	6.9
6	1.1	1.3	1.5	1.7	1.9	2.1	2.4	2.6	2.9	3.1	3.4	3.7	3.9	4.2	4.5	4.7	5.0	5.2	5.5	5.7
7	1.1	1.3	1.4	1.6	1.8	2.0	2.2	2.4	2.6	2.8	3.1	3.3	3.5	3.7	3.9	4.1	4.3	4.5	4.7	4.9
8	1.1	1.3	1.4	1.6	1.7	1.9	2.1	2.3	2.4	2.6	2.8	3.0	3.2	3.3	3.5	3.7	3.9	4.0	4.2	4.3
9	1.1	1.2	1.4	1.5	1.7	1.8	2.0	2.1	2.3	2.4	2.6	2.8	2.9	3.1	3.2	3.4	3.5	3.6	3.8	3.9
10	1.1	1.2	1.3	1.5	1.6	1.7	1.9	2.0	2.2	2.3	2.4	2.6	2.7	2.8	3.0	3.1	3.2	3.3	3.4	3.6
11	1.1	1.2	1.3	1.4	1.6	1.7	1.8	1.9	2.1	2.2	2.3	2.4	2.5	2.7	2.8	2.9	3.0	3.1	3.2	3.3
12	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.6	2.7	2.8	2.9	3.0	3.0
13	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.4	2.5	2.5	2.6	2.7	2.8	2.9
14	1.1	1.2	1.3	1.4	1.4	1.5	1.6	1.7	1.8	1.9	2.0	2.1	2.2	2.3	2.3	2.4	2.5	2.6	2.6	2.7
15	1.1	1.2	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.8	1.9	2.0	2.1	2.2	2.2	2.3	2.4	2.4	2.5	2.5
16	1.1	1.1	1.2	1.3	1.4	1.5	1.6	1.6	1.7	1.8	1.9	1.9	2.0	2.1	2.1	2.2	2.3	2.3	2.4	2.4
17	1.1	1.1	1.2	1.3	1.4	1.4	1.5	1.6	1.7	1.7	1.8	1.9	1.9	2.0	2.0	2.1	2.2	2.2	2.3	2.3
18	1.1	1.1	1.2	1.3	1.3	1.4	1.5	1.6	1.6	1.7	1.7	1.8	1.9	1.9	2.0	2.0	2.1	2.1	2.2	2.2
19	1.1	1.1	1.2	1.3	1.3	1.4	1.5	1.5	1.6	1.6	1.7	1.8	1.8	1.9	1.9	2.0	2.0	2.0	2.1	2.1
20	1.1	1.1	1.2	1.2	1.3	1.4	1.4	1.5	1.5	1.6	1.7	1.7	1.8	1.8	1.8	1.9	1.9	2.0	2.0	2.0

Table 26. Reasonable potential multiplying factors: 99% confidence level and 99% probability basis.

Number of Samples	Coefficient of Variation																			
	0.1	0.2	0.3	0.4	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3	1.4	1.5	1.6	1.7	1.8	1.9	2.0
1	1.6	2.5	3.9	6.0	9.0	13.2	18.9	26.5	36.2	48.3	63.3	81.4	102.8	128.0	157.1	190.3	227.8	269.9	316.7	368.3
2	1.4	2.0	2.9	4.0	5.5	7.4	9.8	12.7	16.1	20.2	24.9	30.3	36.3	43.0	50.4	58.4	67.2	76.6	86.7	97.5
3	1.4	1.9	2.5	3.3	4.4	5.6	7.2	8.9	11.0	13.4	16.0	19.0	22.2	25.7	29.4	33.5	37.7	42.3	47.0	52.0
4	1.3	1.7	2.3	2.9	3.8	4.7	5.9	7.2	8.7	10.3	12.2	14.2	16.3	18.6	21.0	23.6	26.3	29.1	32.1	35.1
5	1.3	1.7	2.1	2.7	3.4	4.2	5.1	6.2	7.3	8.6	10.0	11.5	13.1	14.8	16.6	18.4	20.4	22.4	24.5	26.6
6	1.3	1.6	2.0	2.5	3.1	3.8	4.6	5.5	6.4	7.5	8.6	9.8	11.1	12.4	13.8	15.3	16.8	18.3	19.9	21.5
7	1.3	1.6	2.0	2.4	2.9	3.6	4.2	5.0	5.8	6.7	7.7	8.7	9.7	10.8	12.0	13.1	14.4	15.6	16.9	18.2
8	1.2	1.5	1.9	2.3	2.8	3.3	3.9	4.6	5.3	6.1	6.9	7.8	8.7	9.6	10.6	11.6	12.6	13.6	14.7	15.8
9	1.2	1.5	1.8	2.2	2.7	3.2	3.7	4.3	5.0	5.7	6.4	7.1	7.9	8.7	9.6	10.4	11.3	12.2	13.1	14.0
10	1.2	1.5	1.8	2.2	2.6	3.0	3.5	4.1	4.7	5.3	5.9	6.6	7.3	8.0	8.8	9.5	10.3	11.0	11.8	12.6
11	1.2	1.5	1.8	2.1	2.5	2.9	3.4	3.9	4.4	5.0	5.6	6.2	6.8	7.4	8.1	8.8	9.4	10.1	10.8	11.5
12	1.2	1.4	1.7	2.0	2.4	2.8	3.2	3.7	4.2	4.7	5.2	5.8	6.4	7.0	7.5	8.1	8.8	9.4	10.0	10.6
13	1.2	1.4	1.7	2.0	2.3	2.7	3.1	3.6	4.0	4.5	5.0	5.5	6.0	6.5	7.1	7.6	8.2	8.7	9.3	9.9
14	1.2	1.4	1.7	2.0	2.3	2.6	3.0	3.4	3.9	4.3	4.8	5.2	5.7	6.2	6.7	7.2	7.7	8.2	8.7	9.2
15	1.2	1.4	1.6	1.9	2.2	2.6	2.9	3.3	3.7	4.1	4.6	5.0	5.4	5.9	6.4	6.8	7.3	7.7	8.2	8.7
16	1.2	1.4	1.6	1.9	2.2	2.5	2.9	3.2	3.6	4.0	4.4	4.8	5.2	5.6	6.1	6.5	6.9	7.3	7.8	8.2
17	1.2	1.4	1.6	1.9	2.1	2.5	2.8	3.1	3.5	3.8	4.2	4.6	5.0	5.4	5.8	6.2	6.6	7.0	7.4	7.8
18	1.2	1.4	1.6	1.8	2.1	2.4	2.7	3.0	3.4	3.7	4.1	4.4	4.8	5.2	5.6	5.9	6.3	6.7	7.0	7.4
19	1.2	1.4	1.6	1.8	2.1	2.4	2.7	3.0	3.3	3.6	4.0	4.3	4.6	5.0	5.3	5.7	6.0	6.4	6.7	7.1
20	1.2	1.3	1.6	1.8	2.0	2.3	2.6	2.9	3.2	3.5	3.8	4.2	4.5	4.8	5.2	5.5	5.8	6.1	6.5	6.8

The number of samples evaluated in determining the maximum observed effluent concentration (MOEC) should be used in this table and may be used to calculate the CV. EPA recommends a CV of 0.6 for $N < 10$ (where N is the number of samples). For $N > 10$, the CV can be calculated using Equation 9:

The critical effluent **pollutant** concentration (C_e) can now be calculated (Equation 20):

$$C_e = MOEC \times RPF$$

Equation 20. Calculation of critical effluent flow.

For most pollutants, if the receiving water pollutant concentration projected by a steady state model exceeds the **When the projected pollutant concentration in the receiving water exceeds the** applicable water quality criterion, there is reasonable potential, and the permit writer must calculate WQBELs. (Note that for dissolved oxygen, reasonable potential would occur if the water quality model indicates that the projected effluent concentration of the oxygen-demanding pollutants would result in depletion of dissolved oxygen below acceptable values in the receiving water).

If C_e is equal to or less than the applicable criterion, there is no reasonable potential and, thus far, there is no demonstrated need to calculate WQBELs.

In situations where mixing is incomplete, the permit writer projects the concentration of the pollutant of concern at the edge of the mixing zone after accounting for available dilution allowance. Then, the projected concentration can be compared to the applicable water quality criterion.

RPA must be completed for all pollutants of concern and their applicable criteria.

3.4.4.1 What to do if Data is not Available

In some cases, (e.g., new or modifications to an existing permit) **effluent** data may not be available as input into a steady-state model. In these cases, the permit writer determines RPA using a qualitative approach. The permit writer will use the following sources in the RPA:

- Effluent variability information such as history of compliance problems and toxic impacts
- Point and nonpoint source controls such as existing treatment technology, the type of industry, POTW treatment system, or BMPs in place
- Species sensitivity data including in-stream data, adopted water quality criteria, or designated uses
- Dilution information such as critical receiving water flows or mixing zones
- **Engineering reports provided with a New Source/Discharger application**
- **Effluent data from similar operations either provided in the application or through research**

After evaluating all available information, the permit writer may determine that monitoring **should may** be required to gather additional data. The permit writer might work with the permittee to obtain data before permit issuance, if sufficient time exists. The permit will include effluent and receiving water monitoring and reporting requirements that allow DEQ to complete an RPA and evaluate any appropriate mixing zones.

3.4.4.2 Document RPA in the Fact Sheet

Once the permit writer has shown RPTE, permit writers will document the details of the RPA in the IPDES permit fact sheet. The permit writer should clearly identify the information and procedures used to determine the need for WQBELs. The documentation will include:

- Statutory or regulatory citation
- Applicable site specific water quality standards considered
- The process used to determine the water quality model, critical conditions, and dilution allowance
- The process used to conduct the RPA including formulas and calculations.

3.5 Calculate Pollutant-Specific WQBELs

If a permit writer has determined that a pollutant or pollutant parameter is discharged at a level that will cause, have reasonable potential to cause, or contribute to an excursion above any state WQS at the edge of the mixing zone, then the permit writer must develop WQBELs for that pollutant parameter. The calculation of WQBELs for toxic pollutants and for a number of conventional or non-conventional pollutants with effluent concentrations that tend to follow lognormal distribution will have a similar procedure. When pollutants with effluent concentrations that do not follow lognormal distributions are encountered, the methodology used may be either a Monte Carlo simulation or current/relevant methods documented in DEQ's or other agency's guidance.

3.5.1 Calculate Pollutant-Specific WQBELs from Aquatic Life Criteria

Once an RPA has been performed that indicates an RPTE the permit writer calculates WQBELs. The process for developing pollutant-specific WQBELs for each pollutant involves several steps (Figure 9):



Figure 9. Process for developing chemical specific WQBELs.

DEQ will follow EPA's TSD (1991) process for calculating WQBELs from aquatic life criteria using the five steps in Figure 9 and described in the sections that follow.

3.5.1.1 Determine Acute and Chronic WLAs

The first step in the process of calculating a pollutant-specific WQBEL from aquatic life criteria is to determine the appropriate WLA. A TMDL WLA must be used if present; otherwise, a WLA can be calculated for a facility on a case-by-case basis if no TMDL exists.

If a TMDL is not available, the simple mass-balance equation used in Equation 19 can be rearranged to solve for the critical effluent pollutant concentration (C_e), which will be equivalent to the WLA, see Equation 21. C_e must be calculated for both acute and chronic criteria. The

downstream receiving water concentration, C_d , will be replaced with the water quality criterion (WQC), acute or chronic, for the pollutant under consideration.

$$C_e = WLA_{(a\ or\ c)} = \frac{WQC_{(a\ or\ c)}[Q_e + (Q_u \times \%MZ)] - [C_u \times (Q_u \times \%MZ)]}{Q_e}$$

Equation 21. Simple mass-balance equation for calculating WLA for flow water.

Where:

WQC _(a or c) = pollutant water quality criterion (acute or chronic)	Calculated value
Q _e = critical effluent flow	From discharge flow data (design flow for POTW)
Q _u = critical upstream flow (1Q10 acute criterion or 7Q10 chronic)	From water quality standards
%MZ = percent of critical low flow provided by mixing zone	From mixing zone analysis
C _u = critical upstream pollutant concentration	From receiving water data
C _e = WLA _(a or c) = waste load allocation (acute or chronic)	

Equation 21 must be applied to both the acute and chronic water quality criterion for each pollutant under investigation present in the effluent. Each of these values will be used to determine the acute and chronic long term averages (LTA_(a or c)), presented in Section 3.5.1.2.

To determine the WLA for non-flowing waters, the receiving water volume surrounding the discharge point must be determined. For discharges that commenced after July 1, 2015, the volume is the column of water at the discharge point whose surface area is either ≤ 5% of the receiving water’s surface area or 100 meters from the point of discharge, whichever is smaller. For discharges that existed before July 1, 2015 the receiving water volume is the column of water ≤ 10% of the receiving water’s surface area.

The WLA equation for non-flowing waters is presented in Equation 22:

$$WLA_{(a\ or\ c)} = WQC_{(a\ or\ c)}(D + 1) - D \times C_r$$

Equation 22. Simple mass-balance equation for calculating WLA for non-flowing water.

Where:

WLA _(a or c) = waste load allocation (acute or chronic)	Calculated value
WQC _(a or c) = pollutant water quality criterion (acute or chronic)	
D = Dilution ratio	Calculated from Equation 23
C _r = critical receiving water pollutant concentration (acute & chronic)	

The dilution ratio (D) used in Equation 22 is a simple ratio of the effluent volume and the receiving water volume. Equation 23 provides the relationship:

$$D = \frac{Q_e \times t}{V_r + Q_e \times t}$$

Equation 23. Non-flowing water dilution ratio.

Where:

D = Dilution ratio	Calculated (unitless)
--------------------	-----------------------

V_r = non-flowing receiving water volume	Millions of gallons (MG)
Q_e = effluent flow rate	Millions of gallons per day (MGD)
t = time required for the receiving water volume to turn over	Days

The pollutant specific WLA discharging to non-flowing waters will need to be calculated for both acute and chronic values using Equation 22.

3.5.1.2 Calculate Long-Term Average (LTA) Concentration for each WLA

The second step in calculating WQBELs is to calculate long-term average (LTA) values for both acute and chronic WLAs. DEQ has selected the TSD’s procedures for calculating LTAs. Tables for acute and chronic back calculations of LTA are located in the current TSD on page 102. The permit writer will use the 99th CL whenever calculating an LTA, acute or chronic, from the associated WLA. LTA_a will be calculated using Equation 24.

$$LTA_a = WLA_a \times e^{(0.5\sigma^2 - z_{99}\sigma)} \quad \text{Equation 24. Acute Long Term Average for Toxics}$$

Where:

LTA_a = acute long term average	Calculated value
WLA_a = acute wasteload allocation	Calculated value. See Equation 21 and Equation 22.
e = base of natural log	Approximately 2.718
σ = square root of σ^2	
$\sigma^2 = \text{Ln}(CV^2+1)$	Ln is the natural log
CV = Coefficient of Variation	Calculated using field data. If 10 or less samples available use default value of 0.6. See Equation 9
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326

LTA_c will be calculated using Equation 25.

$$LTA_c = WLA_c \times e^{(0.5\sigma_n^2 - z_{99}\sigma_n)} \quad \text{Equation 25. Chronic Long Term Average for Toxics}$$

Where:

LTA_c = chronic long term average	Calculated value
WLA_c = chronic wasteload allocation	Calculated value. See Equation 21 and Equation 22.
e = base of natural log	Approximately 2.718
σ_n = square root of σ_n^2	
$\sigma_n^2 = \text{Ln}[(CV^2)/n + 1]$	Ln is the natural log
CV = Coefficient of Variation	Calculated using field data. If 10 or less samples available use default value of 0.6. See Equation 9
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326
n = number of samples specified in the permit to be analyzed each month	Varies;

3.5.1.3 Select the Lowest LTA as the Performance Basis for the Permitted Discharger

To calculate MDL and AML for each pollutant select the lowest (minimum value) LTA (LTA_m) calculated using the acute and chronic WLAs. Using the smallest LTA assures that both WLAs are met, attaining both acute and chronic criteria, and sets one basis for facility performance.

3.5.1.4 Calculate Average Monthly and Maximum Daily Limits

DEQ has selected EPA's recommendation of applying the 99th percentile value to calculate the MDL while applying the 95th percentile value to calculate the AML. LTA multipliers for MDL and AML are listed in the TSD on page 103.

Calculate the CV using Equation 9, (round the CV to the nearest tenth (0.1)). Using the 99th percentile column in TDS Table 5-2, on page 103, and the calculated CV, identify the "LTA multiplier". If the calculated CV value exceeds 2.0, use Equation 26 to calculate the MDL.

$$MDL = LTA_m \times e^{(z_{99}\sigma - 0.5\sigma^2)}$$

Equation 26. Maximum Daily Limit for Toxics.

Where:

LTA_m = minimum long term average value	Calculated value. See Equation 24 and Equation 25.
MDL = maximum daily limit	Calculated value
e = base of natural log	Approximately 2.718
σ = square root of σ^2	
$\sigma^2 = \text{Ln}(\text{CV}^2 + 1)$	Ln is the natural log of base e
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326
CV = coefficient of variation	Equation 9

Calculating the AML requires that the permit writer identify how many samples (n) the permittee will be required to collect and analyze each month to verify compliance with the AML. This is not the number of samples that were used to assess RPTE. The AML will be evaluated at the 95th percentile CL. Calculate the CV, using Equation 9, (round the CV to the nearest tenth (0.1)). If the permit writer selects any of the following sample quantities (n = 1, 2, 4, 10, or 30), and the CV value is 2.0 or less, the 95th Percentile columns in TDS Table 5-2, on page 103, should be used to identify the "LTA multiplier". If the calculated CV value exceeds 2.0, or the samples required differ from the number specified (n = 1, 2, 4, 10, or 30), use Equation 27 to calculate the AML.

$$AML = LTA_m \times e^{(z_{95}\sigma_n - 0.5\sigma_n^2)}$$

Equation 27. Average Monthly Limit for Toxics.

Where:

LTA_m = minimum long term average	Calculated value. See Equation 24 and Equation 25.
AML = average monthly limit	Calculated value
e = base of natural log	Approximately 2.718
σ_n = square root of σ_n^2	
$\sigma_n^2 = \text{Ln}[(\text{CV}^2)/n + 1]$	Ln is the natural log of base e
Z_{95} = z score of the 95 th percentile of the normal distribution	1.645
n = Number of sample specified in the permit to be analyzed each month	Typically n = 1, 2, 4, 10, or 30.

CV = coefficient of variation

Equation 9

3.5.1.5 Document Calculation of WQBELs in the Fact Sheet

The rationale and calculations for the WQBELs must be included in the permit's fact sheet, which should include, at a minimum:

- Statutory and regulatory citations
- Process for determining the applicable WLA, including:
 - Selected water quality model
 - Critical conditions
 - Dilution allowance or mixing zone
- Process used to calculate water quality-based effluent limitations (including calculations)
- Number of samples (n) the permittee will be required to collect and analyze each month
- Antidegradation analysis or anti-backsliding analysis conducted and the basis for resulting decisions

The WQBEL calculations in the fact sheet are used in setting permit effluent limits.

3.5.2 Calculate Chemical-Specific WQBELs Based on Human Health Criteria for Toxic Pollutants

Developing WQBELs for toxic pollutants affecting human health is somewhat different from calculating WQBELs for other pollutants because (1) the exposure period of concern is generally longer (e.g., often a lifetime exposure) and (2) usually the average exposure, rather than the maximum exposure, is of concern. EPA's recommended approach for setting WQBELs for toxic pollutants for human health protection is to set the AML equal to the WLA calculated from the human health toxic pollutant criterion and then calculate the MDL from the AML.

If the permit writer calculates chemical-specific WQBELs from human health criteria, these WQBELs should be compared to any other WQBELs (e.g. WQBELs based on aquatic life criteria) and TBELS, and apply antidegradation and anti-backsliding requirements to determine the final limitations that meet all technology and water quality standards. As discussed above, that process should be documented in the permit's fact sheet.

3.6 Calculate RPA and WQBELs for Whole Effluent Toxicity (WET)

WET tests measure the degree of response of exposed aquatic test organisms to an effluent sample or a sample mixture of some proportion of effluent with dilution water (e.g., laboratory water, non-toxic receiving water). Idaho WQS do not have numeric criteria for WET. WET tests are more complicated and expensive than most other types of analyses. The number of test results for a given permittee is often less than other commonly evaluated pollutants. For example, semi-annual acute and chronic testing, which is generally recommended for major facilities, will yield 10 tests over the 5-year permit cycle. Less frequent testing is generally required for minor facilities.

The RPTE is based on toxicity data submitted by the discharger. For a RPTE analysis, data should be available for acute and chronic testing with select aquatic test species listed in the User's Guide Volume 2, Section X, Table Y. The permit writer can evaluate the need for

WQBELs using a calculated numeric criterion that will attain and maintain the applicable narrative criterion. Typically, Idaho's narrative criterion for toxics is interpreted to mean $TU_a = 0.3$ and $TU_c = 1$, as defined in Section 3.3.2.3. Using these values, the permit writer uses WET test results to project acute or chronic toxicity in the receiving water after accounting for the applicable dilution allowance or mixing zone. If the projected toxicity exceeds the calculated criterion, the permit writer has demonstrated RPTE and must calculate WET limits.

3.6.1 Expressing WET Limits or Test Results

There are two options for expressing WET limits or test results: directly in terms of endpoints or indirectly in terms of toxic units.

Toxicity in terms of endpoints is typically expressed in one of the following ways:

- No observed effect concentration (NOEC), the highest concentration of effluent (i.e., highest percent effluent) at which no adverse effects are observed on the aquatic test organisms;
- Lowest observed effect concentration (LOEC), the lowest concentration of effluent that causes observable adverse effects in exposed test organisms;
- Inhibition concentration (IC), a point estimate of the effluent concentration that would cause a given percent reduction in a biological measurement of the test organisms; or
- Effect concentration (EC), a point estimate of the effluent concentration that would cause an observable adverse effect in a given percentage of test organisms.

Each of these endpoints can be converted, where applicable, to toxic units by dividing 100 by the test result percentage. For example, if the IC_{25} for a chronic test is 60% (Equation 28):

$$\frac{100}{60} = 1.7 \text{ chronic toxic units } (TU_c)$$

Equation 28. Example of endpoint conversion to toxic units.

However, it should be noted that $1.0 TU_a \neq 1.0 TU_c$, because they represent toxicity at different endpoints. A permit may require monitoring both acute and chronic toxicity. When at least 10 sets of paired acute and chronic WET test data are available, the permit writer may develop an acute-to-chronic ratio (ACR), to equate TU_a and TU_c . For fewer than 10 paired sets of data, EPA recommends a default ACR of 10. The ACR will be used to convert acute data to chronic or chronic data to acute. If chronic data are not available, the acute data are converted to chronic data by multiplying each acute toxicity TU_a by the TSD default ACR of 10. The reciprocal mathematical operation is used to convert each chronic TU_c to a TU_a using the ACR. The ACR used is the average of these 10 individual ratios.

The ACR is expressed as: (Equation 29):

$$ACR = \frac{\text{Acute Endpoint}}{\text{Chronic Endpoint}} = \frac{LC_{50}}{IC_{25}} \quad \text{Equation 29. ACR expression.}$$

A TU is the inverse of the sample fraction (Equation 30). Therefore:

$$TU_a = \frac{100}{LC_{50}} \text{ and } TU_c = \frac{100}{IC_{25}} \quad \text{Equation 30. } TU_a \text{ and } TU_c \text{ expressions.}$$

Consequently, toxicity as percent sample, may be expressed as Equation 31:

$$LC_{50} = \frac{100}{TU_a} \text{ and } IC_{25} = \frac{100}{TU_c} \quad \text{Equation 31. Toxicity expressed as percent sample.}$$

Substituting into Equation 29, we can rearrange to obtain Equation 32:

$$ACR = \frac{LC_{50}}{IC_{25}} = \frac{\frac{100}{TU_a}}{\frac{100}{TU_c}} = \frac{TU_c}{TU_a} \quad \text{Equation 32. ACR in terms of TU.}$$

Example 1:

Given $LC_{50} = 28\%$, $IC_{25} = 10\%$

Using Equation 32, $ACR = \frac{28\%}{10\%} = 2.8$

Example 2:

Given $TU_a = 3.6$, $TU_c = 10.0$

Using Equation 32, $ACR = \frac{TU_c}{TU_a} = \frac{10.0}{3.6} = 2.8$

Example 3:

Given the toxicity data for a facility's effluent for *C. dubia* (Table 27) and using Equation 32 to calculate the ACR in column 3:

Table 27. Example WET data.

LC ₅₀ (% effluent)	IC ₂₅ (% effluent)	ACR
62	10	6.2
18	10	1.8
68	25	2.7
61	10	6.1
63	25	2.5
70	25	2.8
17	5	3.4
35	10	3.5
35	10	3.5
35	25	1.4
47	10	4.7
Mean = 3.5		

Example 4:

Given $TU_a = 1.8$, $ACR = 3.5$

Using Equation 32 and rearranging to solve for TU_c , $TU_c = ACR \times TU_a = 3.5 \times 1.8 = 6.3$

3.6.2 WET WLA and RPA

The first step in performing RPA for WET is to assess the WET WLAs. The wasteload allocations for acute and chronic WET criteria ($WLA_{a/c}$) must be calculated from the simple mass balance equation presented in Equation 33, with a few terms changed.

$$WLA_{a/c} = \frac{(AC \text{ or } CC) \times [Q_e + (Q_u \times \%MZ)] - [C_u \times (Q_u \times \%MZ)]}{Q_e}$$

Equation 33. Simple mass-balance equation for WET WLA.

Where:

$WLA_{a/c}$ = wasteload allocation (acute or chronic)	Calculated value
Q_e = critical effluent flow	From discharge flow data
Q_u = critical upstream flow (1Q10 acute criterion or 7Q10 chronic)	From water quality standards
%MZ = percent of critical low flow provided by mixing zone	From mixing zone analysis
C_u = critical upstream pollutant concentration	Default is 0
$WLA_{a/c}$ = waste load allocation (acute or chronic)	
AC = Acute Whole Effluent Criterion	0.3 TU_a
CC = Chronic Whole Effluent Criterion	1.0 TU_c

3.6.2.1 Data Quantity and Quality Considerations

An RPA is based on toxicity data submitted by the discharger. For a RPA data should be available for acute and chronic testing with *Ceriodaphnia dubia* and *Pimephales promelas*. However, as an alternative when there is a lack of acute or chronic testing data, the ACR may be used to convert acute data to chronic or chronic data to acute.

If less than 10 acute or chronic data points are available, then an RPA generally should not be performed. In this case monitoring will be required where data is lacking. For major facilities, acute and chronic monitoring should be on a semi-annual basis so that 10 valid data points will be available by the end of the permit cycle.

3.6.2.2 RPA Assessment

An RPA can be assessed if there are at least 10 valid WET test results for acute, chronic, or both (whichever is applicable), and:

- The maximum probable effluent TU_a at the 99% CL of the 99% probability level is greater than the WET WLA_a ;
- The maximum probable effluent TU_c at the 99% CL of the 99% probability level is greater than the WET WLA_c .

Select the appropriate RPMF from Table 26 based on the CV and number of tests performed.

These analyses will result in 4 possible Maximum Probable Concentrations (MPC), an acute and a chronic value for each of the 2 species used in the WET tests. The MPC is calculated by multiplying the maximum TU_a for each species, and the maximum TU_c for each species by the RPMF from Table 26. If the MPC for a species for a given test type (acute or chronic) is less than the appropriate WET WLA, then no RPTE exists, and no WET WQBELs need be generated. If RPTE are indicated then WET limits may need to be calculated for WET WLA_a , WET WLA_c , or both.

3.6.3 Determine WET Triggers and Limits

If there is no RPTE, then the permit writer should include a trigger value equal to 90% of the calculated numeric criterion and require WET monitoring in the permit. If a WET monitoring result exceeds the trigger value, then the permittee must conduct accelerated testing. Accelerated test results that exceed the calculated numeric criteria will determine the need for a WET limit in future permits.

3.6.3.1 Calculate Acute WET Limit

Using the WET WLA_a , calculate the LTA_a at the 99% CL using the Equation 34.

$$LTA_a = WLA_a \times e^{(0.5\sigma^2 - z_{99}\sigma)}$$

Equation 34. WET acute LTA.

Where:

LTA_a = acute long term average
 WLA_a = acute wasteload allocation
 e = base of natural log
 σ = square root of σ^2

Calculated value
 Calculated value. See Equation 33.
 Approximately 2.718

$\sigma^2 = \text{Ln}(\text{CV}^2+1)$	Ln is the natural log
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326

Calculate the maximum daily and average monthly permit limits using the LTA_a . Use Equation 35 to calculate the Maximum Daily Limit (MDL), using 99th percentile z-score, and use Equation 36 to calculate the Average Monthly Limit (AML), using the 95th percentile z-score.

$$MDL_a = LTA_a \times e^{(z_{99}\sigma - 0.5\sigma^2)} \quad \text{Equation 35. Acute WET maximum daily limit.}$$

$$AML_a = LTA_a \times e^{(z_{95}\sigma_n - 0.5\sigma_n^2)} \quad \text{Equation 36. Acute WET average monthly limit.}$$

Where:

LTA_a = acute long term average	Calculated value. See Equation 34.
MDL_a = acute maximum daily limit	Calculated value
AML_a = acute average monthly limit	Calculated value
e = base of natural log	Approximately 2.718
σ = square root of σ^2	
σ_n = square root of σ_n^2	
$\sigma^2 = \text{Ln}(\text{CV}^2+1)$	Ln is the natural log of base e
$\sigma_n^2 = \text{Ln}[(\text{CV}^2/n) + 1]$	Ln is the natural log of base e
Z_{95} = z score of the 95 th percentile of the normal distribution	1.645
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326
n = Number of sample specified in the permit to be analyzed each month	Default = 1
CV = coefficient of variation	Equation 9

3.6.3.2 Calculate Chronic WET Limit

Using the WET WLA_c , calculate the LTA_c at the 99% CL using the Equation 37.

$$LTA_c = WLA_c \times e^{(0.5\sigma_4^2 - z_{99}\sigma_4)} \quad \text{Equation 37. Chronic WET long-term average.}$$

Where:

LTA_c = chronic long term average	Calculated value
WLA_c = chronic wasteload allocation	Calculated value. See Equation 33.
e = base of natural log	Approximately 2.718
σ_4 = square root of σ_4^2	
$\sigma_4^2 = \text{Ln}[(\text{CV}^2/4) + 1]$	Ln is the natural log of base e
Z_{99} = z score of the 99 th percentile of the normal distribution	2.326

Calculate the maximum daily and average monthly permit limits using the LTA_c . Use Equation 38 to calculate the Maximum Daily Limit (MDL), using 99th percentile z-score, and use Equation 39 to calculate the Average Monthly Limit (AML), using the 95th percentile z-score.

$$MDL_c = LTA_c \times e^{(z_{99}\sigma - 0.5\sigma^2)} \quad \text{Equation 38. Chronic WET maximum daily limit.}$$

$$AML_c = LTA_c \times e^{(z_{95}\sigma_n - 0.5\sigma_n^2)} \quad \text{Equation 39. Chronic WET average monthly limit.}$$

Where:

LTA _c = chronic long term average	Calculated value. See Equation 37.
MDL _c = chronic maximum daily limit	Calculated value
AML _c = chronic average monthly limit	Calculated value
e = base of natural log	Approximately 2.718
σ = square root of σ^2	
σ_n = square root of σ_n^2	
$\sigma^2 = \text{Ln}(\text{CV}^2+1)$	Ln is the natural log of base e
$\sigma_n^2 = \text{Ln}[(\text{CV}^2/n) + 1]$	Ln is the natural log of base e
Z ₉₅ = z score of the 95 th percentile of the normal distribution	1.645
Z ₉₉ = z score of the 99 th percentile of the normal distribution	2.326
n = Number of sample specified in the permit to be analyzed each month	Default = 1
CV = coefficient of variation	Equation 9

3.6.4 Document RPA and WQBEL Calculations for WET in the Fact Sheet

The permit writer will record all rationale, regulatory justification, and decisions regarding RPA and WQBELs calculation for WET in the permit’s fact sheet, including:

- Statutory and regulatory citations
- Monitoring frequency – the required WET monitoring frequency
- RP determinations – the calculations for deriving or revising WET limit and the associated RPA workbook.
- WET triggers and limits – the decision making process and calculations for establishing the permittee’s WET triggers in the IPDES permit (see Section 3.3.2.3 for details on criteria that qualify a permittee for WET triggers). Permittees with WET limits will be assigned triggers at 90% of the calculated WET limit. These WET triggers will flag in the IPDES interface in response to WET test results that exceed 90% of the calculated WET limit and will require the permittee to complete accelerated WET testing.
- Justification for inclusion or omission of valid WET data – how generated WET test data is used for or not used in reasonable potential determinations and NPDES permit compliance. If data generated over the course of a previous permit cycle are not used, the reasons for not using certain data or using other data must be clearly explained.

4 Final Effluent Limits and Antibacksliding

References

Author. Date. *Title*. City, State: Publisher. Document No. [Document Link](#)

APHA, AWWA, WEF (American Public Health Association, American Water Works Association, Water Environment Federation). 1999. *Standard Methods for the Examination of Water and Wastewater, Part 1050 B*.
http://www.mwa.co.th/download/file_upload/SMWW_1000-3000.pdf

Conover, W.L. 1999. *Practical Nonparametric Statistics*. 3rd ed. New York, NY: John Wiley & Sons.

- DEQ (Idaho Department of Environmental Quality). 2002. *NPDES Decision Analysis Report #2 – Appendix 4. Guidance for Water Quality-Based Effluent Limits*. Boise, ID: DEQ. www.deq.idaho.gov/media/529907-npdes_primacy_report2.pdf
- DEQ (Idaho Department of Environmental Quality). 2012. *Quality Management Plan*. Boise, ID: DEQ. http://www.deq.idaho.gov/media/1069323-deq_quality_management_plan.pdf
- DEQ (Idaho Department of Environmental Quality). 2014. *Statistical Guidance for Determining Background Ground Water Quality and Degradation*. Boise, ID: DEQ. www.deq.idaho.gov/media/1226/guidance-statistical-degradation.pdf
- DEQ (Idaho Department of Environmental Quality). 2015. *Water Body Assessment Guidance*: 3rd ed. Boise, ID: DEQ. www.deq.idaho.gov/media/60179244/water-body-assessment-guidance.pdf
- DEQ (Idaho Department of Environmental Quality). 2016. *User's Guide to Permitting and Compliance Volume 1 – General Information*. Boise, ID: DEQ. www.deq.idaho.gov/media/60178999/ipdes-user-guide-ipdes-permitting-compliance-0816.pdf
- DEQ (Idaho Department of Environmental Quality). 2017. *Idaho Antidegradation Implementation Procedures*. Draft. Boise, ID: DEQ. <http://www.deq.idaho.gov/media/792352-antidegradation-implementation-procedures-draft-0112.pdf>
- EPA (US Environmental Protection Agency). 1985. *Draft Guidance for NPDES Permits and Compliance Personnel—Secondary Treatment Redefinition*. Washington, DC: Office of Water Enforcement and Permits.
- EPA (US Environmental Protection Agency). 1991. *Technical Support Document for Water Quality-Based Toxics Control*. Washington, DC: Office of Water. EPA/505/2-90-001. <https://www3.epa.gov/npdes/pubs/owm0264.pdf>
- EPA (US Environmental Protection Agency). 1996a. *Guidance on the Documentation and Evaluation of Trace Metals Data Collected for Clean Water Act Compliance Monitoring*. Washington, DC: Office of Science and Technology. <https://nepis.epa.gov/Exe/ZyNET.exe/P10058HZ.TXT?ZyActionD=ZyDocument&Client=EPA&Index=1995+Thru+1999&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C95thru99%5CTxt%5C00000024%5CP10058HZ.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL>
- EPA (US Environmental Protection Agency). 1996b. *Method 1669: Sampling Ambient Water for Trace Metals at EPA Water Quality Criteria Levels*. Washington, DC: Office of Water. https://www3.epa.gov/caddis/pdf/Metals_Sampling_EPA_method_1669.pdf

- EPA (US Environmental Protection Agency). 1996c. *EPA Region 10 Guidance for WQBELs Below Analytical Detection/Quantitation Level*. Seattle, WA: Office of Water.
<https://dec.alaska.gov/water/npdes/Binders/application/APDES%20Application%20Guidance%20Documents/EPA%20Region%2010%20Guidance%20for%20%20WQBEL%20below%20detection%20level.pdf>
- EPA (US Environmental Protection Agency). 2000. *Understanding and Accounting for Method Variability in Whole Effluent Toxicity Applications under the National Pollutant Discharge System*. Office of Water, Office of Research and Development, and Office of Enforcement and Compliance Assurance. EPA 833-R-00-003.
<https://www3.epa.gov/npdes/pubs/wetmethodvariability.pdf>
- EPA (US Environmental Protection Agency). 2001. *EPA Requirements for Quality Assurance Project Plans*. Office of Environmental Information. EPA/240/B-01/003.
https://www.epa.gov/sites/production/files/2016-06/documents/r5-final_0.pdf
- EPA (US Environmental Protection Agency). 2002. *Guidance for Quality Assurance Project Plans*. Office of Environmental Information. EPA/240/R-02/009.
<https://www.epa.gov/sites/production/files/2015-06/documents/g5-final.pdf>
- EPA (US Environmental Protection Agency). 2004. *Local Limits Development Guidance*. Office of Wastewater Management. EPA 833-R-04-002A.
https://www3.epa.gov/npdes/pubs/final_local_limits_guidance.pdf
- EPA (US Environmental Protection Agency). 2005. *Guidance on Water Quality Based Effluent Limits Set Below Analytical Detection/Quantitation Limits*. Seattle, WA: EPA Region 10.
[https://yosemite.epa.gov/r10/water.nsf/NPDES+Permits/Permits+Homepage/\\$FILE/ML-MDL-Policy-4-25-05.pdf](https://yosemite.epa.gov/r10/water.nsf/NPDES+Permits/Permits+Homepage/$FILE/ML-MDL-Policy-4-25-05.pdf)
- EPA (US Environmental Protection Agency). 2009. *Statistical Analysis of Groundwater Monitoring Data at RCRA Facilities: Unified Guidance*. Washington, DC: Office of Resource Conservation and Recovery.
<https://nepis.epa.gov/Exe/ZyNET.exe/P10055GQ.TXT?ZyActionD=ZyDocument&Client=EPA&Index=2006+Thru+2010&Docs=&Query=&Time=&EndTime=&SearchMethod=1&TocRestrict=n&Toc=&TocEntry=&QField=&QFieldYear=&QFieldMonth=&QFieldDay=&IntQFieldOp=0&ExtQFieldOp=0&XmlQuery=&File=D%3A%5Czyfiles%5CIndex%20Data%5C06thru10%5CTxt%5C00000011%5CP10055GQ.txt&User=ANONYMOUS&Password=anonymous&SortMethod=h%7C-&MaximumDocuments=1&FuzzyDegree=0&ImageQuality=r75g8/r75g8/x150y150g16/i425&Display=hpfr&DefSeekPage=x&SearchBack=ZyActionL&Back=ZyActionS&BackDesc=Results%20page&MaximumPages=1&ZyEntry=1&SeekPage=x&ZyPURL#>
- EPA (US Environmental Protection Agency). 2010. *NPDES Permit Writer's Manual*. Washington, DC: Office of Wastewater Management. EPA-833-K-001.
https://www3.epa.gov/npdes/pubs/pwm_2010.pdf
- EPA (United States Environmental Protection Agency). 2013a. *ProUCL 5.0 Software and User Guide*. Washington, DC: Office of Research and Development. EPA/600/R-07/041
https://www.epa.gov/sites/production/files/2015-03/documents/proucl_v5.0_user.pdf

- EPA (United States Environmental Protection Agency). 2013b. *ProUCL 5.0 Technical Guide*. Washington, DC: Office of Research and Development. EPA/600/R-07/041
https://www.epa.gov/sites/production/files/2015-03/documents/proucl_v5.0_tech.pdf
- EPA (US Environmental Protection Agency). 2016. *Protocol for Review and Validation of New Methods for Regulated Organic and Inorganic Analytes in Wastewater under EPA's Alternate Test Procedure Program*. Office of Water. EPA 821-B-16-001.
https://www.epa.gov/sites/production/files/2016-03/documents/chemical-new-method-protocol_feb-2016.pdf
- EPA (United States Environmental Protection Agency). 1993. *Guidance Manual for Developing Best Management Practices (BMP)*. Washington, DC: Office of Water.
www.epa.gov/npdes/pubs/owm0274.pdf
- EPA (United States Environmental Protection Agency). 1992. *Storm Water Management for Industrial Activities: Developing Pollution Prevention Plans and BMPs*. Washington, DC: Office of Water. EPA/832/R/92/006
- ODEQ (Oregon Department of Environmental Quality). 2013. *The Use of Significant Figures and Rounding Conventions in Water Quality Permitting*. Portland, OR: ODEQ
<http://www.deq.state.or.us/wq/pubs/imds/SigFigsIMD.pdf>
- Gibbons, R.D. 1994. *Statistical Methods for Groundwater Monitoring*. New York, NY: John Wiley & Sons.
- Gilbert, R.O. 1987. *Statistical Methods for Environmental Pollution Monitoring*. New York, NY: Van Nostrand Reinhold.
- Harris, J., J.C. Loftis, and R.H. Montgomery. 1987. Statistical Methods for Characterizing Ground-Water Quality. *Ground Water*. 25(2): 185–193.
- Putnam, Hayes and Bartlett, Inc. 1982. *Protocol and Workbook for Determining Economic Achievability for National Pollutant Discharge Elimination System Permits*. U.S. Environmental Protection Agency, Permits Division, Washington, DC.
<www.epa.gov/npdes/pubs/protocol_npdespermits.pdf> and
<www.epa.gov/npdes/pubs/workbook_econ_permits.pdf>
- VDEQ (Commonwealth of Virginia, Department of Environmental Quality). 2009. *TMDL Guidance Memo No. 09-2001. Guidance for monitoring of point sources for TMDL development using low-level PCB method 1668*. Richmond, VA: VDEQ.
<http://www.deq.virginia.gov/Portals/0/DEQ/Water/TMDL/PCB/pcbmonguidance.pdf>

Key Terms

Citations for key terms used in this guide are provided below. To see the official definition for a term, users should go directly to the rule that is referenced.

Term	IDAPA, CFR, or CWA Citation
Antibacksliding	Clean Water Act section 402(o).
Application	IDAPA 58.01.25.010.03.
Background	IDAPA 58.01.25.010.08.
Balanced, Indigenous, Community (or Population)	40 CFR 125.71(c).
Best Management Practices (BMPs)	IDAPA 58.01.25.010.09.
Biochemical Oxygen Demand (BOD)	IDAPA 58.01.25.010.10.
Compliance Schedule or Schedule of Compliance	IDAPA 58.01.25.010.17.
Direct discharge	IDAPA 58.01.25.010.24.
Discharge	IDAPA 58.01.25.010.27.
Discharge Monitoring Report (DMR)	IDAPA 58.01.25.010.26.
Discharge of a Pollutant	IDAPA 58.01.25.010.28.
Draft Permit	IDAPA 58.01.25.010.29.
Effluent	IDAPA 58.01.25.010.30.
Effluent Data	40 CFR 2.302(a)(2)(i)–(ii)
Effluent Limitation	IDAPA 58.01.25.010.31.
Effluent Limitation Guidelines (ELG)	IDAPA 58.01.25.010.32.
Existing Discharger	IDAPA 58.01.02.010.37.
Facility or Activity	IDAPA 58.01.25.010.38.
Fundamentally Different Factors	IDAPA 58.01.02.010.39.
General Permit	IDAPA 58.01.02.010.40.

Hydrologically-Based Design Flow	IDAPA 58.01.02.010.50 <ul style="list-style-type: none"> • 1Q10 (IDAPA 58.01.02.210.03.b.i) • 1B3 (IDAPA 58.01.02.210.03.b.ii) • 7Q10 (IDAPA 58.01.02.210.03.b.iii) • 4B3 (IDAPA 58.01.02.210.03.b.iv) • Harmonic Mean Flow (IDAPA 58.01.02.210.03.b.v)
Idaho Pollutant Discharge Elimination System (IPDES)	IDAPA 58.01.25.010.42
Indirect Discharger	IDAPA 58.01.25.010.45
Intake Pollutant	IDAPA 58.01.25.303.07.a.i
Interference	40 CFR 403.3(k)
Load Allocation (LA)	IDAPA 58.01.25.010.50
Major Facility	IDAPA 58.01.25.010.51
Method Detection Limit (MDL)	40 CFR 136, Appendix B
Minimum Level (ML)	40 CFR 136, Table 2
Mixing Zone	IDAPA 58.01.25.010.54
Municipality	IDAPA 58.01.25.010.55
National Pollutant Discharge Elimination System (NPDES)	IDAPA 58.01.25.010.56
New Discharger	IDAPA 58.01.25.010.57
New Source	IDAPA 58.01.25.010.58.a
Owner or Operator	IDAPA 58.01.25.010.62
Pass Through	40 CFR 403.3(p)
Permit	IDAPA 58.01.25.010.63
Person	IDAPA 58.01.25.010.64
Point source	IDAPA 58.01.25.010.65
Pollutant	IDAPA 58.01.25.010.66
Pretreatment	IDAPA 58.01.25.010.68
Process Wastewater	IDAPA 58.01.25.010.71
Publicly Owned Treatment Works (POTW)	IDAPA 58.01.25.010.73
Reasonable Potential Analysis (RPA)	58.01.25.302.06.a.ii–vi

Reasonable Potential to Exceed (RPTE)	58.01.25.302.06.a.ii–vi
Recommencing Discharger	IDAPA 58.01.25.010.75
Secondary Treatment	IDAPA 58.01.25.010.78
Sewage Sludge	IDAPA 58.01.25.010.84
Source	IDAPA 58.01.25.010.90
Storm Water	IDAPA 58.01.25.010.94
Technology-Based Effluent Limitation (TBEL)	IDAPA 58.01.25.010.95
Total Maximum Daily Load (TMDL)	IDAPA 58.01.02.010.100
Treatment Works Treating Domestic Sewage (TWTDS)	IDAPA 58.01.25.010.100
Variance	IDAPA 58.01.25.103
Wasteload Allocation (WLA)	IDAPA 58.01.25.010.104
Water Body (Unit)	IDAPA 58.01.02.010.110
Water Quality-Based Effluent Limitation (WQBEL)	IDAPA 58.01.25.010.107
Waters of the United States	IDAPA 58.01.25.003.aa
Whole Effluent Toxicity	IDAPA 58.01.25.010.110

Appendix A. Significant Figures and Precision for Permit Limits and Reporting

Permit writers should include in IPDES permits, the following or similar language, clarifying how permittees should report significant figures on the DMR:

The permittee ~~shall~~must report the same number of significant figures or precision as the permit limit for a given pollutant or pollutant parameter. Regardless of the rounding conventions used by the permittee, the permittee ~~shall~~must use the conventions consistently, and ~~shall~~must ensure that consulting laboratories employed by the permittee use the same conventions.

Pollutant	Typical Permit Limit Range	Standard Laboratory Technique	Concentration Value = Minimum Number of Significant Figures	DMR Reporting Precision
Conventional Pollutants				
BOD	5.0 to 50 mg/L	DO Probe	< 10 mg/L = 2 sig figs > 10 mg/L = 2 sig figs	Report to 0.1 mg/L Report whole numbers
CBOD	2.0 to 45 mg/L	DO Probe	< 10 mg/L = 2 sig figs > 10 mg/L = 2 sig figs	Report to 0.1 mg/L Report whole numbers
TSS	5.0 to 80.0 mg/L	Filtration/ Gravimetric	<10 mg/L = 2 sig figs > 10 mg/L = 3 sig figs	Report to 0.1 mg/L
Temperature	77°F as a maximum	Various	Various	Report + 0.1 degrees F or C
Bacteria (fecal, E. coli, etc.)	126/ 235/ 406/ 576 for E. coli	Various	<10 = 1 sig fig >10 <100 = 2 sig figs >100 = 3 sig figs	Report whole numbers only
DO	8.0 to 10.0 mg/L	DO Probe	< 10 mg/L = 2 sig figs > 10 mg/L = 3 sig figs	Report to 0.1 mg/L
Total chlorine residual (method dependent)	0.02 to 1.0 mg/L 0.1 to 1.0 mg/L	Amperometric Titr. DPD – colorimetric	< 0.1 mg/L = 1 sig fig > 0.1 <10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.01 mg/L Report to 0.1 mg/L Report to 0.1 mg/L
Minimum UV dose	35 millijoules			
pH	6.0 to 9.0	pH Probe	<10 = 2 sig figs >10 = 3 sig figs	Report to 0.1 pH unit
Nutrients				
TKN	5.0 to 20.0 mg/L	Digest w/ ISE or Colorimetric	<10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.1 mg/L
Total Ammonia as N	1.0 to 30.0 mg/L	Distill w/ ISE or Colorimetric IC	<10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.1 mg/L
Nitrate and Nitrite	1.0 to 20.0 mg/L	Colorimetric or IC	<10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.1 mg/L
Total Phosphorus	0.01 to 3.0 mg/L	Colorimetric	< 0.1 mg/L = 1 sig fig > 0.1 <10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.01 mg/L Report to 0.1 mg/L Report to 0.1 mg/L
Dissolved Orthophosphate as P	0.01 to 3.0 mg/L	Colorimetric	< 0.1 mg/L = 1 sig fig > 0.1 <10 mg/L = 2 sig figs >10 mg/L = 3 sig figs	Report to 0.01 mg/L Report to 0.1 mg/L Report to 0.1 mg/L
Toxics				
In Permit	In Permit	In Permit	In Permit	In Permit

Appendix B. Potential Approaches for Limiting Toxic Pollutants

Toxics are a broad group of chemicals that can have a detrimental effect on living organisms. The CWA Section 307(a) *priority* pollutants are a subset of this group of pollutants. The TSD (EPA 1991) provides a foundation for evaluating toxics; however, IPDES permit writers should be aware of currently-evolving issues regarding toxics, which include:

- Appropriate protocols and methods must be followed during the data collection of toxic pollutants or samples could easily be contaminated. If collection methods contaminate a sample, the data should be blank corrected or censored and the data should be collected using appropriate methods and results should be appropriately handled (e.g. blank adjusted where needed).
- There are various methods for the laboratory analysis of toxics, which may have different detection levels. Permit writers should use caution when assessing a dataset when the results are based on different methods and different detection levels.
- Depending on the data distribution, permit writers may consider using a geometric mean for background of toxic pollutants. While the TSD is silent on this issue, other states and programs may have more recent and comprehensive methods for determining background concentrations.

Table B-1 provides a matrix overview of toxics and topics to consider for toxics during the effluent limit development process.

Table B-1. Matrix overview of topics and considerations in effluent development for toxic pollutants.

Effluent Limit Development Step	Ammonia	Copper	Metals Cd, Pb, Zn, Arsenic	Hg	HHC, PCBs, Phthalates, Plus Others
Characterize Effluent	Toxic and dissolved oxygen impacts MPEC 95th	BLM	Cause of background Intake variance	MPEC Geometric mean	Blank correction
Characterize Receiving Water	Little or no ambient	DEQ Guidance	Geometric mean	Geometric mean	Geometric mean Blank correction
Determine Applicable Water Quality Standards	Appropriate frequency and duration	Updates to criteria	WER Recalculation 304(a) criteria	Fish tissue	Probabilistic approach Variances
Determine the Need for WQBELs (RPA)	Monte Carlo Mixed pH Mixing Zone	Monte Carlo Mixing Zone	TSD Mixing Zone	DEQ guidance	Plausible cause and reductions Mixing zone
Interim and Final WQBELs	Monte Carlo	Monte Carlo	Plausible cause and reductions	Dental BMPs	Toxic management plans Congener cap

Acronyms: BLM = Biotic Ligand Model; MPEC = Mathematical Program with Equilibrium Constraints

Appendix C. Pollutants Regulated by Categorical Pretreatment Standards

	1,1,1-Trichloroethane	1,1,2,2-Tetra-chloroethane	1,1,2-Trichloroethane	1,1-Dichloroethane	1,1-Dichloroethylene	1,2,4-Trichloro- benzene	1,2-Dichlorobenzene	1,2-Dichloroethane	1,2-Dichloropropane	1,2-Diphenyl- hydrazine	1,2-trans-Dichloroethylene	1,3-Dichloro- benzene	1,3-Dichloro- propene	1,4-Dichloro- benzene	2,3,4,6-Tetra-chlorophenol	2,3-Dichloro- aniline	2,4,5-Trichloro- phenol	2,4,6-Trichloro- phenol	2,4-Dichlorophenol	2,4-Dimethyl- phenol	2,4-Dinitro- toluene	2,4-Dinitrophenol	2,6-Dinitro- toluene	2-Chloro- naphthalene	2-Chloroethyl vinyl ether (mixed)	2-Chlorophenol	2-Nitrophenol	3,3-Dichloro- benzidine	3,4,5-Trichloro- catechol	3,4,5-Trichloro- guaiacol	3,4,6-Trichloro- catechol	3,4,6-Trichloro- guaiacol	4,4-DDD	4,4-DDE				
Aluminum Forming										X											X					X												
Battery Manufacturing																																						
Carbon Black Manufacturing																																						
Centralized Waste Treatment																X		X																				
Coil Coating	X	X		X	X																																	
Copper Forming	X																							X														
Electrical and Electronic Components	X		X		X	X	X	X		X		X		X				X	X							X	X											
Electroplating	X	X	X	X	X	X	X	X	X	X	X	X	X	X				X	X	X	X	X	X	X	X		X	X	X						X	X		
Feedlots																									X													
Fertilizer Manufacturing																																						
Glass Manufacturing																																						
Grain Mills																																						
Ink Formulating																																						
Inorganic Chemicals Manufacturing																																						
Iron and Steel Manufacturing																																						
Leather Tanning and Finishing																																						
Metal Finishing	X	X	X	X	X		X	X	X	X	X																									X	X	
Metal Molding and Casting	X					X						X	X	X				X	X	X	X	X	X	X		X	X	X										
Nonferrous Metals Form./Metal																									X													
Nonferrous Metals Manufacturing																		X	X	X						X												
Oil and Gas																																						
Organic Chems., Plastics, and Syn.	X		X	X	X		X	X	X		X																											
Paint Formulating																																						
Paving and Roofing Materials						X						X	X	X																								
Pesticide Chemicals	X				X		X	X	X		X																											
Petroleum Refining																																						
Pharmaceutical Manufacturing							X	X					X	X																								
Porcelain Enameling																																						
Pulp, Paper, and Paperboard																																						
Rubber Manufacturing																																						
Soap and Detergent Manufacturing																X		X	X																			
Steam Electric Power Generating	X	X	X	X	X		X	X	X	X	X																										X	X
Timber Products Processing																																						
Transportation Equip. Cleaning						X						X	X	X				X	X	X	X	X	X	X		X	X	X										
Waste Combustors																									X													

	4,4-DDT	4,5,6-Trichloro- quaiacol	4,6-Dinitro-o- cresol	4-Bromophenyl phenyl ether	4-Chlorophenyl phenyl ether	4-Nitrophenol	Acenaphthene	Acenaphthylene	Acetone	Acrolein	Acrylonitrile	Aldrin	Alpha- endosulfan	Alpha-BHC	Ammonia (as N)	Anthracene	Benzene	Benzidine	Benzo (a) anthracene	Benzo (a) pyrene	Benzo (b) fluoranthene	Benzo (ghi) perylene	Benzo (k) fluoranthene	Beta-BHC	Beta-endosulfan	Bis (2-chloro- ethoxy) methane	Bis (2-chloro- ethyl) ether	Bis (2-chloro- isopropyl) ether	Bis (2-ethyl- hexyl) phthalate	BOD	Bromoform	Butyl benzyl phthalate	Carbazole	Carbon tetrachloride			
Aluminum Forming							X	X								X				X	X	X							X								
Battery Manufacturing																																					
Carbon Black Manufacturing																																					
Centralized Waste Treatment																													X					X			
Coil Coating																													X					X			
Copper Forming																X	X																				
Electrical and Electronic Components						X										X																	X		X	X	
Electroplating	X		X	X	X	X	X	X		X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
Feedlots																																					
Fertilizer Manufacturing															X																						
Glass Manufacturing																																					
Grain Mills																																		X			
Ink Formulating																																					
Inorganic Chemicals Manufacturing																																					
Iron and Steel Manufacturing															X																						
Leather Tanning and Finishing																																					
Metal Finishing	X		X		X	X	X	X		X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
Metal Molding and Casting				X		X	X	X								X	X		X	X	X		X										X		X	X	
Nonferrous Metals Form./Metal															X																						
Nonferrous Metals Manufacturing															X					X														X			
Oil and Gas																																					
Organic Chems., Plastics, and Syn.			X			X	X									X	X																X				
Paint Formulating																																					
Paving and Roofing Materials																																					X
Pesticide Chemicals																	X																	X			
Petroleum Refining															X																						
Pharmaceutical Manufacturing									X						X	X																				X	
Porcelain Enameling																																					
Pulp, Paper, and Paperboard		X																																			
Rubber Manufacturing																																					
Soap and Detergent Manufacturing																																					
Steam Electric Power Generating	X		X		X	X	X	X		X	X	X	X	X		X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		
Timber Products Processing																																					
Transportation Equip. Cleaning				X																															X		X
Waste Combustors																																					

	Chlordane (tech. mix. & metabolites)	Chlorobenzene	Chlorodibromo-methane	Chloroethane	Chloroform	Chrysene	COD	Cresol	Delta-BHC	Dibenzo (a,h) anthracene	Dichlorobromo-methane	Dieldrin	Diethyl phthalate	Diethylamine	Dimethyl phthalate	Di-n-butyl phthalate	Di-n-octyl phthalate	Endosulfan sulfate	Endrin	Endrin aldehyde	Ethyl acetate	Ethylbenzene	Flow Restrictions Only	Fluoranthene	Fluorene	Fluoride	Gamma-BHC	Heptachlor	Heptachlor epoxide	Hexachloro- benzene	Hexachloro- ethane	Hexachlorobuta- diene	Hexachlorocyclo pentadiene	Indeno (1,2,3- cd)pyrene						
Aluminum Forming						X				X			X			X		X	X	X		X		X	X											X				
Battery Manufacturing																																								
Carbon Black Manufacturing																																								
Centralized Waste Treatment								X																X																
Coil Coating					X											X										X														
Copper Forming					X																		X																	
Electrical and Electronic Components					X						X					X							X			X														
Electroplating		X	X	X	X	X			X	X	X	X	X		X	X	X	X	X	X		X		X	X		X	X	X	X	X	X	X	X	X	X	X			
Feedlots	X																							X																
Fertilizer Manufacturing																																								
Glass Manufacturing																										X														
Grain Mills																																								
Ink Formulating																								X																
Inorganic Chemicals Manufacturing								X																		X														
Iron and Steel Manufacturing																																								
Leather Tanning and Finishing																																								
Metal Finishing																																				X	X	X	X	X
Metal Molding and Casting		X	X	X	X	X			X	X	X	X	X		X	X	X	X	X	X		X		X	X		X	X	X											
Nonferrous Metals Form./Metal	X																									X														
Nonferrous Metals Manufacturing		X			X	X							X		X	X								X	X	X									X					
Oil and Gas																								X																
Organic Chems., Plastics, and Syn.																																			X	X		X		
Paint Formulating																								X																
Paving and Roofing Materials		X		X	X								X		X								X		X	X														
Pesticide Chemicals																																								
Petroleum Refining																																								
Pharmaceutical Manufacturing		X	X		X						X												X																	
Porcelain Enameling																																								
Pulp, Paper, and Paperboard		X			X									X									X																	
Rubber Manufacturing								X																																
Soap and Detergent Manufacturing					X																			X																
Steam Electric Power Generating																																			X	X	X	X	X	
Timber Products Processing																																								
Transportation Equip. Cleaning		X	X	X	X	X			X	X	X	X	X		X	X	X	X	X	X		X		X	X		X	X	X											
Waste Combustors	X																																							

	Isobutylaldehyde	Isophorone	Isopropyl acetate	Isopropyl ether	Methyl bromide	Methyl cellosolve	Methyl chloride	Methyl formate	Methyl Isobutyl Ketone	Methylene chloride	n-Amyl acetate	Naphthalene	n-Butyl acetate	n-Decane	n-Heptane	n-Hexane	Nitrate (as N)	Nitrobenzene	N-nitrosodi-methylamine	N-nitrosodi-phenylamine	N-nitrosodi-n-propylamine	n-Octadecane	Non-polar material (SGT-HEM)	Oil (mineral)	Oil and Grease	Organic Nitrogen (as N)	Parachloro- metacresol	PCB-1016	pH	Phenols	Phosphorus	Sulfide	TSS			
Aluminum Forming		X										X								X				X		X	X									
Battery Manufacturing																									X											
Carbon Black Manufacturing																									X											
Centralized Waste Treatment														X									X													
Coil Coating										X															X								X			
Copper Forming										X		X								X					X											
Electrical and Electronic Components		X								X		X														X										
Electroplating		X			X		X			X		X						X	X	X	X							X	X							
Feedlots																																				
Fertilizer Manufacturing																	X									X				X		X				
Glass Manufacturing																								X												
Grain Mills																																			X	
Ink Formulating																																				
Inorganic Chemicals Manufacturing																																	X			
Iron and Steel Manufacturing												X																					X			
Leather Tanning and Finishing																																X			X	
Metal Finishing		X			X		X			X		X						X	X	X	X							X	X							
Metal Molding and Casting										X		X													X			X				X				
Nonferrous Metals Form./Metal																			X	X	X															
Nonferrous Metals Manufacturing																																	X			
Oil and Gas																																				
Organic Chems., Plastics, and Syn.							X			X		X						X																		
Paint Formulating																																				
Paving and Roofing Materials																										X										
Pesticide Chemicals					X		X			X		X																								
Petroleum Refining																										X										
Pharmaceutical Manufacturing	X		X	X		X		X	X	X	X		X		X	X																				
Porcelain Enameling																																				
Pulp, Paper, and Paperboard																						X														
Rubber Manufacturing																									X											
Soap and Detergent Manufacturing																																				
Steam Electric Power Generating		X			X		X			X		X						X	X	X	X							X	X							
Timber Products Processing																										X										
Transportation Equip. Cleaning																																				
Waste Combustors																								X												X

Appendix D. Fact Sheet SOP and Checklist

Endnotes: IDAPA and CFR References