

Idaho Department of Environmental Quality
Reuse Permit
DMI-245-01

Table 1. Facility Information

| | |
|--------------------------------------|--|
| Facility Name | City of Kuna – Bernie Fisher Park Splash Pad |
| Facility location | Bernie Fisher Park near intersection of N. Linder Avenue and Swan Falls Road, Kuna, Idaho 83634, Ada County |
| Facility mailing address | 751 W. 4 th Street, Kuna, Idaho 83634 |
| Facility responsible official | Robert Withrow, City of Kuna Parks Director 208-922-5546 bwithrow@kunaid.gov Notify DEQ within 30 days if there is a change in personnel for the above facility contact. A minor permit modification will be issued by the Idaho Department of Environmental Quality (DEQ) to confirm the change. |

Table 2. Permit Limits and Conditions

| Parameter | Permit Conditions |
|---|---|
| Public Health Hazard or Nuisance Condition | Activities covered under this permit must not create a public health hazard or nuisance condition, as stated in the <i>Wastewater Rules</i> , IDAPA 58.01.16.600.03. |
| Groundwater | The activities covered under this permit shall not cause a violation of the <i>Ground Water Quality Rule</i> , IDAPA 58.01.11. |
| Surface Water | The activities covered under this permit shall not cause a violation of the water quality standards in the <i>Water Quality Standards</i> , IDAPA 58.01.02. |
| Entry and Access | The permittee shall allow DEQ entry and access to inspect the facility in accordance with the <i>Recycled Water Rules</i> , IDAPA 58.01.17.500.05. |
| Reporting | The permittee shall report changes, non-compliances and other relevant facts in accordance with the <i>Recycled Water Rules</i> , IDAPA 58.01.17.500.06. |
| Condition no. 1 | This permit covers reuse of water generated from the splash pad, disinfected, and discharged to the irrigation system. |
| Condition no. 2 | Application may occur only in the area identified in the permit application materials and shown in Figure 1. Sprinklers near Indian Creek shall be adjusted or relocated to not spray in Indian Creek as outlined in the Request for Wastewater Permit Waiver, dated April 26, 2017. The sprinklers shall be inspected as outlined in the April 26, 2017 request, or as amended and reported in the annual certification. |
| Condition no. 3 | The treatment system shall receive regular maintenance as described in the Operation Manuals submitted October 10, 2017, or as amended and approved by DEQ. |
| Condition no. 4 | A backflow prevention assembly shall be provided to protect Kuna Well #2 from the treated water, and shall be tested annually. Backflow prevention shall be provided to protect the treated water from the sanitary sewer. |
| Recordkeeping | An Annual Operational Summary documenting compliance with the limit(s) specified in conditions 1, 2, 3 and 4 shall be maintained on site, including any supporting documents used to demonstrate compliance. The Annual Operational Summary documents shall be maintained on site for a minimum of 5 years from the date of each annual certification. |

