

Septic Tank Manufacturer	Unit Liquid Volume (gallons)	Maximum Bury Depth (feet)	Tank Description (material, number of compartments, number of pieces, uses)	Approval Date (month/day/year)
<b>White Block Company, Inc.</b> 6219 East Trent Ave. Spokane Valley, WA 99212 (509) 543-0651	1,000, 1,250, 1,500	3	Concrete, single compartment, one piece	4/2/86
	2,000, 2,500	3	Concrete, single compartment, two piece	4/2/86
<b>Wilbert Precast, Inc.</b> 2215 East Brooklyn Spokane, WA 99217 (509) 325-4573	1,000	3	Concrete, two compartment <sup>a</sup> , one or two piece	9/23/14
	1,000 + 500	3	Concrete, two-compartment, one-piece, 1,000-gallon septic tank with integral 500-gallon dosing chamber only	6/12/13
	750, 1,000, 1,250, 1,500	3	Concrete, single compartment, one or two piece	2/6/81
	1,500	3	Concrete, one- or two-compartment, two-piece, 1,000-gallon septic tank with integral 500-gallon dosing chamber or 1,500-gallon septic tank	3/21/97
	2,000	3	Concrete, single compartment, two piece	9/19/13
	3,000	3	Concrete, single compartment, three piece	4/4/03
	5,215	8 or HS20	Concrete, single compartment, four piece, traffic rated	12/7/06
5,215	8 or HS20	Concrete, two-compartment, four-piece, traffic-rated, 3,475-gallon septic tank with integral 1,740-gallon dosing chamber or 5,215-gallon septic tank	8/15/13	
<b>Xerxes Corporation</b> 7901 Xerxes Ave. South Minneapolis, MN 55431	2,500, 3,400, 4,200, 5,000	7	FRP, single wall, one- or two-compartment, one piece	6/7/06

a. Indicates that the compartments are not hydraulically isolated and the second compartment is not a dosing chamber for use in individual subsurface sewage disposal system designs. Nonhydraulically isolated tanks may be used for septic tank effluent pump (STEP) stations as long as the STEP tank precedes a central secondary wastewater treatment system and is included in the approved plans and specifications for the collection system for use as an individual residence wastewater pumping station.

b. In a STEP pumping application, the tank’s nominal volume would be calculated from the inlet invert, which is 1086 and 1615, respectively because no gravity outlet would be installed.

Notes: Extended treatment package system (ETPS); polyethylene (PE); polypropylene (PP); high-density polyethylene (HDPE); fiberglass-reinforced plastic (FRP)