

DOCKET NO. 58-0108-0701 – REVISIONS TO PROPOSED RULE

100. MONITORING AND ANALYTICAL REQUIREMENTS.

01. Microbiological Contaminant Sampling and Analytical Requirements. (10-1-93)

e. A system must collect repeat samples within twenty-four (24) hours of notification of positive results as specified in 40 CFR 141.21(b) and Subsection 100.01. The Department may allow a system to delay collection of repeat samples if the system; (12-10-92)

iv. Follows public notification requirements specified under 40 CFR ~~Part 141.32, Subpart Q~~, revised as of July 1, 2004~~6~~, for **acute-Tier 1** MCL violations including notice for consumers to boil their water;~~(3-15-02)()~~