

Definitions

Module: A module shall consist of one (1) primary drain field, one (1) secondary drain field with a design flow equal to that of the primary drain field, and one (1) reserve area capable of handling the same design flow as the primary drain field. The primary drain field in any module may be designed for flows up to a maximum of ten thousand (10,000) gallons per day and the module shall not receive more than ten thousand (10,000) gallons per day.