

Septic Tank Manufacturer	Unit Liquid Volume (gallons)	Maximum Bury Depth (feet)	Tank Description (material, number of compartments, number of pieces, uses)	Approval Date (month/day/year)
White Block Company, Inc. 6219 East Trent Ave. Spokane Valley, WA 99212 (509) 543-0651	1,000, 1,250, 1,500	3	Concrete, single compartment, one piece	4/2/86
	2,000, 2,500	3	Concrete, single compartment, two piece	4/2/86
Wilbert Precast, Inc. 2215 East Brooklyn Spokane, WA 99217 (509) 325-4573	1,000	3	Concrete, two compartment*, one or two piece	9/23/14
	1,000 + 500	3	Concrete, two compartment, one piece, 1,000-gallon septic tank with integral 500-gallon dosing chamber only	6/12/13
	750, 1,000, 1,250, 1,500	3	Concrete, single compartment, one or two piece	2/6/81
	1,500	3	Concrete, one or two compartment, two piece, 1,000-gallon septic tank with integral 500-gallon dosing chamber or 1,500-gallon septic tank	3/21/97
	2,000	3	Concrete, single compartment, two piece	9/19/13
	3,000	3	Concrete, single compartment, three piece	4/4/03
	5,215	HS20	Concrete, single compartment, four piece, traffic rated	12/7/06
5,215	HS20	Concrete, two compartment, four piece, traffic rated, 3,475-gallon septic tank with integral 1,740-gallon dosing chamber or 5,215-gallon septic tank	8/15/13	
Xerxes Corporation 7901 Xerxes Ave. South Minneapolis, MN 55431	2,500, 3,400, 4,200, 5,000	7	FRP, single wall, single compartment, one piece	6/7/06

Notes: * - indicates that the compartments are not hydraulically isolated and the second compartment is not a dosing chamber; extended treatment package system (ETPS); polyethylene (PE); polypropylene (PP); high-density polyethylene (HDPE); fiberglass-reinforced plastic (FRP)