

RECEIVED

APR 30 1968

REPORT OF WELL DRILLER  
State of Idaho



Department of Reclamation that this report shall be filed with the State Reclamation Engineer within 30 days after completion or abandonment of the well.

WELL OWNER:

Name IDAHO WATER CO.  
Address COEUR D'ALENE IDAHO  
95-55-N-1-1

Owner's Permit No. G 25671  
NATURE OF WORK (check): Replacement well   
New well  Deepened  Abandoned

Water is to be used for: MUNICIPAL  
METHOD OF CONSTRUCTION: Rotary  Cable   
Dug  Other

(explain)  
CASING SCHEDULE: Threaded  Welded   
18"Diam. from 175 ft. to 190 ft.  
18"Diam. from 235 ft. to 260 ft.  
12"Diam. from 275 ft. to 280 ft.  
Thickness of casing: .375 Material:  
Steel  concrete  wood  other

(explain)  
PERFORATED? Yes  No  Type of perforator used: \_\_\_\_\_


Size of perforations: \_\_\_\_\_" by \_\_\_\_\_"  
\_\_\_\_\_perforations from \_\_\_\_\_ft. to \_\_\_\_\_ft.  
\_\_\_\_\_perforations from \_\_\_\_\_ft. to \_\_\_\_\_ft.  
\_\_\_\_\_perforations from \_\_\_\_\_ft. to \_\_\_\_\_ft.  
\_\_\_\_\_perforations from \_\_\_\_\_ft. to \_\_\_\_\_ft.

WAS SCREEN INSTALLED? Yes  No   
Manufacturer's name JOHNSON  
Type ARMCO IRON Model No. PIPE SIZE  
Diam. 18 Slot size 140 Set from 190 ft. to 200 ft.  
Diam. 18 Slot size 187 Set from 200 ft. to 217 ft.  
18" Slot 25 to 40 set 217 to 235  
12" Slot 28 to 40 set 260 to 275  
CONSTRUCTION: Well gravel packed? Yes   
No  size of gravel 3/4 to 1/2" Gravel placed from 176 ft. to 202 ft. Surface seal provided? Yes  No  To what depth? \_\_\_\_\_ft. Material used in seal: CEMENT

SEAL FROM 175 TO 176  
Did any strata contain unusable water? Yes   
No  Type of water: \_\_\_\_\_  
Depth of strata \_\_\_\_\_ft. Method of sealing strata off: \_\_\_\_\_

Surface casing used? Yes  No   
Cemented in place? Yes  No

Locate well in section



LOCATION OF WELL: County KOOTENAI  
NW 1/4 SW 1/4 Sec. 12 T. 50 N/S R. 4 E/W

Size of drilled hole: 20" Total depth of well: 295 Standing water level below ground: 167.1 Temp. Fahr. 54 Test delivery: 3900 gpm or \_\_\_\_\_cfs Pump?  Bail

Size of pump and motor used to make test: 12"x14" BOWLS WITH 450 H.P. ENGINES  
Length of time of test: 3 Hrs.      Min.  
Drawdown: 5.9 ft. Artesian pressure: ft. above land surface \_\_\_\_\_ Give flow \_\_\_\_\_cfs or \_\_\_\_\_gpm. Shutoff pressure: \_\_\_\_\_

Controlled by: Valve  Cap  Plug   
No control  Does well leak around casing? Yes  No

DEPTH FROM	DEPTH TO	MATERIAL	WATER YES OR NO
202	225	GRAVEL + SAND 1" MINUS	YES
225	235	SAND FINE	YES
235	260	SAND + CLAY FINE	NO
260	275	SAND FINE	YES
275	276	CLAY GREY	NO
276	284	SAND VERY FINE	NO
284	295	SANDY CLAY	NO

Work started: MARCH 20 1968  
Work finished: APRIL 22 1968  
Well Driller's Statement: This well was drilled under my supervision and this report is true to the best of my knowledge.  
Name: HOLMAN DRILLING CORP  
Address: E 3410 9TH SPOKANE WASH 99202  
Signed by: Arnold E Holman  
License No. 108 Date: APRIL 23-68

Use other side for additional remarks

USGS

copied