

\*Updates to these two tables will occur in sections 4.22 and 4.23 respectively.

**Table 4-16. Secondary biological treatment system hydraulic application rates.**

<b>Soil Design Subgroup</b>	<b>Application Rate (gallons/square foot/day)</b>
A-1	1.7
A-2a	1.2
<u>A-2b</u>	<u>1.0</u>
B-1	0.8
B-2	0.6
C-1	0.4
C-2	0.3

**Table 4-18. Secondary biological treatment system hydraulic application rates.**

<b>Soil Design Subgroup</b>	<b>Application Rate (gallons/square foot/day)</b>
A-1	1.7
A-2a	1.2
<u>A-2b</u>	<u>1.0</u>
B-1	0.8
B-2	0.6
C-1	0.4
C-2	0.3