

Revisions to Proposed Rule, Docket No. 58-0108-1501 (dated November 18, 2015)

Revisions to Subsections 100.01, 100.10, 300.05.d.iii(3), and 552.08.a. were made by the Board on November 18, 2015 before adoption of the pending rule. The revisions are highlighted. Only those portions of the rule containing revisions are included.

100. MONITORING AND ANALYTICAL REQUIREMENTS.

01. ~~Microbiological Contaminant~~ Total Coliform Sampling and Analytical Requirements. ~~The Total Coliform Rule, 40 CFR 141.21, is herein incorporated by reference and is effective until March 31, 2016. The Revised Total Coliform Rule, 40 CFR Part 141, Subpart Y, is herein incorporated by reference, excluding the annual monitoring provisions in 40 CFR 141.854 (a)(4), (d), (e), (f) and (h) and is effective April 1, 2016.~~

~~(10-1-93)()~~

(Break in Continuity)

10. Approved Laboratories. 40 CFR 141.28 ~~and beginning April 1, 2016, 40 CFR 141.852(b) is~~ are herein incorporated by reference. All analyses conducted pursuant to these rules, except those listed below, shall be performed in laboratories certified or granted reciprocity by the Idaho Department of Health and Welfare, Bureau of Laboratories, as provided in IDAPA 16.02.13, "Rules Governing Certification of Idaho Water Quality Laboratories." The following analyses may be performed by any person acceptable to the Department of Environmental Quality:

~~(4-4-13)()~~

(Break in Continuity)

300. FILTRATION AND DISINFECTION.

(Break in Continuity)

05. Analytical and Monitoring Requirements. 40 CFR 141.74 is herein incorporated by reference.

(4-4-13)

d. As provided for in 40 CFR 141.74(b), the Department may specify interim monitoring requirements for unfiltered systems notified by the Department or U.S. Environmental Protection Agency that filtration treatment must be installed. Until filtration is installed, systems shall conduct monitoring for turbidity and disinfectant residuals as follows unless otherwise specified by the Department:

~~(4-4-13)()~~

i. Disinfectant residual concentrations entering the distribution system shall be measured at the following minimum frequencies, and samples must be taken at evenly spaced intervals throughout the workday.

Minimum Frequencies	
Population	Samples/day
Less than 500	1
501 - 1000	2
1,001 - 2,500	3
Greater than 2501	4

(12-10-92)

ii. Turbidity shall be measured at least once per day at the entry point to the distribution system.

(12-10-92)

iii. The Department may, at its discretion, reduce the turbidity monitoring frequency for any noncommunity system which demonstrates to the satisfaction of the Department: (12-10-92)

(1) A free chlorine residual of two-tenths (0.2) part per million is maintained throughout the distribution system; (12-10-92)

(2) The water source is well protected; (12-10-92)

(3) ~~Through March 31, 2016, the~~ The total coliform MCL is not exceeded, ~~or after March 31, 2016, a Level 1 or Level 2 Assessment has not been triggered in accordance with 40 CFR 141.859; and~~ (12-10-92) ()

(Break in Continuity)

552. OPERATING CRITERIA FOR PUBLIC WATER SYSTEMS.

08. Start-up Procedures For Seasonal Systems Subject To Subsections 100.01.a., c., and d.

()

a. ~~Beginning April 1, 2016, a~~All seasonal system owners and operators must demonstrate completion of a Department approved start-up procedure, including start-up sampling, prior to serving water to the public. The system owner or operator must submit information on a Department provided or approved form that includes a statement certifying that the system owner or operator followed proper start-up procedures. The form shall be submitted to the Department within 30 (thirty) days following the system's start-up date. ()