

5.6 Individual Wastewater Incinerator

Revision: May 18, 2016

Table 5-6 shows individual wastewater incinerators currently approved by DEQ.

Table 5-6. Individual wastewater incinerators approved by DEQ.

Incinerating Toilets	Model	Notes	Requirements	Approval Date
SWSLOO, Inc. 2005 FM 1704 Elgin, TX 78621-5522 Phone: (866) 797-3566 (ELOO) E-mail: info@swsloo.com Website: www.swsloo.com	THE ENVIRO LOO® 2010 Standard			
	THE ENVIRO LOO® 2040 Standard	Solar and Wind Evaporative Toilet	N/A	2010
ECOJOHN 17282 Mount Wynne Circle Fountain Valley, CA 92708 714-658-1077 1-866-ECOJOHN	ECOJOHN SR	Gas-fired	N/A	2007
	WC5 Mini	Propane or gas-fired	Toilets only	2016
	WC5	Propane, gas, or diesel-fired	25 GPD max, minimum 600 gallon storage tank	2016
	WC32	Propane, gas, or diesel-fired	75 GPD max, minimum 800 gallon storage tank	2016
	WC48	Propane, gas, or diesel-fired	125 GPD max, minimum 1,000 gallon storage tank	2016
	WC64	Propane, gas, or diesel-fired	300 GPD max, minimum 1,000 gallon storage tank	2016

Research Products/Blankenship Incinolet (800) 527-5551	CF (120v) TR (208v, 240v) RV (120v) WB (120v 208v, 240v)	120 V or 240 V Marine	— —	2001 2001
Storburn (519) 442-4731	60K	Gas-fired	—	1993

Notes: not applicable (N/A); gallons per day (GPD)