



STATE OF IDAHO  
DEPARTMENT OF  
ENVIRONMENTAL QUALITY

1410 North Hilton • Boise, Idaho 83706 • (208) 373-0502  
www.deq.idaho.gov

C.L. "Butch" Otter, Governor  
John H. Tippetts, Director

October 25, 2017

Shawn Dolan  
Manager of Engineering  
Kootenai Electric Cooperative – Fighting Creek Landfill  
2451 W. Dakota Ave.  
Hayden, ID 83835

RE: Facility ID No. 055-00091, Kootenai Electric Cooperative – Fighting Creek, Coeur d'Alene  
Final Tier I Operating Permit Letter

Dear Mr. Dolan:

The Department of Environmental Quality (DEQ) is issuing Tier I Operating Permit No. T1-2017.0027 to Kootenai Electric Cooperative – Fighting Creek at Coeur d'Alene in accordance with IDAPA 58.01.01.300 through 386, Rules for the Control of Air Pollution in Idaho (Rules).

The enclosed permit is effective immediately, summarizes the applicable requirements for your facility, and requires an annual compliance certification for all emissions units. This permit replaces Tier I Operating Permit No. T1-2012.0044, issued December 12, 2012. The enclosed operating permit is based on the information contained in your permit application received on May 8, 2017. Modifications to and/or renewal of this operating permit shall be requested in a timely manner in accordance with the Rules.

In order to fully understand the compliance requirements of this permit, DEQ highly recommends that you schedule a meeting with Almer Casile, Air Quality Analyst, at 208-666-4600 to review and discuss the terms and conditions of this permit. Should you choose to schedule this meeting, DEQ recommends the following representatives attend the meeting: your facility's plant manager, responsible official, environmental contact, and any other staff responsible for day-to-day compliance with permit conditions.

Pursuant to IDAPA 58.01.23, you, as well as any other entity, may have the right to appeal this final agency action within 35 days of the date of this decision. However, prior to filing a petition for a contested case, I encourage you to call Rakael Pope at 208-373-0502 or [rakael.pope@deq.idaho.gov](mailto:rakael.pope@deq.idaho.gov) to address any questions or concerns you may have with the enclosed permit.

Sincerely,

A handwritten signature in black ink that reads "Mike Simon".

Mike Simon  
Stationary Source Program Manager  
Air Quality Division

MS/RP Permit No. T1-2017.0027 PROJ 61885

Enclosures

## Air Quality

### TIER I OPERATING PERMIT

---

**Permittee** Kootenai Electric Cooperative – Fighting Creek  
**Permit Number** T1-2017.0027  
**Project ID** 61885  
**Facility ID** 055-00091  
**Facility Location** 22089 South Highway 95  
Coeur d’Alene, ID 83814

### Permit Authority

This permit (a) is issued according to the “Rules for the Control of Air Pollution in Idaho” (Rules) (IDAPA 58.01.01.300–386) (b) incorporates all applicable terms and conditions of prior air quality permits issued by the Idaho Department of Environmental Quality (DEQ) for the permitted source, unless the permittee emits toxic pollutants subject to state-only requirements pursuant to IDAPA 58.01.01.210 and the permittee elects not to incorporate those terms and conditions into this operating permit.


The permittee shall comply with the terms and conditions of this permit. The effective date of this permit is the date of signature by DEQ on this cover page.

**Date Issued** October 25, 2017

**Date Expires** October 25, 2022

  
Rakaël Pope, Permit Writer

  
Mike Simon, Stationary Source Manager



## Contents

1	Acronyms, Units, and Chemical Nomenclature .....	3
2	Permit Scope .....	5
3	Facility-Wide Conditions.....	6
4	Internal Combustion Engines .....	14
5	General Provisions.....	20

# 1 Acronyms, Units, and Chemical Nomenclature

ASTM	American Society for Testing and Materials
Btu	British thermal unit
CAA	Clean Air Act
CAM	Compliance Assurance Monitoring
CFR	Code of Federal Regulations
CI	compression ignition
CMS	continuous monitoring systems
CO	carbon monoxide
CO <sub>2</sub>	carbon dioxide
CO <sub>2</sub> e	CO <sub>2</sub> equivalent emissions
COMS	continuous opacity monitoring systems
DEQ	Idaho Department of Environmental Quality
EPA	United States Environmental Protection Agency
GHG	greenhouse gases
HAP	hazardous air pollutants
hp	horsepower
hr/yr	hours per consecutive 12-calendar-month period
ICE	internal combustion engines
IDAPA	a numbering designation for all administrative rules in Idaho promulgated in accordance with the Idaho Administrative Procedures Act
lb/hr	pounds per hour
MACT	Maximum Achievable Control Technology
MMBtu	million British thermal units
MMscf	million standard cubic feet
MRRR	Monitoring, Recordkeeping and Reporting Requirements
NESHAP	National Emission Standards for Hazardous Air Pollutants
NO <sub>2</sub>	nitrogen dioxide
NO <sub>x</sub>	nitrogen oxides
NSPS	New Source Performance Standards
O&M	operation and maintenance
O <sub>2</sub>	oxygen
PC	permit condition
PM	particulate matter
PM <sub>2.5</sub>	particulate matter with an aerodynamic diameter less than or equal to a nominal 2.5 micrometers
PM <sub>10</sub>	particulate matter with an aerodynamic diameter less than or equal to a nominal 10 micrometers
ppm	parts per million
ppmvd	parts per million by volume, dry basis
ppmw	parts per million by weight
PSD	Prevention of Significant Deterioration
PTC	permit to construct
PTE	potential to emit
RICE	reciprocating internal combustion engines
Rules	Rules for the Control of Air Pollution in Idaho
scf	standard cubic feet
SIP	State Implementation Plan
SO <sub>2</sub>	sulfur dioxide

SO <sub>x</sub>	sulfur oxides
T/day	tons per calendar day
T/hr	tons per hour
T/yr	tons per consecutive 12 calendar-month period
T1	Tier I operating permit
T2	Tier II operating permit
U.S.C.	United States Code
VOC	volatile organic compound

## 2 Permit Scope

### Purpose

- 2.1 This Tier I operating permit establishes facility-wide requirements in accordance with the Idaho State Implementation Plan control strategy and the Rules.
- 2.2 This Tier I operating permit incorporates the following permit(s):
- Permit to Construct No. P-2010.0139, Project 60607 issued February 1, 2011.
- 2.3 This Tier I operating permit replaces the following permit(s):
- Tier I Operating Permit No. T1-2012.0044 issued December 12, 2012.

### Regulated Sources

Table 2.1 lists all sources of regulated emissions in this permit.

**Table 2.1 Regulated Sources**

Permit Section	Source	Control Equipment
4	<u>Internal Combustion Engines (2)</u> Manufacturer: Caterpillar Model: G3520C, spark ignition, 4 stroke lean burn design Allowable fuel type: landfill gas Manufactured: 2011	None

### 3 Facility-Wide Conditions

Table 3.1 contains a summary of requirements that apply generally to emissions units at the facility.

**Table 3.1 Applicable Requirements Summary**

Permit Conditions	Parameter	Limit / Standard Summary	Applicable Requirements Reference	Monitoring, Recordkeeping, and Reporting Requirements
3.1–3.4	Fugitive Dust	Reasonable control	IDAPA 58.01.01.650–651	3.2–3.4, 3.20, 3.25
3.5–3.6	Odors	Reasonable control	IDAPA 58.01.01.775–776	3.6, 3.20, 3.25
3.7–3.9	Visible Emissions	20% opacity for no more than 3 minutes in any 60-minute period	IDAPA 58.01.01.625	3.8, 3.9, 3.24, 3.25
3.10–3.14	Excess Emissions	Compliance with IDAPA 58.01.01.130-136	IDAPA 58.01.01.130–136	3.10–3.14, 3.20, 3.25
3.15	Open Burning	Compliance with IDAPA 58.01.01.600-623	IDAPA 58.01.01.600–623	3.18, 3.20, 3.25
3.16	Asbestos	Compliance with 40 CFR 61, Subpart M	40 CFR 61, Subpart M	3.19, 3.20, 3.25
3.17	Accidental Release Prevention	Compliance with 40 CFR 68	40 CFR 68	3.20, 3.25
3.18	Recycling and Emissions Reductions	Compliance with 40 CFR 82, Subpart F	40 CFR 82, Subpart F	3.20, 3.21, 3.25
3.19	NSPS/NESHA P General Provisions	Compliance with 40 CFR 60, Subpart A	IDAPA 58.01.01.107.03	3.22, 3.23, 3.20, 3.25
3.20	Monitoring and Recordkeeping	Maintenance of required records	IDAPA 58.01.01.322.06	3.20, 3.25
3.21–3.24	Testing	Compliance testing	IDAPA 58.01.01.157	3.21 – 3.24, 3.20, 3.25
3.25	Reports and Certifications	Submittal of required reports, notifications, and certifications	IDAPA 58.01.01.322.08	3.25
3.26	Incorporation of Federal Requirements by Reference	Compliance with applicable federal requirements referenced	IDAPA 58.01.01.107	3.26

#### Fugitive Dust

**3.1** All reasonable precautions shall be taken to prevent particulate matter (PM) from becoming airborne in accordance with IDAPA 58.01.01.650–651.

[IDAPA 58.01.01.650–651, 4/11/15]

**3.2** The permittee shall monitor and maintain records of the frequency and the method(s) used (e.g., water, chemical dust suppressants) to reasonably control fugitive emissions.

[IDAPA 58.01.01.322.06, 07, 5/1/94]

- 3.3 The permittee shall maintain records of all fugitive dust complaints received. The permittee shall take appropriate corrective action as expeditiously as practicable after receiving of a valid complaint. The records shall include, at a minimum, the date that each complaint was received and a description of the following: the complaint, the permittee's assessment of the validity of the complaint, any corrective action taken, and the date the corrective action was taken.

[IDAPA 58.01.01.322.06, 07, 5/1/94]

- 3.4 The permittee shall conduct a quarterly facility-wide inspection of potential sources of fugitive emissions during daylight hours and under normal operating conditions to ensure that the methods used to reasonably control fugitive emissions are effective. If fugitive emissions are not being reasonably controlled, the permittee shall take corrective action as expeditiously as practicable. The permittee shall maintain records of the results of each fugitive emissions inspection. The records shall include, at a minimum, the date of each inspection and a description of the following: the permittee's assessment of the conditions existing at the time fugitive emissions were present (if observed), any corrective action taken in response to the fugitive emissions, and the date the corrective action was taken.

[IDAPA 58.01.01.322.06, 07, 5/1/94]

### Odors

- 3.5 The permittee shall not allow, suffer, cause, or permit the emission of odorous gases, liquids, or solids to the atmosphere in such quantities as to cause air pollution.

[IDAPA 58.01.01.775-776 (state only), 5/1/94]

- 3.6 The permittee shall maintain records of all odor complaints received. If the complaint has merit, the permittee shall take appropriate corrective action as expeditiously as practicable. The records shall include, at a minimum, the date that each complaint was received and a description of the following: the complaint, the permittee's assessment of the validity of the complaint, any corrective action taken, and the date the corrective action was taken.

[IDAPA 58.01.01.322.06, 07 (state only), 5/1/94]

### Visible Emissions

- 3.7 The permittee shall not discharge any air pollutant to the atmosphere from any point of emission for a period or periods aggregating more than three minutes in any 60-minute period which is greater than 20% opacity as determined by procedures contained in IDAPA 58.01.01.625. These provisions shall not apply when the presence of uncombined water, NO<sub>x</sub>, and/or chlorine gas is the only reason for the failure of the emission to comply with the requirements of this section.

[IDAPA 58.01.01.625, 4/5/00]

- 3.8 The permittee shall conduct a quarterly facility-wide inspection of potential sources of visible emissions, during daylight hours and under normal operating conditions. Sources that are monitored using a continuous opacity monitoring system (COMS) are not required to comply with this permit condition. The inspection shall consist of a see/no see evaluation for each potential source of visible emissions. If any visible emissions are present from any point of emission, the permittee shall either:

- a) Take appropriate corrective action as expeditiously as practicable to eliminate the visible emissions. Within 24 hours of the initial see/no see evaluation and after the corrective action, the permittee shall conduct a see/no see evaluation of the emissions point in question. If the visible emissions are not eliminated, the permittee shall comply with b).

or

- b) Perform a Method 9 opacity test in accordance with the procedures outlined in IDAPA 58.01.01.625. A minimum of 30 observations shall be recorded when conducting the opacity test. If opacity is greater than 20%, as measured using Method 9, for a period or periods aggregating more than three minutes in any 60-minute period, the permittee shall take all necessary corrective actions and report the period or periods as an excess emission in the annual compliance certification and in accordance with IDAPA 58.01.01.130–136.

[IDAPA 58.01.01.322.06, 5/1/94]

- 3.9 The permittee shall maintain records of the results of each visible emission inspection and each opacity test when conducted. The records shall include, at a minimum, the date and results of each inspection and test and a description of the following: the permittee's assessment of the conditions existing at the time visible emissions are present (if observed), any corrective action taken in response to the visible emissions, and the date corrective action was taken.

[IDAPA 58.01.01.322.07, 5/1/94]

## **Excess Emissions**

### *Excess Emissions—General*

- 3.10 The permittee shall comply with the procedures and requirements of IDAPA 58.01.01.130–136 for excess emissions. The provisions of IDAPA 58.01.01.130–136 shall govern in the event of conflicts between the excess emissions facility wide conditions (Permit Conditions 3.10 through 3.14) and the regulations of IDAPA 58.01.01.130–136.

During an excess emissions event, the permittee shall, with all practicable speed, initiate and complete appropriate and reasonable action to correct the conditions causing the excess emissions event; to reduce the frequency of occurrence of such events; to minimize the amount by which the emission standard is exceeded; and shall, as provided below or upon request of DEQ, submit a full report of such occurrence, including a statement of all known causes, and of the scheduling and nature of the actions to be taken.

[IDAPA 58.01.01.132, 4/5/00]

### *Excess Emissions—Startup, Shutdown, and Scheduled Maintenance*

- 3.11 In all cases where startup, shutdown, or scheduled maintenance of any equipment or emission unit is expected to result or results in an excess emissions event, the permittee shall demonstrate compliance with IDAPA 58.01.01.133.01(a) through (d), including, but not limited to, the following:
- Prohibiting any scheduled startup, shutdown, or maintenance resulting in excess emissions shall occur during any period in which an Atmospheric Stagnation Advisory or a Wood Stove Curtailed Advisory has been declared by DEQ.
  - Notifying DEQ of the excess emissions event as soon as reasonably possible, but no later than two hours prior to, the start of the event, unless the permittee demonstrates to DEQ's satisfaction that a shorter advance notice was necessary.
  - Reporting and recording the information required pursuant to the excess emissions reporting and recordkeeping requirements (Permit Conditions 3.14 and 3.15) and IDAPA 58.01.01.135 and 136 for each excess emissions event due to startup, shutdown, or scheduled maintenance.

[IDAPA 58.01.01.133, 4/11/06]

***Excess Emissions—Upset, Breakdown, or Safety Measures***

**3.12** In all cases where upset or breakdown of equipment or an emissions unit, or the initiation of safety measures, results or may result in an excess emissions event, the permittee shall demonstrate compliance with IDAPA 58.01.01.134.01(a) and (b) and the following:

- Immediately undertake all appropriate measures to reduce and, to the extent possible, eliminate excess emissions resulting from the event and to minimize the impact of such excess emissions on the ambient air quality and public health.
- Notify DEQ of any upset, breakdown, or safety event that results in excess emissions. Such notification shall identify the time, specific location, equipment or emissions unit involved, and (to the extent known) the cause(s) of the occurrence. The notification shall be given as soon as reasonably possible, but no later than 24 hours after the event, unless the permittee demonstrates to DEQ's satisfaction that the longer reporting period was necessary.
- Report and record the information required pursuant to the excess emissions reporting and recordkeeping facility wide conditions (Permit Conditions 3.14 and 3.15) and IDAPA 58.01.01.135 and 136 for each excess emissions event caused by an upset, breakdown, or safety measure.
- During any period of excess emissions caused by upset, breakdown, or operation under facility safety measures, DEQ may require the permittee to immediately reduce or cease operation of the equipment or emissions unit causing the period until such time as the condition causing the excess has been corrected or brought under control. Such action by DEQ shall be taken upon consideration of the factors listed in IDAPA 58.01.01.134.03 and after consultation with the permittee.

[IDAPA 58.01.01.134, 4/11/06]

***Excess Emissions—Reporting and Recordkeeping***

**3.13** The permittee shall submit a written report to DEQ for each excess emissions event, no later than 15 days after the beginning of such an event. Each report shall contain the information specified in IDAPA 58.01.01.135.02.

[IDAPA 58.01.01.135, 4/11/06]

**3.14** The permittee shall maintain excess emissions records at the facility for the most recent five calendar-year period. The excess emissions records shall be made available to DEQ upon request and shall include the information requested by IDAPA 58.01.01.136.03(a) and (b) as summarized in the following:

- An excess emissions log book for each emissions unit or piece of equipment containing copies of all reports that have been submitted to DEQ pursuant to IDAPA 58.01.01.135 for the particular emissions unit or equipment; and
- Copies of all startup, shutdown, and scheduled maintenance procedures and upset, breakdown, or safety preventative maintenance plans that have been developed by the permittee in accordance with IDAPA 58.01.01.133 and 134, and facility records as necessary to demonstrate compliance with such procedures and plans.

[IDAPA 58.01.01.136, 4/5/00]

**Open Burning**

**3.15** The permittee shall comply with the “Rules for Control of Open Burning” (IDAPA 58.01.01.600–623).

[IDAPA 58.01.01.600–623, 5/08/09]

## **Asbestos**

### **3.16 NESHAP 40 CFR 61, Subpart M—National Emission Standard for Asbestos**

The permittee shall comply with all applicable portions of 40 CFR 61, Subpart M—“National Emission Standard for Asbestos.”

[40 CFR 61, Subpart M]

## **Accidental Release Prevention**

**3.17** A permittee of a stationary source that has more than a threshold quantity of a regulated substance in a process, as determined under 40 CFR 68.115, shall comply with the requirements of the “Chemical Accident Prevention Provisions” at 40 CFR 68 no later than the latest of the following dates:

- Three years after the date on which a regulated substance is present above a threshold quantity is first listed under 40 CFR 68.130.
- The date on which a regulated substance is first present above a threshold quantity in a process

[40 CFR 68.10(a)]

## **Recycling and Emissions Reductions**

### **3.18 40 CFR Part 82 - Protection of Stratospheric Ozone**

The permittee shall comply with applicable standards for recycling and emissions reduction of refrigerants and their substitutes pursuant to 40 CFR 82, Subpart F, “Recycling and Emissions Reduction.”

[40 CFR 82, Subpart F]

## **NSPS/NESHAP General Provisions**

### **3.19 NSPS 40 CFR 60, Subpart A - General Provisions**

The permittee shall comply with the applicable requirements of 40 CFR 60, Subpart A—“General Provisions”—in accordance with 40 CFR 60.1. A summary of requirements for affected facilities is provided in Table 3.2.

**Table 3.2. NSPS 40 CFR 60, Subpart A—General Provisions**

Section	Subject	Summary of Section Requirements
60.4	Address	<ul style="list-style-type: none"> <li>• <u>All requests, reports, applications, submittals, and other communications associated with 40 CFR 60, Subpart JJJ shall be submitted to:</u> Coeur d’Alene Regional Office Department of Environmental Quality 2110 Ironwood Parkway Coeur d’Alene, ID 83814</li> </ul>
60.7(a),(b), and (f)	Notification and Recordkeeping	<ul style="list-style-type: none"> <li>• Notification shall be furnished of commencement of construction postmarked no later than 30 days of such date.</li> <li>• Notification shall be furnished of initial startup postmarked within 15 days of such date.</li> <li>• Notification shall be furnished of any physical or operational change that may increase emissions postmarked 60 days before the change is made.</li> <li>• Records shall be maintained of the occurrence and duration of any startup, shutdown or malfunction; any malfunction of the air pollution control equipment; or any periods during which a CMS or monitoring device is inoperative.</li> <li>• Records shall be maintained, in a permanent form suitable for inspection, of all measurements, performance testing measurements, calibration checks, adjustments and maintenance performed, and other required information. Records shall be maintained for a period of two years following the date of such measurements, maintenance, reports, and records.</li> </ul>
60.8	Performance Tests	<ul style="list-style-type: none"> <li>• At least 30 days prior notice of any performance test shall be provided to afford the opportunity to have an observer to be present.</li> <li>• Within 60 days of achieving the maximum production rate, but not later 180 days after initial startup, performance test(s) shall be conducted and a written report of the results of such test(s) furnished.</li> <li>• Performance testing facilities shall be provided as follows: Sampling ports adequate for test methods applicable to such facility. Safe sampling platform(s). Safe access to sampling platform(s). Utilities for sampling and testing equipment.</li> <li>• Performance tests shall be conducted and data reduced in accordance with 40 CFR 60.8(b), (c), and (f).</li> </ul>
60.11(a),(c), (d), (f), and (g)	Compliance With Standards and Maintenance Requirements	<ul style="list-style-type: none"> <li>• When performance tests are required, compliance with standards is determined by methods and procedures established by 40 CFR 60.8.</li> <li>• At all times, including periods of startup, shutdown, and malfunction, the owners and operators shall, to the extent practicable, maintain and operate any affected facility including associated air pollution control equipment in a manner consistent with good air pollution control practice for minimizing emissions.</li> <li>• For the purpose of submitting compliance certifications or establishing whether or not a person has violated or is in violation of any standard, nothing shall preclude the use, including the exclusive use, of any credible evidence or information, relevant to whether a source would have been in compliance with applicable requirements if the appropriate performance or compliance test or procedure had been performed.</li> <li>• The opacity standards shall apply at all times except during periods of startup, shutdown, malfunction, and as otherwise provided.</li> </ul>
60.12	Circumvention	<ul style="list-style-type: none"> <li>• No permittee shall build, erect, install, or use any article, machine, equipment or process, the use of which conceals an emission which would otherwise constitute a violation of an applicable standard.</li> </ul>
60.14	Modification	<ul style="list-style-type: none"> <li>• A physical or operational change which results in an increase in the emission rate to the atmosphere or any pollutant to which a standard applies shall be considered a modification, and upon modification an existing facility shall become an affected facility in accordance with the requirements and exemptions in 40 CFR 60.14.</li> <li>• Within 180 days of the completion of any physical or operational change, compliance with all applicable standards must be achieved.</li> </ul>
60.15	Reconstruction	<ul style="list-style-type: none"> <li>• An existing facility, upon reconstruction, becomes an affected facility, irrespective of any change in emission rate in accordance with the requirements of 40 CFR 60.15.</li> </ul>

[40 CFR 60, Subpart A]

## Monitoring and Recordkeeping

**3.20** The permittee shall maintain sufficient records to ensure compliance with all of the terms and conditions of this operating permit. Monitoring records shall include, but not be limited to, the following: (a) the date, place, and times of sampling or measurements; (b) the date analyses were performed; (c) the company or entity that performed the analyses; (d) the analytical techniques or methods used; (e) the results of such analyses; and (f) the operating conditions existing at the time of sampling or measurement. All monitoring records and support information shall be retained for a period of at least five years from the date of the monitoring sample, measurement, report, or application. Supporting information includes, but is not limited to, all calibration and maintenance records, all original strip-chart recordings for continuous monitoring instrumentation, and copies of all reports required by this permit. All records required to be maintained by this permit shall be made available in either hard copy or electronic format to DEQ representatives upon request.

[IDAPA 58.01.01.322.06, 07, 5/1/94]

## Performance Testing

**3.21** If performance testing is required, the permittee shall provide notice of intent to test to DEQ at least 15 days prior to the scheduled test or shorter time period as provided in a permit, order, consent decree, or by DEQ approval. DEQ may, at its option, have an observer present at any emissions tests conducted on a source. DEQ requests such testing not be performed on weekends or state holidays.

**3.22** All testing shall be conducted in accordance with the procedures in IDAPA 58.01.01.157. Without prior DEQ approval, any alternative testing is conducted solely at the permittee's risk. If the permittee fails to obtain prior written approval by DEQ for any testing deviations, DEQ may determine that the testing does not satisfy the testing requirements. Therefore, prior to conducting any performance test, the permittee is encouraged to submit in writing to DEQ, at least 30 days in advance, the following for approval:

- The type of method to be used
- Any extenuating or unusual circumstances regarding the proposed test
- The proposed schedule for conducting and reporting the test

[IDAPA 58.01.01.157, 4/11/15; IDAPA 58.01.01.322.06, 08.a, 09, 4/5/00]

**3.23** Within 60 days following the date in which a performance test required by this permit is concluded, the permittee shall submit to DEQ a performance test report. The report shall include a description of the process, identification of the test method(s) used, equipment used, all process operating data collected during the test period, and test results, as well as raw test data and associated documentation, including any approved test protocol.

**3.24** The proposed test date(s), test date rescheduling notice(s), compliance test report, and all other correspondence shall be sent to the DEQ address specified in the "Reports and Certifications" facility wide condition.

[IDAPA 58.01.01.157, 4/11/15; IDAPA 58.01.01.322.06, 08.a, 09, 4/5/00]

## Reports and Certifications

3.25 Any reporting required by this permit, including but not limited to, records, monitoring data, supporting information, requests for confidential treatment, notifications of intent to test, testing reports, or compliance certifications, shall contain a certification by a responsible official. The certification shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document(s) are true, accurate, and complete. All periodic reports and certifications required by this permit shall be submitted to DEQ within 45 days of the end of each specified reporting period. Any reporting required by this permit shall be submitted to the following address:

Air Quality Permit Compliance  
Department of Environmental Quality  
Coeur d'Alene Regional Office  
2110 Ironwood Parkway  
Coeur d'Alene, ID 83814  
Telephone: (208) 769-1422  
Fax: (208) 769-1404

The periodic compliance certification required in the general provisions (General Provision 5.22) shall also be submitted within 45 days of the end of the specified reporting period to:

Part 70 Operating Permit Program  
U.S. EPA Region 10, Mail Stop: OAW-150  
1200 Sixth Ave., Suite 900  
Seattle, WA 98101

[IDAPA 58.01.01.322.08, 11, 4/5/00]

## Incorporation of Federal Requirements by Reference

3.26 Unless expressly provided otherwise, any reference in this permit to any document identified in IDAPA 58.01.01.107.03 shall constitute the full incorporation into this permit of that document for the purposes of the reference, including any notes and appendices therein. Documents include, but are not limited to:

- Applicable requirements of Standards of Performance for New Stationary Sources (NSPS), 40 CFR Part 60
- Applicable requirements of National Emission Standards for Hazardous Air Pollutants (NESHAP), 40 CFR Part 63

For permit conditions referencing or cited in accordance with any document incorporated by reference (including permit conditions identified as NSPS or NESHAP), should there be any conflict between the requirements of the permit condition and the requirements of the document, the requirements of the document shall govern, including any amendments to that regulation.

[IDAPA 58.01.01.107, 3/29/17]

## 4 Internal Combustion Engines

### Summary Description

Kootenai Electric Cooperative operates a landfill gas-to-energy facility utilizing landfill gas from the Fighting Creek Landfill as fuel for two engines to drive two 1.6 megawatt (MW) generators. Each engine operates at 2,233 brake horsepower (bhp) at 100% load.

Table 4.1 describes the devices used to control emissions from the internal combustion engines.

**Table 4.1 Internal Combustion Engines Description**

Emissions Units / Processes	Control Devices
Engine #1 – Caterpillar G3520C	None
Engine #2 – Caterpillar G3520C	None

Table 4.2 contains a summary of the requirements that apply to the internal combustion engines. Specific permit requirements are listed below.

**Table 4.2 Applicable Requirements Summary**

Permit Conditions	Parameter	Limit / Standard Summary	Applicable Requirements Reference	Operating, Monitoring, and Recordkeeping Requirements
4.1	Emission Limits	Emissions limits listed in Table 4.3	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.2	Visible Emissions	20% opacity for no more than three minutes in any 60-minute period	IDAPA 58.01.01.625, P-2010.0139 PROJ 60607	3.8 – 3.9
4.3	Odors	Reasonable control	IDAPA 58.01.01.776, P-2010.0139 PROJ 60607	3.5 – 3.6, 4.9
4.4	Engine Operation	Manufacturer's recommendations	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.5	Maintenance Plan	Maintenance plan and minimize emissions	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.6	Operation & Maintenance	Emission limits	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.7	AFR Controller Maintenance & Operation	Minimize emissions	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.8	Allowable Fuel	Landfill gas	P-2010.0139 PROJ 60607	No specific requirements beyond generally applicable facility-wide and general requirements
4.11	Performance Test Schedule	Initial performance test and subsequent test every 8,760 hours or 3 years	40 CFR 60 Subpart JJJJ, P-2010.0139 PROJ 60607	4.10, 4.13 – 4.16
4.12	Performance Test Procedures	Performance test requirements	40 CFR 60 Subpart JJJJ, P-2010.0139	4.10, 4.13 – 4.16

## Emission Limits

### 4.1 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – Emission Limits

In accordance with 40 CFR 60.4233(e), the permittee shall comply with the emission standards in Table 1 of this subpart for both spark ignition SI engines. The table below summarizes the emission standards required for the two engines.

**Table 4.3 NO<sub>x</sub>, CO, and VOC Emission Standards for Stationary Non-Emergency SI Engines ≥ 100 hp**

Engine type and fuel	Maximum Engine Power	Manufacture Date	Emission Standards <sup>(a)</sup>					
			g/hp-hr			ppmvd @ 15% O <sub>2</sub>		
			NO <sub>x</sub>	CO	VOC <sup>(b)</sup>	NO <sub>x</sub>	CO	VOC <sup>(b)</sup>
Landfill Gas	hp ≥ 500	7/1/2010	2.0	5.0	1.0	150	610	80

a) Owners and operators of stationary non-certified SI engines may choose to comply with emission standards in units of either g/hp-hr or ppmvd @ 15% O<sub>2</sub>.

b) For the purposes 40 CFR 60, Subpart JJJJ, when calculating emissions of volatile organic compounds, emissions of formaldehyde should not be included.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4233(e)]

### 4.2 Opacity Limit

Emissions from the engine stacks, or any other stack, vent, or functionally equivalent opening associated with the engines, shall not exceed 20% opacity for a period or periods aggregating more than three minutes in any 60-minute period as required by IDAPA 58.01.01.625. Opacity shall be determined by the procedures contained in IDAPA 58.01.01.625.

[PTC No. P-2010.0139, 2/1/11; IDAPA 58.01.01.625, 4/5/00]

### 4.3 Odors

The permittee shall not allow, suffer, cause, or permit the emission of odorous gasses, liquids, or solids to the atmosphere in such quantities as to cause air pollution in accordance with IDAPA 58.01.01.776.01.

[PTC No. P-2010.0139, 2/1/11; IDAPA 58.01.01.776, 5/1/94]

## Operating Requirements

4.4 The permittee shall operate and maintain the engines in a manner consistent with the manufacturer's recommendations.

[PTC No. P-2010.0139, 2/1/11]

4.5 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – Maintenance Plan

In accordance with 40 CFR 60.4243(b)(2)(ii), the permittee shall keep a maintenance plan and must, to the extent practicable, maintain and operate the engines in the manner consistent with good air pollution control practice for minimizing emissions.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4243(b)(2)(ii)]

4.6 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – Life Operation & Maintenance

In accordance with 40 CFR 60.4234, the permittee shall operate and maintain stationary SI engines that achieve the emission standards as required in 60.4233(e) over the entire life of each SI engine.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4234]

**4.7 NSPS 40 CFR 60, Subpart JJJJ - Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – AFR Controller Maintenance and Operation**

In accordance with 40 CFR 60.4243(g), the permittee shall maintain and operate the AFR controller on each engine in order to ensure proper operation of the engine and control device to minimize emissions at all times.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4243(g)]

**4.8 Allowable Fuel**

All engines shall burn only landfill gas.

[PTC No. P-2010.0139, 2/1/11]

## **Monitoring and Recordkeeping Requirements**

**4.9 Odor Complaints**

The permittee shall maintain records of all odor complaints received. If the complaint has merit, the permittee shall take appropriate corrective action as expeditiously as practicable. The records shall include, at a minimum, the date each complaint was received and a description of the following: the complaint, the permittee's assessment of the validity of the complaint, any corrective action taken, and the date the corrective action was taken.

[PTC No. P-2010.0139, 2/1/11]

**4.10 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines - Records**

In accordance with 40 CFR 60.4245 (a)(1) and (2), the permittee shall keep records of the following information:

- For each engine notifications submitted and all documentation supporting any notification.
- Maintenance conducted on each SI engines.

The permittee shall maintain these records on-site and be made available to DEQ representatives upon request for a period of at least five years.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4245(a)(1) and (2)]

## **Performance Testing Requirements**

**4.11 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – Performance Test Schedule**

In accordance with 40 CFR 60.4243(b)(2)(ii), the permittee shall conduct an initial performance test and conduct subsequent performance test every 8,760 hours or 3 years, whichever comes first, thereafter to demonstrate compliance on each engine.

- The permittee shall conduct the initial performance test within 60 days after achieving the maximum production rate, but not later than 180 days after initial startup.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4243(b)(2)(ii)]

**4.12 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines – Performance Test Procedures**

In accordance with 40 CFR 60.4244, the permittee shall follow these procedures:

- Each performance test must be conducted within 10 percent of 100 percent peak (or the highest achievable) load and according to the requirements in §60.8 and under conditions that are specified by Table 2 to subpart JJJJ.

- The permittee may not conduct performance tests during periods of startup, shutdown, or malfunction, as specified §60.8(c). If your stationary SI engine is non-operational, the permittee does not need to startup the engine solely to conduct a performance test.
- The permittee must conduct three separate test runs for each performance test required in this section, as specified in §60.8(f). Each test run must be conducted within 10 percent of 100 percent peak (or the highest achievable) load and last at least 1 hour.
- To determine compliance with the NO<sub>x</sub> mass per unit output emission limitation for each engine, the permittee shall convert the concentration of NO<sub>x</sub> in the engine exhaust using the following equation:

$$ER = \frac{C_d * 1.912 * 10^{-3} * Q * T}{HP - hr}$$

Where:

- ER = Emission rate of NO<sub>x</sub> in g/hp-hr.
- C<sub>d</sub> = Measured NO<sub>x</sub> concentration in parts per million by volume (ppmv).
- 1.912 x 10<sup>-3</sup> = Conversion for ppm NO<sub>x</sub> to grams per standard cubic meter @ 20 degrees Celsius.
- Q = Stack gas volumetric flow rate, in standard cubic meter per hour, dry basis.
- T = Time of test run, in hours.
- HP-hr = Brake work of the engine, horsepower-hour.

- To determine compliance with the CO mass per unit output emission limitation, the permittee shall convert the concentration of CO in the engine exhaust using the following equation:

$$ER = \frac{C_d * 1.164 * 10^{-3} * Q * T}{HP - hr}$$

Where:

- ER = Emission rate of CO in g/hp-hr.
- C<sub>d</sub> = Measured CO concentration in parts per million by volume (ppmv).
- 1.164 x 10<sup>-3</sup> = Conversion for ppm CO to grams per standard cubic meter at 20 degrees Celsius.
- Q = Stack gas volumetric flow rate, in standard cubic meter per hour, dry basis.
- T = Time of test run, in hours.
- HP-hr = Brake work of the engine, horsepower-hour.

- When calculating emissions of VOC, emissions of formaldehyde should not be included. To determine compliance with the VOC mass per unit output emission limitation, the permittee shall convert the concentration of VOC in the engine exhaust using the following equation:

$$ER = \frac{C_d * 1.833 * 10^{-3} * Q * T}{HP - hr}$$

Where:

- ER = Emission rate of VOC in g/hp-hr.
- C<sub>d</sub> = Measured VOC concentration as propane in parts per million by volume (ppmv).

1.833 x 10 <sup>-3</sup>	=	Conversion for ppm VOC measured as propane to grams per standard cubic meter at 20 degrees Celsius.
Q	=	Stack gas volumetric flow rate, in standard cubic meter per hour, dry basis.
T	=	Time of test run, in hours.
HP-hr	=	Brake work of the engine, horsepower-hour. [PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4244]

## Reporting Requirements

**4.13** Any notifications or reporting required by 40 CFR 60 Subpart JJJJ shall be submitted to both of the following addresses:

EPA Region 10  
 Director, Office of Air Quality  
 1200 Sixth Avenue  
 (OAQ-107)  
 Seattle, WA 98101

And

Air Quality Permit Compliance  
 Department of Environmental Quality  
 Coeur d'Alene Regional Office  
 2110 Ironwood Parkway  
 Coeur d'Alene, ID 83814  
 (208) 769-1422

[PTC No. P-2010.0139, 2/1/11]

**4.14** NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines - Initial Notification

In accordance with 40 CFR 60.4245, the permittee SI ICE must meet the following notification, reporting and recordkeeping requirements:

If the SI engines have not been certified by an engine manufacturer to meet the emission standards of 40 CFR 60.4231, the permittee must submit an initial notification as required in §60.7(a)(1). The notification must include the following information:

- Name and address of the owner or operator;
- The address of the affected source;
- Engine information including make, model, engine family, serial number, model year, maximum engine power, and engine displacement;
- Emission control equipment; and
- Fuel used.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4245]

**4.15** NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines - Performance Test Submittal

In accordance with 60.4245(d), the permittee must submit a copy of each performance test as conducted in 40 CFR 60.4244 within 60 days after the test has been completed.

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4245(d)]

**4.16 NSPS 40 CFR 60, Subpart JJJJ – Standards of Performance for Stationary Spark Ignition Internal Combustion Engines - General Provisions of 40 CFR 60**

In accordance with 40 CFR 60.4246, the permittee shall comply with the following applicable General Provisions of 40 CFR 60:

**Table 4.4 NSPS 40 CFR 60 General Provisions**

<b>General Provisions Citation</b>	<b>Subject of Citation</b>	<b>Applies to Subpart</b>	<b>Explanation</b>
§60.1	General applicability of the General Provisions	Yes	
§60.2	Definitions	Yes	Additional terms defined in §60.4248.
§60.3	Units and abbreviations	Yes	
§60.4	Address	Yes	
§60.5	Determination of construction or modification	Yes	
§60.6	Review of plans	Yes	
§60.7	Notification and Recordkeeping	Yes	Except that §60.7 only applies as specified in §60.4245.
§60.8	Performance tests	Yes	Except that §60.8 only applies to owners and operators who are subject to performance testing in subpart JJJJ.
§60.9	Availability of information	Yes	
§60.10	State Authority	Yes	
§60.11	Compliance with standards and maintenance requirements	Yes	Requirements are specified in subpart JJJJ.
§60.12	Circumvention	Yes	
§60.13	Monitoring requirements	No	
§60.14	Modification	Yes	
§60.15	Reconstruction	Yes	
§60.16	Priority list	Yes	
§60.17	Incorporations by reference	Yes	
§60.18	General control device requirements	No	
§60.19	General notification and reporting requirements	Yes	

[PTC No. P-2010.0139, 2/1/11; 40 CFR 60.4246]

## 5 General Provisions

### General Compliance

- 5.1 The permittee shall comply with all conditions of this permit. Any permit noncompliance constitutes a violation and is grounds for enforcement action; for permit termination, revocation and reissuance, or revision; or for denial of a permit renewal application.  
[IDAPA 58.01.01.322.15.a, 5/1/94; 40 CFR 70.6(a)(6)(i)]
- 5.2 It shall not be a defense in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the terms and conditions of this permit.  
[IDAPA 58.01.01.322.15.b, 5/1/94; 40 CFR 70.6(a)(6)(ii)]
- 5.3 Any permittee who fails to submit any relevant facts or who has submitted incorrect information in a permit application shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary facts or corrected information.  
[IDAPA 58.01.01.315.01, 5/1/94; 40 CFR 70.5(b)]

### Reopening

- 5.4 This permit may be revised, reopened, revoked and reissued, or terminated for cause. Cause for reopening exists under any of the circumstances listed in IDAPA 58.01.01.386. Proceedings to reopen and reissue a permit shall follow the same procedures as apply to initial permit issuance and shall affect only those parts of the permit for which cause to reopen exists. Such reopening shall be made as expeditiously as practicable in accordance with IDAPA 58.01.01.360 through 369.  
[IDAPA 58.01.01.322.15.c, 5/1/94; IDAPA 58.01.01.386, 3/19/99; 40 CFR 70.7(f)(1), (2); 40 CFR 70.6(a)(6)(iii)]
- 5.5 The filing of a request by the permittee for a permit revision, revocation and reissuance, or termination or of a notification of planned changes or anticipated noncompliance does not stay any permit condition.  
[IDAPA 58.01.01.322.15.d, 5/1/94; 40 CFR 70.6(a)(6)(iii)]

### Property Rights

- 5.6 This permit does not convey any property rights of any sort or any exclusive privilege.  
[IDAPA 58.01.01.322.15.e, 5/1/94; 40 CFR 70.6(a)(6)(iv)]

### Information Requests

- 5.7 The permittee shall furnish all information requested by DEQ, within a reasonable time, that DEQ may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit.  
[Idaho Code §39-108; IDAPA 58.01.01.122, 4/5/00; IDAPA 58.01.01.322.15.f, 4/5/00; 40 CFR 70.6(a)(6)(v)]
- 5.8 Upon request, the permittee shall furnish to DEQ copies of records required to be kept by this permit. For information claimed to be confidential, the permittee may furnish such records along with a claim of confidentiality in accordance with Idaho Code §9-342A and applicable implementing regulations including IDAPA 58.01.01.128.  
[IDAPA 58.01.01.322.15.g, 5/1/94; IDAPA 58.01.01.128, 4/5/00; 40 CFR 70.6(a)(6)(v)]

## Severability

- 5.9 The provisions of this permit are severable, and if any provision of this permit to any circumstance is held invalid, the application of such provision to other circumstances and the remainder of this permit shall not be affected thereby.

[IDAPA 58.01.01.322.15.h, 5/1/94; 40 CFR 70.6(a)(5)]

## Changes Requiring Permit Revision or Notice

- 5.10 The permittee may not commence construction or modification of any stationary source, facility, major facility, or major modification without first obtaining all necessary permits to construct or an approval under IDAPA 58.01.01.213, or complying with IDAPA 58.01.01.220 through 223. The permittee shall comply with IDAPA 58.01.01.380 through 386 as applicable.

[IDAPA 58.01.01.200–223, 4/2/08; IDAPA 58.01.01.322.15.i, 3/19/99; IDAPA 58.01.01.380–386, 7/1/02; 40 CFR 70.4(b)(12), (14), (15); 40 CFR 70.7(d), (e)]

- 5.11 Changes that are not addressed or prohibited by the Tier I operating permit require a Tier I operating permit revision if such changes are subject to any requirement under Title IV of the Clean Air Act (CAA), 42 United States Code (U.S.C.) Section 7651 through 7651c, or are modifications under Title I of the CAA, 42 U.S.C. Section 7401 through 7515. Administrative amendments (IDAPA 58.01.01.381), minor permit modifications (IDAPA 58.01.01.383), and significant permit modifications (IDAPA 58.01.01.382) require a revision to the Tier I operating permit. IDAPA 58.01.01.502(b)(10) changes are authorized in accordance with IDAPA 58.01.01.384. Off permit changes and required notice are authorized in accordance with IDAPA 58.01.01.385.

[IDAPA 58.01.01.381–385, 4/5/00; IDAPA 58.01.01.209.05, 4/11/06; 40 CFR 70.4(b)(14), (15)]

## Federal and State Enforceability

- 5.12 Unless specifically identified as a "state-only" provision, all terms and conditions in this permit, including any terms and conditions designed to limit a source's potential to emit, are enforceable: (i) by DEQ in accordance with state law; and (ii) by the United States or any other person in accordance with federal law.

[IDAPA 58.01.01.322.15.j, 5/1/94; 40 CFR 70.6(b)(1), (2)]

- 5.13 Provisions specifically identified as a "state-only" provision are enforceable only in accordance with state law. "State-only" provisions are those that are not required under the Federal Clean Air Act or under any of its applicable requirements or those provisions adopted by the state prior to federal approval.

[Idaho Code §39-108; IDAPA 58.01.01.322.15.k, 3/23/98]

## Inspection and Entry

- 5.14 Upon presentation of credentials, the permittee shall allow DEQ or an authorized representative of DEQ to do the following:

- Enter upon the permittee's premises where a Tier I source is located, or emissions related activity is conducted, or where records are kept under conditions of this permit;
- Have access to and copy, at reasonable times, any records that are kept under the conditions of this permit;
- Inspect at reasonable times any facilities, equipment (including monitoring and air pollution control equipment), practices, or operations regulated or required under this permit; and
- As authorized by the Idaho Environmental Protection and Health Act, sample or monitor, at reasonable times, substances or parameters for the purpose of determining or ensuring compliance with this permit or applicable requirements.

[Idaho Code §39-108; IDAPA 58.01.01.322.15.l, 5/1/94; 40 CFR 70.6(c)(2)]

## **New Applicable Requirements**

**5.15** The permittee shall comply with applicable requirements that become effective during the permit term on a timely basis.

[IDAPA 58.01.01.322.10, 4/5/00; IDAPA 58.01.01.314.10.a.ii, 5/1/94;  
40 CFR 70.6(c)(3) citing 70.5(c)(8)]

## **Fees**

**5.16** The permittee shall pay annual registration fees to DEQ in accordance with IDAPA 58.01.01.387 through IDAPA 58.01.01.397.

[IDAPA 58.01.01.387, 4/2/03; 40 CFR 70.6(a)(7)]

## **Certification**

**5.17** All documents submitted to DEQ shall be certified in accordance with IDAPA 58.01.01.123 and comply with IDAPA 58.01.01.124.

[IDAPA 58.01.01.322.15.o, 5/1/94; 40 CFR 70.6(a)(3)(iii)(A); 40 CFR 70.5(d)]

## **Renewal**

**5.18** The permittee shall submit an application to DEQ for a renewal of this permit at least six months before, but no earlier than 18 months before, the expiration date of this operating permit. To ensure that the term of the operating permit does not expire before the permit is renewed, the permittee is encouraged to submit a renewal application nine months prior to the date of expiration.

[IDAPA 58.01.01.313.03, 4/5/00; 40 CFR 70.5(a)(1)(iii)]

**5.19** If a timely and complete application for a Tier I operating permit renewal is submitted, but DEQ fails to issue or deny the renewal permit before the end of the term of this permit, then all the terms and conditions of this permit, including any permit shield that may have been granted pursuant to IDAPA 58.01.01.325, shall remain in effect until the renewal permit has been issued or denied.

[IDAPA 58.01.01.322.15.p, 5/1/94; 40 CFR 70.7(b)]

## **Permit Shield**

**5.20** Compliance with the terms and conditions of the Tier I operating permit, including those applicable to all alternative operating scenarios and trading scenarios, shall be deemed compliance with any applicable requirements as of the date of permit issuance, provided that:

- Such applicable requirements are included and are specifically identified in the Tier I operating permit; or
- DEQ has determined that other requirements specifically identified are not applicable and all of the criteria set forth in IDAPA 58.01.01.325.01(b) have been met.
- The permit shield shall apply to permit revisions made in accordance with IDAPA 58.01.01.381.04 (administrative amendments incorporating the terms of a permit to construct), IDAPA 58.01.01.382.04 (significant modifications), and IDAPA 58.01.01.384.03 (trading under an emissions cap).
- Nothing in this permit shall alter or affect the following:
  - Any administrative authority or judicial remedy available to prevent or terminate emergencies or imminent and substantial dangers;
  - The liability of a permittee for any violation of applicable requirements prior to or at the time of permit issuance;
  - The applicable requirements of the acid rain program, consistent with 42 U.S.C. Section 7651(g)(a); and

- The ability of EPA to obtain information from a source pursuant to Section 114 of the CAA; or the ability of DEQ to obtain information from a source pursuant to Idaho Code §39-108 and IDAPA 58.01.01.122.  
[Idaho Code §39-108 and 112; IDAPA 58.01.01.122, 4/5/00; IDAPA 58.01.01.322.15.m, 5/1/94; IDAPA 58.01.01.325, 3/19/99; IDAPA 58.01.01.381.04, 382.04, 383.05, 384.03, 385.03, 3/19/99; 40 CFR 70.6(f)]

## Compliance Schedule and Progress Reports

5.21 The permittee shall comply with the following:

- For each applicable requirement for which the source is not in compliance, the permittee shall comply with the compliance schedule incorporated in this permit.
- For each applicable requirement that will become effective during the term of this permit and that provides a detailed compliance schedule, the permittee shall comply with such requirements in accordance with the detailed schedule.
- For each applicable requirement that will become effective during the term of this permit that does not contain a more detailed schedule, the permittee shall meet such requirements on a timely basis.
- For each applicable requirement with which the permittee is in compliance, the permittee shall continue to comply with such requirements.

[IDAPA 58.01.01.322.10, 4/5/00; IDAPA 58.01.01.314.9, 5/1/94; IDAPA 58.01.01.314.10, 4/5/00; 40 CFR 70.6(c)(3) and (4)]

## Periodic Compliance Certification

5.22 The permittee shall submit compliance certifications during the term of the permit for each emissions unit to DEQ and the EPA as follows:

- The compliance certifications for all emissions units shall be submitted annually from January 1 to December 31 or more frequently if specified by the underlying applicable requirement or elsewhere in this permit by DEQ.
- The initial compliance certification for each emissions unit shall address all of the terms and conditions contained in the Tier I operating permit that are applicable to such emissions unit, including emissions limitations, standards, and work practices;
- The compliance certification shall be in an itemized form providing the following information (provided that the identification of applicable information may cross-reference the permit or previous reports as applicable):
  - The identification of each term or condition of the Tier I operating permit that is the basis of the certification;
  - The identification of the method(s) or other means used by the permittee for determining the compliance status with each term and condition during the certification period. Such methods and other means shall include, at a minimum, the methods and means required under Subsections 322.06, 322.07, and 322.08;
  - The status of compliance with the terms and conditions of the Tier I operating permit for the period covered by the certification, including whether compliance during the period was continuous or intermittent. The certification shall be based on the method or means designated in Subsection 322.11.c.ii above. The certification shall identify each deviation and take it into account in the compliance certification. The certification shall also identify as possible exceptions to compliance any periods during which compliance is required and in which an excursion or exceedance as defined under 40 CFR Part 64 occurred; and

- Such information as DEQ may require to determine the compliance status of the emissions unit.

5.23 All original compliance certifications shall be submitted to DEQ and a copy of all compliance certifications shall be submitted to the EPA.

[IDAPA 58.01.01.322.11, 4/6/05; 40 CFR 70.6(c)(5)(iii) as amended, 62 Fed. Reg. 54900, 54946 (10/22/97); 40 CFR 70.6(c)(5)(iv)]

### **False Statements**

5.24 No person shall knowingly make any false statement, representation, or certification in any form, notice, or report required under this permit or any applicable rule or order in force pursuant thereto.

[IDAPA 58.01.01.125, 3/23/98]

### **No Tampering**

5.25 No person shall knowingly render inaccurate any monitoring device or method required under this permit or any applicable rule or order in force pursuant thereto.

[IDAPA 58.01.01.126, 3/23/98]

### **Semiannual Monitoring Reports**

5.26 In addition to all applicable reporting requirements identified in this permit, the permittee shall submit reports of any required monitoring at least every six months. The permittee's semiannual reporting periods shall be from January 1 to June 30 and July 1 to December 31. All instances of deviations from this operating permit's requirements must be clearly identified in the report. The semiannual reports shall be submitted to DEQ within 30 days of the end of the specified reporting period.

[IDAPA 58.01.01.322.15.q, 3/23/98; IDAPA 58.01.01.322.08.c, 4/5/00; 40 CFR 70.6(a)(3)(iii)]

### **Reporting Deviations and Excess Emissions**

5.27 The permittee shall promptly report all deviations from permit requirements including upset conditions, their probable cause, and any corrective actions or preventive measures taken. For excess emissions, the report shall be made in accordance with IDAPA 58.01.01.130–136. For all other deviations, the report shall be made in accordance with IDAPA 58.01.01.322.08.c, unless otherwise specified in this permit.

[IDAPA 58.01.01.322.15.q, 3/23/98; IDAPA 58.01.01.135, 4/11/06; 40 CFR 70.6(a)(3)(iii)]

### **Permit Revision Not Required**

5.28 No permit revision shall be required under any approved economic incentives, marketable permits, emissions trading, and other similar programs or processes for changes that are provided for in the permit.

[IDAPA 58.01.01.322.05.b, 4/5/00; 40 CFR 70.6(a)(8)]

### **Emergency**

5.29 In accordance with IDAPA 58.01.01.332, an "emergency," as defined in IDAPA 58.01.01.008, constitutes an affirmative defense to an action brought for noncompliance with such technology-based emissions limitation if the conditions of IDAPA 58.01.01.332.02 are met.

[IDAPA 58.01.01.332.01, 4/5/00; 40 CFR 70.6(g)]