

Idaho Department of Environmental Quality Reuse Permit M-196-03

(Previous Permit No. M-0196-02)

Garden Valley School District #71 (hereafter "permittee") is hereby authorized to construct, install, and operate a reuse facility in accordance with (1) this permit; (2) IDAPA 58.01.17 "Recycled Water Rules"; (3) an approved plan of operation; and (4) all other applicable federal, state, and local laws, statutes, and rules. This permit is effective from the date of signature and expires on May 8, 2029.



Signature



Date

Aaron Scheff

Regional Administrator
Boise Regional Office
Idaho Department of Environmental Quality

Idaho Department of Environmental Quality
Boise Regional Office
1445 N. Orchard St
208-373-0550

This page intentionally left blank for correct double-sided printing.

Table of Contents

1. Common Acronyms/Abbreviations and Definitions	5
2. Facility Information	7
3. Compliance Schedule for Required Activities.....	8
4. Permit Limits and Conditions	10
4.1 Hydraulic Management Unit Description.....	10
4.2 Hydraulic Loading Limits.....	10
4.3 Constituent Loading Limits	10
4.4 Management Unit Buffer Zones	10
4.5 Other Permit Limits and Conditions.....	11
5. Monitoring Requirements	12
5.1 Recycled Water and Supplemental Irrigation Water Monitoring Point Locations.....	12
5.1.1 Year-Long Monitoring of Treated Water	13
5.1.2 Irrigation Season Monitoring.....	14
5.1.3 2019-2020 Sampling of Influent and Treated Water.....	14
5.2 Ground Water Monitoring	15
5.2.1 Ground Water Monitoring Point Descriptions	15
5.2.2 Ground Water Monitoring, Sampling, and Analyses	15
5.3 Soil Monitoring.....	16
5.3.1 Soil Monitoring Unit Descriptions	16
5.3.2 Soil Monitoring, Sampling, and Analyses.....	16
5.4 Crop Monitoring – Not Required.....	16
5.5 Lagoon Information	16
6. Reporting Requirements	17
6.1 Annual Report Requirements.....	17
6.1.1 Due Date	17
6.1.2 Required Contents	17
6.1.3 Submittals	18
6.2 Emergency and Noncompliance Reporting	19
7. Reserved.....	21
8. Standard Permit Conditions	21
9. General Permit Conditions.....	23
9.1 Operations	23
9.1.1 Backflow Prevention	23
9.1.2 Restricted to Premises	23
9.1.3 Health Hazards, Nuisances, and Odors Prohibited.....	24
9.1.4 Solids Management	24
9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801).....	25
9.1.6 Plan of Operation (IDAPA 58.01.17.300.05).....	25
9.1.7 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c).....	25
9.1.8 Ground Water Quality Rule (IDAPA 58.01.11).....	26
9.2 Administrative.....	26
9.2.1 Permit Modification (IDAPA 58.01.17.700).....	26
9.2.2 Permit Transferable (IDAPA 58.01.17.800)	26

9.2.3	Permit Revocation (IDAPA 58.01.17.920)	26
9.2.4	Violations (IDAPA 58.01.17.930).....	27
9.2.5	Severability	27
10.	Other Applicable Laws	28
10.1	Owner Responsibilities for Well Use and Maintenance	28
10.1.1	Well Use	28
10.1.2	Well Maintenance.....	28
10.1.3	Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Ground Water Resource	28
11.	Site Maps	29
11.1	Regional Map.....	29
11.2	Facility Map(s).....	30
11.3	Process Flow Diagram with Sampling Points.....	31

1. Common Acronyms/Abbreviations and Definitions

CA	compliance activity
COD	chemical oxygen demand
cwt	a unit of weight measurement equal to 100 pounds
DEQ	Idaho Department of Environmental Quality
director	DEQ director or designee unless otherwise specified
E_i	irrigation efficiency
EPA	Environmental Protection Agency
FM	prefix for flow measurement/monitoring location, device, or method reporting serial number
GVSD	Garden Valley School District
GW	prefix for ground water reporting serial number
IDWR	Idaho Department of Water Resources
IWR	irrigation water requirement – any combination of wastewater and supplemental irrigation water applied at rates commensurate to the moisture requirements of the crop, and calculated monthly during the growing season. The equation used to calculate the IWR is: $IWR = P_{def}/E_i$ where P_{def}
lb	pound
LG	prefix for lagoon reporting serial number
material change	a change in a document required by this permit that would impact DEQ's ability to ensure compliance and protect human health and the environment
μ mhos/cm	micromhos per centimeter
MG	million gallons
mg/kg	milligram per kilogram
mg/L	milligram per liter
mL	milliliter
MU	prefix for management unit reporting environmental serial number
NPDES	National Pollutant Discharge Elimination System
NTU	nephelometric turbidity unit
N	nitrogen
ppm	parts per million
P	phosphorus

P _{def}	precipitation deficit - is synonymous with the net irrigation water requirement of the crop and for the purposes of this permit can be found at the following website http://data.kimberly.uidaho.edu/ETIdaho/
PO	plan of operation
QAPP	quality assurance project plan
Responsible Official	facility contact person authorized by the permittee to communicate with DEQ on behalf of the permittee on any matter related to the permit, including without limitation, the authority to communicate with and receive notices from DEQ regarding notices of violation or non-compliance, permit violations, permit enforcement, and permit revocation. The responsible official provides written certification of permit application materials, annual report submittals, and other information submitted to DEQ as required by the permit. Any notice to or communication with the responsible official is considered a notice to or communication with the permittee. The responsible official may designate an authorized representative to act as the facility contact person for any of the activities or duties related to the permit, except signing and certifying the permit application, which must be done by the responsible official. The authorized representative shall act as the responsible official and shall bind the permittee as described in this definition. Designation of the authorized representative shall follow the requirements specified in section 6.1.3 of the permit.
SBR	sequencing batch reactor
SU	prefix for soil monitoring unit reporting serial number
SW	prefix for supplemental irrigation water reporting serial number
WW	prefix for wastewater reporting serial number
yr	year

2. Facility Information

Information Type	Information Specific to This Permit
Type(s) of recycled water	Class B Municipal
Method of treatment and reuse	Dual-train sequencing batch reactors, coagulation, sand filtration, ultraviolet disinfection system, effluent chlorination, effluent storage pond, slow rate land application. Aerated sludge tank for storage and treatment of biosolids.
Collection and treatment system classification	Wastewater collection system classification: Class I Wastewater treatment system classification: Class II
Facility location	1073 Banks Lowman Highway, Garden Valley, ID 83622, Boise County, (208) 462-3756 Township 9N, Range 4E, Section 26
Facility mailing address	P.O. Box 710 Garden Valley, ID 83622
Facility responsible official and authorized representative	Responsible Official: Vickie Chandler, Superintendent, P.O. Box 710, (208) 462-3756, vchandler@gvsd.net Authorized Representative: Terry Tucker, (208) 859-8826, cinterwaterworks@yahoo.com Notify DEQ within 30 days if a change in personnel occurs for any of the facility contacts. DEQ will issue a minor permit modification to confirm the change.
Ground water	Shallow unconfined aquifer is 9 feet bgs with western flow towards the South Fork of the Payette River. The nearest Public Water Supply Well, PWS # ID4080017, serves the Garden Valley School and is located approximately 430 feet to the north of the reuse site.
Surface water	Small ephemeral stream 150 feet southwest of land application treatment site. South Fork of the Payette River is located 3,500 feet southwest of the land application treatment site. Designated Beneficial uses: cold water biota, salmonid spawning, primary contact recreation, drinking water supply

3. Compliance Schedule for Required Activities

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-196-01 6 months after permit issuance	<p>Updated Plan of Operation (PO): The permittee shall submit for review and approval an updated Plan of Operation that reflects current operations and incorporates the requirements of this permit. The PO shall comply with the applicable requirements stated in IDAPA 58.01.17.300.05 and shall address applicable items in the Plan of Operation Checklist in the DEQ Guidance, and the following plan:</p> <ul style="list-style-type: none"> • Disinfection Management Plan <p>The approved PO shall be updated as needed to reflect current operations. The permittee shall notify DEQ of material changes to the PO and copies shall be kept on site and made available to DEQ upon request.</p>
CA-196-02 6 months after permit issuance	<p>Updated Quality Assurance Project Plan (QAPP): The permittee shall update and implement a QAPP that incorporates all monitoring and reporting required by this permit. A copy of the updated QAPP along with written notice that the permittee has implemented the QAPP shall be provided to DEQ. The Permittee must follow the QAPP when collecting, analyzing, and reporting monitoring data submitted to DEQ.</p> <p>The QAPP shall be designed to assist in planning for the collection, analysis, and reporting of all monitoring in support of this permit and in explaining data anomalies when they occur. At a minimum, the QAPP must include the following:</p> <ol style="list-style-type: none"> 1. Details on the number of measurements, number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection, and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements. 2. Maps indicating the location of each monitoring, and sampling point. 3. Qualification and training of personnel. 4. Names, addresses, and telephone numbers of the laboratories used by or proposed to be used by the permittee. 5. Example formats and tables that will be used by the permittee to summarize and present all data in the annual report. <p>The format and content of the QAPP should adhere to the recommendations and references in the Quality Assurance and Data Processing sections of the DEQ Guidance.</p> <p>The permittee shall amend the QAPP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAPP. The permittee shall notify DEQ of material changes to the QAPP and copies shall be kept on site and made available to DEQ upon request.</p>

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description				
CA-196-03 As specified	<p>Seepage Testing: The following table shows the date by which the permittee shall complete seepage testing on the specified lagoons:</p> <table border="1" data-bbox="435 453 1321 533"> <thead> <tr> <th data-bbox="440 453 878 491">Lagoon:</th> <th data-bbox="881 453 1317 491">Seepage Test Due Date:</th> </tr> </thead> <tbody> <tr> <td data-bbox="440 495 878 533">Storage Lagoon</td> <td data-bbox="881 495 1317 533">August/2019</td> </tr> </tbody> </table> <p>Submit to DEQ for review and approval a proposed schedule and procedure for performing the required seepage tests at least 45 days prior to the planned seepage test. Guidance for developing seepage test procedures are available at: http://www.deq.idaho.gov/water-quality/wastewater/lagoon-seepage-testing.aspx The seepage test procedures shall be sealed by the Idaho licensed professional engineer or professional geologist in responsible charge for the test.</p> <p>Seepage tests shall be completed in accordance with the procedures approved by DEQ. The seepage test report shall be sealed by the Idaho professional engineer or professional geologist in responsible charge for the test and submitted within 90 days after completion of the seepage test.</p> <p>For municipal lagoons, the leakage rate for lagoons constructed after April 15, 2007 shall be no more than zero point one hundred twenty-five (0.125) inches (1/8 inch) per day. The leakage rate for existing lagoons constructed prior to April 15, 2007 shall be no more than zero point twenty-five (0.25) inches (1/4 inch) per day. See IDAPA 58.01.16.493.03. Requirements for lagoons leaking above the allowable amount are outlined in IDAPA 58.01.16.493.04.</p>	Lagoon:	Seepage Test Due Date:	Storage Lagoon	August/2019
Lagoon:	Seepage Test Due Date:				
Storage Lagoon	August/2019				
CA-196-04 18 months before permit expiration	<p>Pre-Application Workshop: If the permittee intends to continue operating the reuse facility beyond the expiration date of this permit, the permittee shall contact DEQ and schedule a pre-application workshop to discuss the compliance status of the facility and the content required for the reuse permit application package.</p>				
CA-196-05 12 months before permit expiration	<p>Renewal Permit Application: The permittee shall submit to DEQ a complete permit renewal application package, which fulfills the requirements specified at the pre-application workshop identified in CA-196-04.</p>				

4. Permit Limits and Conditions

4.1 Hydraulic Management Unit Description

Serial Number	Description	Irrigation System Type and Irrigation Efficiency	Maximum Acres ^a Allowed
MU-196-01	Football Field	Sprinkler system: (Ei = 0.80)	2.3
Total acreage			2.3

- a. Maximum acres represent the total permitted acreage of the MU as provided by the permittee. If the permittee uses less acreage in any season or year, then loading rates shall be presented and compliance shall be determined based on the actual acreage utilized during each season or year.

4.2 Hydraulic Loading Limits

Serial Number	Growing Season Hydraulic Loading	Nongrowing Season Maximum Hydraulic Loading, inches
MU-196-01	Substantially at the irrigation water requirement (IWR) ^a	Not Allowed

- a. For compliance purposes, the source of P_{def} data used to calculate the IWR shall be specified in the PO.

4.3 Constituent Loading Limits

Serial Number	Constituent Loading from All Sources
MU-196-01	Nitrogen (lb/acre)
	$220 + 110 * (\text{fraction of time clippings are removed from the site})$

4.4 Management Unit Buffer Zones

Serial Number	Buffer Distances (in feet) from Hydraulic Management Units					
	Public Water Supplies	Private Water Supplies ^a	Inhabited Dwellings	Permanent and Intermittent Surface Water	Irrigation Ditches and Canals	Areas Accessible to the Public
MU-196-01	100	100	100	10	10	0

- a. A buffer distance of 100 feet to food service areas and drinking water shall be provided.

4.5 Other Permit Limits and Conditions

Category	Permit Limits and Conditions
Growing season	May 1 through October 31 (184 days)
Nongrowing season	November 1 through April 30 (181 days)
Reporting year for annual loading rates	January 1 through December 31
Operator certification and endorsement	The wastewater treatment facility and reuse system shall be operated by personnel certified and licensed in the State of Idaho wastewater operator training program at the operator class level specified in IDAPA 58.01.16.203 and properly trained to operate and maintain the system.
Disinfection limits in recycled water	Class B: The median number of total coliform organisms does not exceed 2.2 total coliform organisms/100 mL, as determined from the bacteriological results of the last 7 days for which analyses have been completed. No sample shall exceed 23 total coliform organisms/100 mL in any confirmed sample.
Turbidity	The daily arithmetic mean of all daily measurements shall not exceed five (5) NTU and turbidity shall not exceed ten (10) NTU at any time. The turbidity standard shall be met prior to disinfection.
Grazing	Grazing is not allowed.
Posting	Signs shall read "Caution: Recycled Water—Do Not Drink," or equivalent signage both in English and Spanish. Signs to be posted every 500 feet around the perimeter of the irrigated site during periods of irrigation with recycled water.
Fencing	Temporary fencing shall be in place when irrigating with recycled water.
Shock Chlorination	Prior to the start of irrigation, the lagoon shall be chlorinated in accordance with the Plan of Operation. Irrigation shall not commence until the results of the total coliform test are received by the permittee.
Maximum Wastewater Flow Rate to SBR Treatment System	Maximum daily flow rate shall not exceed 6,675 gallons/day. Maximum flow during the NGS shall not exceed 657,000 gallons.
Construction plans	Pursuant to Idaho Code §39-118, IDAPA 58.01.16, and IDAPA 58.01.17, detailed plans and specifications shall be submitted to DEQ for review and approval prior to construction, modification, or expansion of any wastewater treatment, storage, conveyance structures, ground water monitoring wells, or reuse facility. Inspection requirements shall be satisfied, and within 30 days of completion of construction, the permittee shall submit as-built plans, or a letter from an Idaho Professional Engineer certifying the facilities or structures were constructed in substantial accordance with the approved plans and specifications.
Backflow prevention and testing requirements	Backflow prevention is required to protect surface water and ground water from an unauthorized discharge of recycled water or wastewater. Refer to section 9.1.1 of this permit and the Plan of Operation.
Records retention requirements	Keep records generated to meet the requirements of this permit for the duration of the permit, including administrative extensions, plus 2 years.

5. Monitoring Requirements

5.1 Recycled Water and Supplemental Irrigation Water Monitoring Point Locations

Monitoring Point Serial Number	Common Designation
WW-196-01	Wastewater influent to distribution tank, after screen
WW-196-02	Filtered recycled water, pre-disinfection (prior to Chlorine Injection)
WW-196-03	Disinfected recycled water measured in the Chlorine Contact Tank, following chlorine contact time
WW-196-04	Recycled water in the Dose Tank to be discharged to the lagoon (LG-196-01)
WW-196-05	Recycled water discharge from lagoon (LG-196-01) to football field (MU-196-01), sample collected from the wet well next to the lagoon
SW-196-01	Supplemental irrigation water supplied by PWS #ID4080017
FM-196-01	Wastewater influent flow from either SBR tank to the Filter Feed Tank
FM-196-02	Recycled water flow from the Dose Tank to the lagoon (LG-196-01)
FM-196-03	Recycled water flow from lagoon (LG-196-01), or supplemental irrigation water flow to football field (MU-196-01)

Monitoring for this permit occurs during two overlapping periods, with some monitoring required all year long, and some monitoring required only during the growing season, when irrigation of the management units is allowed.

5.1.1 Year-Long Monitoring of Treated Water

Throughout the year, the following monitoring is required of the wastewater treated by the SBR Wastewater Treatment Plant.

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Measured Parameters
FM-196-01 Influent flow – Pump run time	Volume of wastewater treated by SBR	- Daily record of total runtime; - Monthly compilation of data	- Hours per day
FM-196-02 Effluent flow meter – Impeller Type	Volume recycled water	- Daily meter reading; - Monthly compilation of data	- Flow (gallons per day, MG/month)
WW-196-02 Pre-disinfection	Turbidity of filtered recycled water, pre- disinfection	In-line/Continuous Monitoring and Recording	- Turbidity (NTU)
WW-196-03 Recycled Water	Recycled water to LG-196-01	Grab/ Twice per week when discharging treated water to LG-196-01	- Total coliform (MPN/100ml)
WW-196-03 Recycled Water	Recycled water to LG-196-01	Daily Grab/Field sample	- Total chlorine residual (mg/L) - Free chlorine residual (mg/L) - pH (standard units)
WW-196-04 Recycled Water	Recycled Water to LG-196-01	Grab/monthly	- Total Kjeldahl nitrogen, as N (mg/L) - Nitrite + nitrate nitrogen, as N (mg/L) - Total phosphorus, as P (mg/L)

5.1.2 Irrigation Season Monitoring

During the growing season, from May to October, the following monitoring is required in addition to the year-long monitoring in Section 5.1.1.

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Measured Parameters
FM-196-03 Recycled water irrigation	Recycled water flow from LG-196-01 to MU-196-01	- Daily meter reading - Monthly compilation of data	- Flow (gal/day, MG/month) - Application depth (inches/month)
FM-196-03 Supplemental irrigation water	Supplemental irrigation water volume to MU-196-01	- Daily meter reading - Monthly compilation of data	- Flow (gal/day, MG/month) - Application depth (inches/month)
WW-196-05 Recycled Water from LG-196-01	Recycled water applied to MU-196-01	Grab/monthly when irrigating	- Total Kjeldahl nitrogen, as N (mg/L) - Nitrite + nitrate-nitrogen, as N (mg/L) - Total phosphorus, as P (mg/L)

5.1.3 2019-2020 Sampling of Influent and Treated Water

For a one-year period in 2019-2020 only, the following monitoring is required of the influent to and treated water from the SBR Wastewater Treatment Plant.

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Measured Parameters
WW-196-01 Influent	Wastewater Influent	<u>Composite</u> ^a /July and October in 2019 and January and April of 2020	- COD (mg/L) - Nitrate + nitrite nitrogen, as N (mg/L) - Ammonia, as N (mg/L) - Total nitrogen, as N (mg/L) - Total phosphorus, as P (mg/L) - Alkalinity
		<u>Grab</u> Sample / July and October in 2019, and January and April of 2020	- Oil and Grease
		Field Data / Record <u>monthly</u> for 12 consecutive months starting in May, 2019	- pH (standard units) - Temperature (°C)
WW-196-04 Recycled Water	Recycled Water to LG-196-01	<u>Composite</u> ^a / July and October in 2019, and January and April of 2020	- COD (mg/L)

a. The composite shall be defined in the QAPP, and shall be comprised of at least three grab samples collected on separate days.

5.2 Ground Water Monitoring

5.2.1 Ground Water Monitoring Point Descriptions

Monitoring Point Serial Number	Common Designation	Well Type	Gradient Location
GW-196-01	MW 1 "North"	Monitoring well	Upgradient
GW-196-02	MW 2 "South"	Monitoring well	Downgradient
GW-196-03	MW 3 "East"	Monitoring well	Sidegradient

5.2.2 Ground Water Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sampling Point Description	Sample Type and Frequency	Constituents (Units in mg/L Unless Otherwise Specified)
GW-196-01 GW-196-02 GW-196-03	Monitoring wells	Measurement/monthly (May through October)	- Depth to ground water (inches) ^a
GW-196-01 GW-196-02 GW-196-03	Monitoring wells	Unfiltered grab sample/three times per year: (April, July, October) ^b	- Nitrate-nitrogen, as N - Total Kjeldahl Nitrogen, as N - Total Dissolved Solids - Total phosphorus, as P
		Field Data/three times per year: (April, July, October) ^b	- Specific conductance/electrical conductivity (µmhos/cm) - pH (Standard Units)

- a. Depth to ground water shall be measured prior to purging the ground water monitoring wells.
- b. Ground water monitoring wells shall be purged a minimum of three casing volumes and/or until field measurements for pH, specific conductance, and temperature meet the following conditions: two successive temperature values measured at least five minutes apart are within one degree Celsius of each other, pH values for two successive measurements measured at least five minutes apart are within 0.2 units of each other, and two successive specific conductance values measured at least five minutes apart are within 10% of each other.

5.3 Soil Monitoring

5.3.1 Soil Monitoring Unit Descriptions

Monitoring Point Serial Number	Description	Associated Hydraulic Management Unit
SU-196-01	Football field	MU-196-01

5.3.2 Soil Monitoring, Sampling, and Analyses

Monitoring Point Serial Number	Sample Type	Sample Frequency	Constituents (Units in mg/kg Soil Unless Otherwise Specified)
SU-196-01	Composite samples ^a	May of 2019, 2023, and 2027	<ul style="list-style-type: none"> - Electrical conductivity (µmhos/cm in saturated paste extract) - Nitrate-nitrogen - Ammonium nitrogen - Plant available phosphorus - pH (standard units) - Exchangeable Sodium Percentage (%)

- a. The number of sample locations specified in the PO or QAPP for each SU shall be sampled. At each location, samples shall be obtained from three depths: 0–12 inches; 12–24 inches; and 24–36 inches or refusal. The samples obtained from each depth shall be composited by depth to yield three composite samples for each soil monitoring unit; one composite sample for each depth.

5.4 Crop Monitoring – Not Required

5.5 Lagoon Information

Serial number	Description	Surface Area, acres	Maximum Operating Volume, MG	Liner Type
LG-196-01	Storage Lagoon	0.57	0.876	60 mil HDPE

6. Reporting Requirements

6.1 Annual Report Requirements

The permittee shall submit to DEQ an Annual Report prepared by a competent environmental professional covering the previous reporting year.

6.1.1 Due Date

The Annual Report is due no later than January 31 of each year, which shall cover the previous reporting year.

6.1.2 Required Contents

The Annual Report shall include the following:

1. A brief interpretive discussion of all required monitoring data. The discussion shall address data quality objectives, validation, and verification; permit compliance; and reuse facility environmental impacts. The reporting year for this permit is specified in section 4.5.
2. Results of the required monitoring as described in section 5 of this permit. If the permittee monitors any parameter for compliance purposes more frequently than required by this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the annual report. The report shall present all monitoring data in organized data summary tables to expedite review.
3. Status of all work described in section 3 of this permit.
4. Results of all backflow testing, repairs, and replacements required by section 9.1.1 of this permit.
5. Discussion of major maintenance activities such as major equipment replacement, lagoon liner maintenance, and wastewater treatment and reuse facility maintenance.
6. A summary of all noncompliance events that occurred during the reporting year. Examples of noncompliance events that must be discussed include, but are not limited to: exceedance of permit limits, complaints, missed monitoring events, incorrect monitoring dates or frequencies, dry monitoring wells, uncontained spills causing runoff, construction without DEQ engineering plan approval, construction without engineering inspection, and reporting incorrect acreage.
7. Laboratory analytical reports for monitoring specified in section 5 of the permit. Chain of custody forms, supporting information for laboratory analytical reports, and quality assurance documentation shall be available for review upon request by DEQ.
8. Submittal of the calculations and observations for the MU specified in the following table:

Monitoring Point Serial Number	Parameter (Calculate for each MU)	Units
MU-196-01	Influent volume calculated from pump run time and the rated capacity of the pump	Gallons/day Gallons/month
	Recycled water loading rate	Gallons/month Inches/month
	Irrigation water loading rate	Gallons/month Inches/month
	Irrigation water requirement (IWR) for each crop grown	Inches/month Inches/Growing Season
	Recycled water nitrogen and phosphorus loading rates	Pounds/acre-year
	Fertilizer nitrogen and phosphorus application rates, reported as elemental N and P	Pounds/acre-year
<p>Other Reporting Requirements: If the nitrogen loading limit from Section 4.3 is calculated using the fraction of times that grass clippings are removed from the site, include the records for clipping removal.</p>		

6.1.3 Submittals

All applications, annual reports, or information submitted to DEQ as required by this permit shall be signed and certified as follows:

1. Permit applications shall be signed by the responsible official as described below:
 - a. For a corporation by a responsible corporate officer
 - b. For a partnership or sole proprietorship by a general partner or the proprietor, respectively
 - c. For a municipality, state, federal, Indian tribe, or other public agency by either the principal executive officer, ranking elected official, or a person of decision-making authority who can legally bind the permittee with respect to the permit.
2. Annual reports and other information required by this permit shall be signed by the responsible official or by a duly authorized representative of that person. A person is a duly authorized representative only if all of the following are true:
 - a. The authorization is made in writing by the responsible official.
 - b. The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual having overall responsibility for environmental matters for the company.
 - c. The written authorization is submitted to DEQ.

Submit all applications, annual reports, and other information required by this permit to the following DEQ regional office at this address:

Engineering Manager
Idaho Department of Environmental Quality
Boise Regional Office
1445 N. Orchard St.
Boise, ID 83705

The annual report, or any other data or monitoring information submitted to DEQ, shall include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative:

"I certify that the information provided in this submittal was prepared in conformance with the Quality Assurance Project Plan required by permit M-196-03, and is to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01 or other enforcement action as provided for under Idaho law."

Permit applications shall include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official:

"I certify that the information provided in this submittal is, to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01, non-issuance of the permit, or other enforcement action as provided for under Idaho law."

Other information submitted to DEQ as required by the permit shall include the above certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative.

6.2 Emergency and Noncompliance Reporting

Report noncompliance incidents to DEQ's regional office at (208) 373-0550 or toll free at (888) 800-3480.

In case of public health emergencies, call the 24-hour Idaho Emergency Medical Services Communications Center number at (800) 632-8000.

Section 8 of this permit and IDAPA 58.01.17.500.06 provide the reporting requirements for facilities.

All instances of permit non-compliance that may endanger public health or the environment and unauthorized discharges to surface waters of the State of Idaho shall be reported to DEQ's regional office by telephone (phone numbers provided in this section) within 24 hours from the time the permittee becomes aware of these events at the phone numbers provided in this section.

A written follow-up shall be provided to the DEQ regional office within five days from the time the permittee became aware of the permit non-compliance or unauthorized discharge.

Reporting of unauthorized discharges to surface waters of the DEQ Idaho Pollutant Discharge Elimination System (IPDES) program may also be required. Contact information for IPDES is provided below:

IPDES Compliance, Inspection, and Enforcement Lead
1410 N. Hilton Street
Boise, ID 83706
833-IPDES24 or 833-473-3724

7. Reserved

8. Standard Permit Conditions

The following standard permit conditions are included as terms of this permit as required by the "Recycled Water Rules," (IDAPA 58.01.17.500).

500. STANDARD PERMIT CONDITIONS.

The following conditions shall apply to and be included in all permits. (4-1-88)

01. Compliance Required. The permittee shall comply with all conditions of the permit. (4-1-88)

02. Renewal Responsibilities. If the permittee intends to continue operation of the permitted facility after the expiration of an existing permit, the permittee shall apply for a new permit in accordance with these rules. (4-1-88)

03. Operation of Facilities. The permittee shall at all times properly maintain and operate all structures, systems, and equipment for treatment, control and monitoring, which are installed or used by the permittee to achieve compliance with the permit or these rules. (4-1-88)

04. Provide Information. The permittee shall furnish to the Director within a reasonable time, any information including copies of records, which may be requested by the Director to determine whether cause exists for modifying, revoking, re-issuing, or terminating the permit, or to determine compliance with the permit or these rules. (4-1-88)

05. Entry and Access. The permittee shall allow the Director, consistent with Title 39, Chapter 1, Idaho Code, to: (4-1-88)

a. Enter the permitted facility. (4-1-88)

b. Inspect any records that must be kept under the conditions of the permit. (4-1-88)

c. Inspect any facility, equipment, practice, or operation permitted or required by the permit. (4-1-88)

d. Sample or monitor for the purpose of assuring permit compliance, any substance or any parameter at the facility. (4-1-88)

06. Reporting. The permittee shall report to the Director under the circumstances and in the manner specified in this section: (4-1-88)

a. In writing at least thirty (30) days before any planned physical alteration or addition to the permitted facility or activity if that alteration or addition would result in any significant change in information that was submitted during the permit application process. When the alteration or addition results in a need for a major modification, such alteration or addition shall not be made prior to Department approval issued in accordance with these rules. (4-7-11)

b. In writing thirty (30) days before any anticipated change which would result in noncompliance with any permit condition or these rules. (4-1-88)

c. Orally within twenty-four (24) hours from the time the permittee became aware of any noncompliance which may endanger the public health or the environment at telephone numbers provided in the permit by the Director. (4-1-88)

d. In writing as soon as possible but within five (5) days of the date the permittee knows or should know of any noncompliance unless extended by the Department. This report shall contain: (4-1-88)

i. A description of the noncompliance and its cause; (4-1-88)

ii. The period of noncompliance including to the extent possible, times and dates and, if the noncompliance has not been corrected, the anticipated length of time it is expected to continue; and (4-7-11)

iii. Steps taken or planned, including timelines, to reduce or eliminate the continuance or reoccurrence of the noncompliance. (4-7-11)

e. In writing as soon as possible after the permittee becomes aware of relevant facts not submitted or incorrect information submitted, in a permit application or any report to the Director. Those facts or the correct information shall be included as a part of this report. (4-1-88)

07. Minimize Impacts. The permittee shall take all necessary actions to eliminate and correct any adverse impact on the public health or the environment resulting from permit noncompliance. (4-1-88)

08. Compliance with "Ground Water Quality Rule." Permits issued pursuant to these rules shall require compliance with IDAPA 58.01.11, "Ground Water Quality Rule." (4-7-11)

9. General Permit Conditions

The following general permit conditions are based on the cited rules at the time of issuance and are enforceable as part of this permit. Note that the rules cited in this section, and elsewhere in this permit, are supplemented by the rules themselves. Rules applicable to your facility are enforceable whether or not they appear in this permit.

9.1 Operations

9.1.1 Backflow Prevention

Reuse facilities with existing or planned cross-connections or interconnections between the recycled water system and any water supply (potable or nonpotable) or surface water, shall have backflow prevention assemblies, devices, or methods as required by applicable rule or as specified in this permit and approved by DEQ.

For public water systems, backflow assemblies shall meet the requirements of IDAPA 58.01.08.543. Assemblies shall be adequately maintained and shall be tested annually by a certified backflow assembly tester, and repaired or replaced as necessary to maintain operational status.

For domestic water supply wells, backflow prevention devices shall meet the requirements of IDAPA 07.02.04 and shall be adequately operated and maintained.

Irrigation water supply wells shall meet the requirements of IDAPA 37.03.09.36 for preventing any waste or contamination of the ground water resource. Backflow prevention assemblies or devices used to protect the ground water shall be adequately operated and maintained.

Discharge of recycled water to surface water is regulated by the EPA NPDES program. An NPDES permit is required for any discharge to surface water and backflow prevention shall be implemented to prevent any unauthorized discharge. Backflow prevention assemblies or devices used to protect surface water shall be adequately operated and maintained.

Records of all testable backflow assembly test results, repairs, and replacements shall be kept at the reuse facility along with other operational records, and shall be discussed in the Annual Report and made available for inspection by DEQ. Other approved means of backflow prevention, such as siphons and air-gap structures that cannot be tested, shall be maintained in operable order.

9.1.2 Restricted to Premises

Wastewaters or recharge waters applied to the land surface must be restricted to the premises of the application site. Wastewater discharges to surface water that require a permit under the Clean Water Act must be authorized by the United States Environmental Protection Agency (IDAPA 58.01.16.600.02).

9.1.3 Health Hazards, Nuisances, and Odors Prohibited

Health hazards, nuisances, and odors are prohibited as follows:

- Wastewater must not create a public health hazard or nuisance condition (IDAPA 58.01.16.600.03).
- No person shall allow, suffer, cause or permit the emission of odorous gases, liquids, or solids into the atmosphere in such quantities as to cause air pollution (IDAPA 58.01.01.776.01).
 - Air Pollution. The presence in the outdoor atmosphere of any air pollutant or combination thereof in such quantity of such nature and duration and under such conditions as would be injurious to human health or welfare, to animal or plant life, or to property, or to interfere unreasonably with the enjoyment of life or property (IDAPA 58.01.01.006.06).

9.1.4 Solids Management

Biosolids are the nutrient-rich organic materials resulting from the treatment of sewage sludge. When treated and processed, sewage sludge becomes biosolids which can be safely recycled and applied as fertilizer to sustainably improve and maintain productive soils and stimulate plant growth.

Biosolids generated from sewage sludge are regulated by EPA under 40 CFR Part 503 and require a DEQ approved sludge disposal plan as outlined in IDAPA 58.01.16.650. Contact DEQ prior to application of biosolids at any permitted reuse facility.

Sludge is the semi-liquid mass produced and removed by wastewater treatment processes. This does not include grit, garbage, and large solids.

Sludge may be generated by wastewater treatment processes at municipal and industrial facilities. A DEQ-approved sludge disposal plan, as outlined in IDAPA 58.01.16.650, may be required.

Solid Waste is any garbage or refuse, sludge from a waste water treatment plant, water supply treatment plant, or air pollution control facility and other discarded material including solid, liquid, semi-solid, or contained gaseous material resulting from industrial, commercial, mining, and agricultural operations and from community activities, but does not include solid or dissolved materials in domestic sewage, or solid or dissolved material in irrigation return flows or industrial discharges which are point sources subject to permits under Section 402 of the Federal Water Pollution Control Act, as amended or source, special nuclear, or by-product material as defined by the Atomic Energy Act of 1954, as amended.

Solid waste does not include inert wastes, manures and crop residues ultimately returned to the soils at agronomic rates, and any agricultural solid waste which is managed and regulated pursuant to rules adopted by the Idaho Department of Agriculture. DEQ reserves the right to use existing authorities to regulate agricultural waste that impacts human health or the environment.

Solid waste is regulated under IDAPA 58.01.06, "Solid Waste Management Rules". Wastes otherwise regulated by DEQ (i.e. this permit) are not regulated under 58.01.06.

Waste Solids include sludge and wastes otherwise regulated by DEQ in accordance with IDAPA 58.01.06.001.03.a.xii. Waste solids may include vegetative waste, silt and mud containing organic matter, and other non-inert solid wastes.

Inert wastes are defined as non-combustible, nonhazardous, and non-putrescible solid wastes that are likely to retain their physical and chemical structure and have a deminimis potential to generate leachate under expected conditions of disposal, which includes resistance to biological attack.

Waste solids require a DEQ approved sludge disposal plan as outlined in IDAPA 58.01.16.650.

9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801)

Temporary cessation of operations and closure must be addressed as follows:

01. Temporary Cessation. A permittee shall implement any applicable conditions specified in the permit for temporary cessation of operations. When the permit does not specify applicable temporary cessation conditions, the permittee shall notify the Director prior to a temporary cessation of operations at the facility greater than sixty (60) days in duration and any cessation not for regular maintenance or repair. Cessation of operations necessary for regular maintenance or repair of a duration of sixty (60) days or less are not required to notify the Department under this section. All notifications required under this section shall include a proposed temporary cessation plan that will ensure the cessation of operations will not pose a threat to human health or the environment. (4-7-11)

02. Closure. A closure plan shall be required when a facility is closed voluntarily and when a permit is revoked or expires. A permittee shall implement any applicable conditions specified in the permit for closure of the facility. Unless otherwise directed by the terms of the permit or by the Director, the permittee shall submit a closure plan to the Director for approval at least ninety (90) days prior to ceasing operations. The closure plan shall ensure that the closed facility will not pose a threat to human health and the environment. Closure plan approval may be conditioned upon a permittee's agreement to complete such site investigations, monitoring, and any necessary remediation activities that may be required. (4-7-11)

9.1.6 Plan of Operation (IDAPA 58.01.17.300.05)

The PO must comply with the following:

05. Reuse Facility Operation and Maintenance Manual or Plan of Operations. A facility's operation and maintenance manual must contain all system components relating to the reuse facility in order to comply with IDAPA 58.01.16 "Wastewater Rules," Section 425. Manuals and manual amendments are subject to the review and approval provision therein. In addition to the content required by IDAPA 58.01.16.425, manuals for reuse facilities shall include, if applicable: operation and management responsibility, permits and standards, general plant description, operation and control of unit operations, land application site maps, wastewater characterization, cropping plan, hydraulic loading rate, constituent loading rates, compliance activities, seepage rate testing, site management plans, monitoring, site operations and maintenance, solids handling and processing, laboratory testing, general maintenance, records and reports, store room and inventory, personnel, an emergency operating plan, and any other information required by the Department. (4-7-11)

9.1.7 Seepage Testing Requirements (IDAPA 58.01.16.493.02.c)

Subsequent Tests. All lagoons covered under these rules must be seepage tested by an Idaho licensed professional engineer, an Idaho licensed professional geologist, or by individuals under their supervision every ten (10) years after the initial testing. (5-8-09)

9.1.8 Ground Water Quality Rule (IDAPA 58.01.11)

The permittee shall comply with the requirements of “Ground Water Quality Rule” (IDAPA 58.01.11).

9.2 Administrative

Requirements for administration of the permit are defined as follows.

9.2.1 Permit Modification (IDAPA 58.01.17.700)

01. Modification of Permits. A permit modification may be initiated by the receipt of a request for modification from the permittee, or may be initiated by the Department if one (1) or more of the following causes for modification exist: (4-7-11)

a. Alterations. There are material and substantial alterations or additions to the permitted facility or activity which occurred after permit issuance which justify the application of permit conditions that are different or absent in the existing permit. (4-7-11)

b. New standards or regulations. The standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued. (4-7-11)

c. Compliance schedules. The Department determines good cause exists for modification of a compliance schedule or terms and conditions of a permit. (4-7-11)

d. Non-limited pollutants. When the level of discharge of any pollutant which is not limited in the permit exceeds the level which may cause an adverse impact to surface or ground waters. (4-7-11)

e. To correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions. (4-7-11)

f. When a treatment technology proposed, installed, and properly operated and maintained by the permittee fails to achieve the requirements of the permit. (4-7-11)

9.2.2 Permit Transferable (IDAPA 58.01.17.800)

01. General. A permit may be transferred only upon approval of the Department. No transfer is required for a corporate name change as long as the secretary of state can verify that a change in name alone has occurred. An attempted transfer is not effective for any purpose until approved in writing by the Department. (4-7-11)

9.2.3 Permit Revocation (IDAPA 58.01.17.920)

01. Conditions for Revocation. The Director may revoke a permit if the permittee violates any permit condition or these rules, or the Director becomes aware of any omission or misrepresentation of condition or information relied upon when issuing the permit. (4-7-11)

02. Notice of Revocation. Except in cases of emergency, the Director shall issue a written notice of intent to revoke to the permittee prior to final revocation. Revocation shall become final within thirty-five (35) days of receipt of the notice by the permittee, unless within that time the permittee requests an administrative hearing in writing. The hearing shall be conducted in accordance with IDAPA 58.01.23, Rules of Administrative Procedure

before the Board of Environmental Quality.”

(5-3-03)

03. Emergency Action. If the Director finds the public health, safety or welfare requires emergency action, the Director shall incorporate findings in support of such action in a written notice of emergency revocation issued to the permittee. Emergency revocation shall be effective upon receipt by the permittee. Thereafter, if requested by the permittee in writing, the Director shall provide the permittee a revocation hearing and prior notice thereof. Such hearings shall be conducted in accordance with IDAPA 58.01.23, “Rules of Administrative Procedure Before the Board of Environmental Quality.”

(3-15-02)

04. Revocation and Closure. A permittee shall perform the closure requirements in a permit, the closure requirements of these rules, and complete all closure plan activities notwithstanding the revocation of the permit.

(4-7-11)

9.2.4 Violations (IDAPA 58.01.17.930)

Any person violating any provision of these rules or any permit or order issued thereunder shall be liable for a civil penalty not to exceed ten thousand dollars (\$10,000) or one thousand dollars (\$1,000) for each day of a continuing violation, whichever is greater. In addition, pursuant to Title 39, Chapter 1, Idaho Code, any willful or negligent violation may constitute a misdemeanor.

(4-1-88)

9.2.5 Severability

The provisions of this permit are severable, and if a provision or its application is declared invalid or unenforceable for any reason, that declaration will not affect the validity or enforceability of the remaining provisions.

10. Other Applicable Laws

DEQ may refer enforcement of the following provisions to the state agency authorized to enforce that rule. The permittee shall comply with all applicable provisions identified in this section. Compliance with this permit does not relieve the permittee from applicable requirements in other federal, state, and local laws, statutes, and rules.

10.1 Owner Responsibilities for Well Use and Maintenance

10.1.1 Well Use

The well owner must not operate any well in a manner that causes waste or contamination of the ground water resource. Failure to operate, maintain, knowingly allow the construction of any well in a manner that violates these rules, or failure to repair or properly decommission (abandon) any well as herein required will subject the well owner to civil penalties as provided by statute. See IDAPA 37.03.09.036.01 and consult the Idaho Department of Water Resources (IDWR) for more information.

10.1.2 Well Maintenance


The well owner must maintain the well to prevent waste or contamination of ground waters through leaky casings, pipes, fittings, valves, pumps, seals, or through leakage around the outside of the casings, whether the leakage is above or below the land surface. Any person owning or controlling a noncompliant well must have the well repaired by a licensed well driller under a permit issued by the IDWR director in accordance with the applicable rules. See IDAPA 37.03.09.036.02 and consult IDWR for more information.

10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Ground Water Resource


The well owner must have any well shown to pose a threat to human health and safety or cause contamination of the ground water resource immediately repaired or decommissioned (abandoned) by a licensed well driller under a permit issued by the IDWR director in accordance with the applicable rules. See IDAPA 37.03.09.036.06 and consult the IDWR for more information.

11. Site Maps


11.1 Regional Map



11.2 Facility Map(s)



Garden Valley School District
M-196-03



Legend	
	Monitoring Well
	Stream
	Highway
	Major Roads
	Lagoon
	Reuse

11.3 Process Flow Diagram with Sampling Points

