

Idaho Department of Environmental Quality Reuse Permit M-186-02

(Previous Permit No. LA-000186-01)

Stonebriar Homeowners Association, Inc. (hereafter "permittee") is hereby authorized to construct, install, and operate a reuse facility in accordance with (1) this permit; (2) IDAPA 58.01.17 "Recycled Water Rules"; (3) an approved plan of operation; and (4) all other applicable federal, state, and local laws, statutes, and rules. This permit is effective from December 23, 2019 and expires on December 23, 2024.


Signature

December 23, 2019

Date

Aaron Scheff

Regional Administrator
Boise Regional Office
Idaho Department of Environmental Quality

Idaho Department of Environmental Quality
Boise Regional Office
1445 North Orchard Street, Boise, Idaho 83706
(208) 373-0550

This page intentionally left blank for correct double-sided printing.

Table of Contents

1. Common Acronyms/Abbreviations and Definitions	5
2. Facility Information	7
3. Compliance Schedule for Required Activities.....	8
4. Permit Limits and Conditions	10
4.1 Management Unit Descriptions	10
4.2 Hydraulic Loading Limits – not applicable	11
4.3 Constituent Loading Limits	11
4.4 Management Unit Buffer Zones	11
4.5 Other Permit Limits and Conditions.....	12
5. Monitoring Requirements	14
5.1 Recycled Water Sampling and Analyses	14
5.1.1 Constituent Monitoring.....	14
5.1.2 Management Unit and Other Flow Monitoring.....	15
5.2 Ground Water Monitoring – not required	15
5.3 Soil Monitoring – not required	15
5.4 Crop Monitoring – not required	15
5.5 Lagoon Information	15
6. Reporting Requirements	16
6.1 Annual Report Requirements.....	16
6.1.1 Due Date	16
6.1.2 Required Contents	16
6.1.3 Submittals	17
6.2 Emergency and Noncompliance Reporting	18
7. Reserved.....	19
8. Standard Permit Conditions	19
9. General Permit Conditions.....	21
9.1 Operations	21
9.1.1 Backflow Prevention	21
9.1.2 Restricted to Premises	21
9.1.3 Health Hazards, Nuisances, and Odors Prohibited.....	22
9.1.4 Solids Management	22
9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801).....	23
9.1.6 Plan of Operation (IDAPA 58.01.17.300.05).....	23
9.1.7 Reserved.	23
9.1.8 Ground Water Quality Rule (IDAPA 58.01.11).....	23
9.2 Administrative.....	24
9.2.1 Permit Modification (IDAPA 58.01.17.700).....	24
9.2.2 Permit Transferable (IDAPA 58.01.17.800)	24
9.2.3 Permit Revocation (IDAPA 58.01.17.920)	24
9.2.4 Violations (IDAPA 58.01.17.930).....	25
9.2.5 Severability.....	25
10. Other Applicable Laws	26

10.1 Owner Responsibilities for Well Use and Maintenance	26
10.1.1 Well Use	26
10.1.2 Well Maintenance	26
10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Ground Water Resource	26
11. Site Maps	27
11.1 Regional Map	27
11.2 Facility Map	28
11.3 Process Flow Diagram	28

1. Common Acronyms/Abbreviations and Definitions

BOD ₅	5-day biological oxygen demand
CA	compliance activity
crop uptake	those constituents assimilated by the crop from the soil, and those from applied fertilizer, biosolids and other soil amendments, recycled water, irrigation water, and other sources. Crop uptake excludes those constituents assimilated from the atmosphere, such as gaseous nitrogen fixed by legumes. Crop uptake plus atmospheric assimilated constituents equals crop content.
DEQ	Idaho Department of Environmental Quality
director	DEQ director or designee unless otherwise specified
EDU	Equivalent Dwelling Unit
E _i	irrigation efficiency
EPA	United States Environmental Protection Agency
GW	prefix for ground water reporting serial number
IDAPA	Numbering designation for all administrative rules in Idaho promulgated according to the Idaho Administrative Procedure Act
IDWR	Idaho Department of Water Resources
IPDES	Idaho Pollutant Discharge Elimination System
IWR	irrigation water requirement — any combination of wastewater and supplemental irrigation water applied at rates commensurate to the moisture requirements of the crop, and calculated monthly during the growing season.
lb	pound
LG	prefix for lagoon reporting serial number
MG	million gallons
mg/kg	milligram per kilogram
mg/L	milligram per liter
mL	milliliter
MU	management unit, prefix for management unit reporting environmental serial number
NTU	nephelometric turbidity unit
N	nitrogen
ppm	parts per million
P	phosphorus

PO	plan of operation
QAPP	quality assurance project plan
responsible official	facility contact person authorized by the permittee to communicate with DEQ on behalf of the permittee on any matter related to the permit, including without limitation, the authority to communicate with and receive notices from DEQ regarding notices of violation or non-compliance, permit violations, permit enforcement, and permit revocation. The responsible official provides written certification of permit application materials, annual report submittals, and other information submitted to DEQ as required by the permit. Any notice to or communication with the responsible official is considered a notice to or communication with the permittee. The responsible official may designate an authorized representative to act as the facility contact person for any of the activities or duties related to the permit, except signing and certifying the permit application, which must be done by the responsible official. The authorized representative shall act as the responsible official and shall bind the permittee as described in this definition. Designation of the authorized representative shall follow the requirements specified in section 6.1.3 of the permit.
WW	prefix for wastewater reporting serial number
SSWD	Star sewer and water district
yr	year

2. Facility Information

Information Type	Information Specific to This Permit
Class of recycled water	Class B
Method of treatment and reuse	Sequencing Batch Reactor (biological treatment), coagulation, sand filtration, and UV disinfection. UV disinfection will be converted to chlorine disinfection in CA-186-03. GS land application to common area turf. NGS discharge to a landscape pond impoundment.
Collection and treatment system classification	Wastewater collection system classification: I Wastewater treatment system classification: II Land Application/Reuse
Facility location	8165 N. Stonebriar Lane Meridian, ID 83646
Facility mailing address	Stonebriar Homeowners Association, Inc. PO Box 810 Star, ID 83669
Facility responsible official and facility contact	Responsible Official: Daniela Hansell, President (208) 286-0563 Facility Contact: Jan Rose, Star Property Management (208) 286-9666 Notify DEQ within 30 days if a change in personnel occurs for any of the facility contacts. DEQ will issue a minor permit modification to confirm the change.
Ground water	The Boise Valley Aquifer is 1.3 to 6 feet below ground surface, saturated to a depth of 30 feet, and underlain by clay and sandy clay. Ground water flows north west
Surface water	The Boise River flows along the north boundary of the WWTP. Beneficial uses: cold water aquatic life, salmonid spawning, primary contact recreation, domestic water supply (IDAPA 58.01.02.140.12.17050114). Also agricultural water supply, industrial water supply, wildlife habitats, and aesthetics (IDAPA 58.01.02.100.03, 04, and 05). The Main Eureka Canal and Phyllis slough cross through the property.

3. Compliance Schedule for Required Activities

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-186-01 One (1) year after permit issuance	<p>Plan of Operation (PO): The permittee shall submit to DEQ for review and approval a PO that reflects current operations including the Wastewater Compliance Improvements in CA-186-03, and incorporates the requirements of this permit. The PO shall incorporate the Operations & Maintenance manual, shall comply with the applicable requirements stated in IDAPA 58.01.17.300.05 and shall address applicable items in the PO checklist in the DEQ <i>Guidance for Reclamation and Reuse of Municipal and Industrial Wastewater</i> (reuse guidance).</p> <p>The PO shall include the following site management plans or the permittee may submit the site management plans individually:</p> <ol style="list-style-type: none"> 1. Buffer zone plan when there are plans to develop Lot 9. 2. Turf management plan 3. Emergency operating plan 4. Irrigation management and scheduling plan 5. Nuisance and odor management plan 6. Runoff management plan 7. Well location acceptability analysis <p>The permittee shall submit for review and approval a well location acceptability analysis (WLAA) for all wells within a half mile of the reuse site. The WLAA should be completed by following the methodology in the reuse guidance.</p> <ol style="list-style-type: none"> 8. Waste solids management plan <p>The PO shall be updated as needed to reflect current operations. The permittee shall notify DEQ of material changes to the PO and copies shall be kept on site and made available to DEQ upon request.</p>

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-186-02 One (1) year after permit issuance	<p>Quality Assurance Project Plan (QAPP): The permittee shall prepare and implement a QAPP that incorporates all monitoring and reporting required by this permit. A copy of the QAPP along with written notice that the permittee has implemented the QAPP shall be provided to DEQ. The Permittee must follow the QAPP when collecting, analyzing, and reporting monitoring data submitted to DEQ.</p> <p>The QAPP shall be designed to assist in planning for collecting, analyzing, and reporting all monitoring in support of this permit and in explaining data anomalies when they occur. At a minimum, the QAPP must include the following:</p> <ol style="list-style-type: none"> 1. Details on the number of measurements, number of samples, type of sample containers, preservation of samples, holding times, analytical methods, analytical detection and quantitation limits for each target compound, type and number of quality assurance field samples, precision and accuracy requirements, sample preparation requirements, sample shipping methods, and laboratory data delivery requirements 2. Maps indicating the location of each monitoring and sampling point 3. Qualification and training of personnel 4. Names, addresses, and telephone numbers of the laboratories used by or proposed to be used by the permittee 5. Example formats and tables that will be used by the permittee to summarize and present all data in the annual report <p>The format and content of the QAPP should adhere to the recommendations and references in the Quality Assurance and Data Processing sections of the reuse guidance.</p> <p>The permittee shall amend the QAPP whenever there is a modification in sample collection, sample analysis, or other procedure addressed by the QAPP. The permittee shall notify DEQ of material changes to the QAPP and copies shall be kept on site and made available to DEQ upon request.</p>

Compliance Activity (CA) Number and Completion Due Date	Compliance Activity Description
CA-186-03 As specified	<p>Wastewater Compliance Improvements: The facility shall complete the Wastewater Compliance Improvements in accordance with the plans and specifications as approved by DEQ in a letter dated April 5, 2019 by the dates listed below. Within 30 days of completion, submit the record drawings to DEQ, as required in the Construction plans condition in Section 4.5 of this permit.</p> <p>Phase I: Submit the as-built record drawings for the isolation of LG-186-01 by <u>within 30 days of completion of construction</u>.</p> <p>Phase II: Install reuse irrigation upgrades, including: recycled water storage tank, chlorine disinfection, recycled water irrigation lines to MU-186-01, backflow prevention, and distribution system identification and signage as approved. <u>Shall be completed by October 31st 2020.</u></p> <p>Phase III: Wastewater Treatment Plant upgrades: including dual-train SBR and equalization tank for treatment capacity redundancy, and automatic effluent rejection and retreatment for when the turbidity limit is exceeded. <u>The facility shall submit written notification to DEQ within 30 days of becoming aware that connection to a community sewer is no longer feasible, and project completion shall be due within 18 months of the notification letter date.</u></p>
CA-186-04 180 days prior to permit expiration	<p>Pre-application Conference: If the permittee intends to continue operating the reuse facility beyond the expiration date of this permit, the permittee shall contact DEQ and schedule a pre-application conference to discuss the compliance status of the facility and the content required for the reuse permit application package.</p>
CA-186-05 1 year prior to permit expiration	<p>Permit Renewal Application: The permittee shall submit to DEQ a complete permit renewal application package that fulfills the requirements specified in CA-186-04 and identified at the pre-application conference.</p>

4. Permit Limits and Conditions

4.1 Management Unit Descriptions

Serial Number	Description	Irrigation System Type and Irrigation Efficiency (E _i)	Maximum Acres ^a Allowed
MU-186-01	Common Area Irrigation	Sprinkler system (E _i = 0.80)	1.9
Total acreage			1.9

- a. Maximum acres represent the total permitted acreage of the MU as provided by the permittee. If the permittee uses less acreage in any season or year, then loading rates shall be presented and compliance shall be determined based on the actual acreage used during each season or year.

4.2 Hydraulic Loading Limits – not applicable

Serial Number	Description	Growing Season Hydraulic Loading	Non-Growing Season Hydraulic Loading
MU-186-01	Common Area Irrigation	Not applicable	Not allowed

4.3 Constituent Loading Limits

Serial Number	Constituent Loading from All Sources	
	Nitrogen (lb/acre)	Non-volatile dissolved solids (lb/acre)
MU-186-01	No GS loading limit at this time ^a	Not Applicable

- a. In the event that DEQ determines that nitrogen limits are necessary, DEQ shall issue a draft modification to the permit and a staff analysis, and shall process the modifications as provided in IDAPA 58.01.17.700.

4.4 Management Unit Buffer Zones

Serial Number	Buffer Distances (feet) from Management Units					
	Public Water Supplies	Private Water Supplies	Inhabited Dwellings	Permanent and Intermittent Surface Water	Irrigation Ditches and Canals	Areas Accessible to the Public
MU-186-01	100	100	100	20 ^a	20 ^a	0

- a. No Class B recycled water may enter surface waters unless an IPDES discharge permit authorizing the discharge is in place.

4.5 Other Permit Limits and Conditions

Category	Permit Limits and Conditions
Growing season	April 1 through October 31 (214 days)
Nongrowing season	November 1 through March 31 (151 days)
Reporting year for annual loading rates	November 1 through October 31
Sewer Connection	No additional sewer connections beyond 13 homes are allowed
GS Land Application period	Recycled water land application shall only be allowed during the growing season between 12AM and 6AM.
Disinfection limits in recycled water	Class B: The median number of total coliform organisms shall not exceed 2.2 total coliform organisms/100 mL, as determined from the bacteriological results of the last seven days for which analyses have been completed. No sample shall exceed 23 total coliform organisms/100 mL in any confirmed sample.
Turbidity	The daily arithmetic mean of all measurements of turbidity shall not exceed two (2) NTU, and turbidity shall not exceed five (5) NTU at any time. Following completion of phase III of CA-186-03 an alternative back-up system must be automatically activated if turbidity exceeds the instantaneous required value for more than five (5) minutes.
Total Chlorine Residual	Chlorine residual at the point of compliance shall not be less than one (1) mg/L total chlorine residual after a contact time of thirty (30) minutes at peak flow.
Total Nitrogen in Recycled Water	Total nitrogen shall not exceed 10 mg/L during Pond 5 discharge This limit is based on a seasonal average as determined from weekly composite sampling.
5-day Biochemical Oxygen Demand in Recycled Water	BOD ₅ shall not exceed 5 mg/L during the Non-Growing Season This limit is based on a monthly arithmetic mean as determined from weekly composite sampling.
pH in Recycled Water	The pH shall be between 6.0 and 9.0
Operator certification and endorsement	The wastewater treatment facility and reuse system shall be operated by personnel certified and licensed in the State of Idaho wastewater operator training program at the operator class level specified in IDAPA 58.01.16.203 and properly trained to operate and maintain the system.
Posting	Signs shall read "Caution: Recycled Water—Do Not Drink," or equivalent signage both in English and Spanish. Signs to be posted at least every 500 feet and at each corner of the outer perimeter of the irrigated site.

Category	Permit Limits and Conditions
Construction plans	Pursuant to Idaho Code §39-118, IDAPA 58.01.16, and IDAPA 58.01.17, detailed plans and specifications shall be submitted to DEQ for review and approval before construction, modification, or expansion of any wastewater treatment, storage, conveyance structures, ground water monitoring wells, or reuse facility. Inspection requirements shall be satisfied, and within 30 days of completion of construction, the permittee shall submit as-built plans or a letter from a professional engineer licensed in the State of Idaho certifying the facilities or structures were constructed in substantial accordance with the approved plans and specifications.
Valve Covers	Valve Boxes and Other Surface Identification. All valves shall have locking valve covers that are non-interchangeable with potable water valve covers, and shall have an inscription cast on the top surface stating "Recycled Water."
Records retention requirements	Keep records generated to meet the requirements of this permit for the duration of the permit, including administrative extensions, plus 2 years.
LG-186-01 Discharge	Discharge to LG-186-01 shall be limited to the non-growing season after CA-186-03 Phase II completion A high-level alarm is required to prevent an overflow of the pumping tank to Pond No. 5 during the growing season. An overflow to Pond No. 5 during the growing season shall be reported as a non-compliance event in accordance with Section 6.2.
Closure Plan	If the facility establishes a commitment to connect to a municipal wastewater collection system, such as the Star Sewer and Water District, then the facility shall submit a closure plan to DEQ for approval at least 90 days prior to ceasing operations in accordance with Section 9.1.5.

5. Monitoring Requirements

5.1 Recycled Water Sampling and Analyses

5.1.1 Constituent Monitoring

Monitoring Point Serial Number and Location	Sample Description	Sample Type and Frequency	Constituents (mg/L unless otherwise specified)
WW-186-01 Filtered Effluent	Effluent following filtration but before disinfection	In-line monitoring and recording turbidimeter / continuous	Turbidity (NTU)
WW-186-02 Disinfected Effluent	Recycled water to MU-186-01 or LG-186-01	Grab / three times per week	Total coliform (organisms per 100 mL)
WW-186-02 Disinfected Effluent	Recycled water to MU-186-01 or LG-186-01	Inline monitoring and continuous recording, or grab three times per week	Total chlorine residual pH
WW-186-02 Disinfected Effluent	Growing Season Recycled water to MU-186-01	Grab / weekly	BOD ₅
WW-186-02 Disinfected Effluent	Growing Season Recycled water to MU-186-01	Composite ^a / monthly (during periods of use)	Total nitrogen Total phosphorus
WW-186-02 Disinfected Effluent	Recycled Water to LG-186-01	Composite ^a / weekly	Total nitrogen BOD ₅
WW-186-02 Disinfected Effluent	Recycled Water to LG-186-01	Composite ^a / monthly	Total phosphorus
WW-186-02 Disinfected Effluent	Recycled water to MU-186-01 or LG-186-01	Composite ^a / monthly for one year following permit issuance (January- December 2020)	TDS VDS NVDS (as calculated)

- a. Each composite sample shall contain a minimum of three grab samples. Each grab sample must be taken on a different date. The annual report shall contain the dates grab samples were taken for each composite sample.

5.1.2 Management Unit and Other Flow Monitoring

Management Unit or Flow Measurement Serial Number and Location	Sample Description	Sample Type and Frequency	Parameters, each MU or FM
FM-186-01 Flow meter	Recycled Water to LG-186-01	Daily meter reading Monthly compilation of data	Volume (gal/day, gal/month)
FM-186-02 Flow Meter	Recycled Water to MU-186-01	Daily meter reading Monthly compilation of data	Volume (gal/day, gal/month)
FM-186-03 Flow Meter (following completion of CA-186-03)	Sand Filter Reject	Daily meter reading Monthly compilation of data	Volume (gal/day, gal/month)

5.2 Ground Water Monitoring – not required

5.3 Soil Monitoring – not required

5.4 Crop Monitoring – not required

5.5 Lagoon Information

Serial number	Description	Surface Area, acres	Maximum Operating Volume, MG	Liner Type
LG-186-01	Pond ^a 5	0.64	1.66 MG	Unlined

a. Pond 5 is an unlined landscape impoundment and is not required to be seepage tested.

6. Reporting Requirements

6.1 Annual Report Requirements

The permittee shall submit to DEQ an annual report prepared by a competent environmental professional covering the previous reporting year.

6.1.1 Due Date

The annual report is due no later than January 31 of each year, which shall cover the previous reporting year.

6.1.2 Required Contents

The annual report shall include the following:

1. Detailed results of the required monitoring as described in section 5 of this permit. The report shall present all monitoring data in summary tables to expedite review. If the permittee monitors any parameter for compliance purposes more frequently than required by this permit, the results of this monitoring shall be included in the calculation and reporting of the data submitted in the annual report.
2. A brief interpretive discussion of the results of all required monitoring data as specified by section 5. The discussion shall address data quality objectives, validation, and verification; explain what the data say about permit compliance; and reuse facility environmental impacts. The reporting year for this permit is specified in section 4.5.
3. Status of all work described in section 3 of this permit.
4. Results of all backflow testing, repairs, and replacements required by section 9.1.1 of this permit.
5. Discussion of major maintenance activities such as major equipment replacement, lagoon liner maintenance, and wastewater treatment and reuse facility maintenance.
6. A summary of all noncompliance events that occurred during the reporting year. Examples of noncompliance events that must be discussed include, but are not limited to: exceedance of permit limits, complaints, missed monitoring events, incorrect monitoring dates or frequencies, dry monitoring wells, uncontained spills causing runoff, construction without DEQ engineering plan approval, construction without engineering inspection, and reporting incorrect acreage.
7. Laboratory analytical reports that show results, analytical methods, and practical quantitation limits for monitoring specified in section 5 of the permit. Chain of custody forms, supporting information for laboratory analytical reports, and quality assurance documentation shall be available for review upon request by DEQ.
8. The calculations and results for the parameters in the following table:

Monitoring Point Serial Number	Parameter (Calculate for each MU)	Units
WW-186-02	Total nitrogen seasonal average as calculated from weekly sampling	mg/L
WW-186-02	Monthly BOD ₅ as calculated from weekly sampling	mg/L
Declining Balance Report	EDU Connections	Number of EDU connections at end of reporting year
Other Reporting Requirements: <ul style="list-style-type: none"> • Delineation and discussion of instances of overflow to Pond 5 during the growing season. • Delineation and discussion of instances of reject for high turbidity. 		

6.1.3 Submittals

All applications, annual reports, or information submitted to DEQ as required by this permit shall be signed and certified as follows:

- Permit applications shall be signed by the responsible official as described below:
 - For a corporation by a responsible corporate officer
 - For a partnership or sole proprietorship by a general partner or the proprietor, respectively
 - For a municipality, state, federal, Indian tribe, or other public agency by either the principal executive officer, ranking elected official, or a person of decision-making authority who can legally bind the permittee with respect to the permit.
- Annual reports and other information required by this permit shall be signed by the responsible official or by a duly authorized representative of that person. A person is a duly authorized representative only if all of the following are true:
 - The authorization is made in writing by the responsible official.
 - The authorization specifies either an individual or position having responsibility for the overall operation of the regulated facility, such as the position of plant manager, superintendent, position of equivalent responsibility, or an individual having overall responsibility for environmental matters for the company.
 - The written authorization is submitted to DEQ.

Submit all applications, annual reports, and other information required by this permit to the following DEQ regional office at this address:

Engineering Manager
 Idaho Department of Environmental Quality
 Boise Regional Office
 1445 N. Orchard Street
 Boise, ID 83706

The annual report, or any other data or monitoring information submitted to DEQ, shall include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative:

"I certify that the information provided in this submittal was prepared in conformance with the Quality Assurance Project Plan required by this permit and is to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01 or other enforcement action as provided for under Idaho law."

Permit applications shall include the following certification statement and be signed, dated, and certified by the permittee's Responsible Official:

"I certify that the information provided in this submittal is, to the best of my knowledge, true, accurate and complete and I acknowledge that knowing submission of false or incomplete information may result in permit revocation as provided for in IDAPA 58.01.17.920.01, non-issuance of the permit, or other enforcement action as provided for under Idaho law."

Other information submitted to DEQ as required by the permit shall include the above certification statement and be signed, dated, and certified by the permittee's Responsible Official or duly Authorized Representative.

6.2 Emergency and Noncompliance Reporting

Report noncompliance incidents to DEQ's regional office at (208) 373-0550 or toll free at (888) 800-3480.

In case of public health emergencies, call the 24-hour Idaho Emergency Medical Services Communications Center number at (800) 632-8000.

Section 8 of this permit and IDAPA 58.01.17.500.06 provide the reporting requirements for facilities.

All instances of permit non-compliance that may endanger public health or the environment and unauthorized discharges to surface waters of the State of Idaho shall be reported to DEQ's regional office by telephone (phone numbers provided in this section) within 24 hours from the time the permittee becomes aware of these events at the phone numbers provided in this section.

A written follow-up shall be provided to the DEQ regional office within five days from the time the permittee became aware of the permit non-compliance or unauthorized discharge.

Reporting of unauthorized discharges to surface waters of the DEQ Idaho Pollutant Discharge Elimination System (IPDES) program may also be required. Contact information for IPDES is provided below:

IPDES Compliance, Inspection, and Enforcement Lead
1410 N. Hilton Street
Boise, ID 83706
833-IPDES24 (833-473-3724)

7. Reserved

8. Standard Permit Conditions

The following standard permit conditions are included as terms of this permit as required by the "Recycled Water Rules," (IDAPA 58.01.17.500).

500. STANDARD PERMIT CONDITIONS.

The following conditions shall apply to and be included in all permits. (4-1-88)

- 01. Compliance Required.** The permittee shall comply with all conditions of the permit. (4-1-88)
- 02. Renewal Responsibilities.** If the permittee intends to continue operation of the permitted facility after the expiration of an existing permit, the permittee shall apply for a new permit in accordance with these rules. (4-1-88)
- 03. Operation of Facilities.** The permittee shall at all times properly maintain and operate all structures, systems, and equipment for treatment, control and monitoring, which are installed or used by the permittee to achieve compliance with the permit or these rules. (4-1-88)
- 04. Provide Information.** The permittee shall furnish to the Director within a reasonable time, any information including copies of records, which may be requested by the Director to determine whether cause exists for modifying, revoking, re-issuing, or terminating the permit, or to determine compliance with the permit or these rules. (4-1-88)
- 05. Entry and Access.** The permittee shall allow the Director, consistent with Title 39, Chapter 1, Idaho Code, to:
 - a.** Enter the permitted facility. (4-1-88)
 - b.** Inspect any records that must be kept under the conditions of the permit. (4-1-88)
 - c.** Inspect any facility, equipment, practice, or operation permitted or required by the permit. (4-1-88)
 - d.** Sample or monitor for the purpose of assuring permit compliance, any substance or any parameter at the facility. (4-1-88)
- 06. Reporting.** The permittee shall report to the Director under the circumstances and in the manner specified in this section:
 - a.** In writing at least thirty (30) days before any planned physical alteration or addition to the permitted facility or activity if that alteration or addition would result in any significant change in information that was submitted during the permit application process. When the alteration or addition results in a need for a major modification, such alteration or addition shall not be made prior to Department approval issued in accordance with these rules. (4-7-11)
 - b.** In writing thirty (30) days before any anticipated change which would result in noncompliance with any permit condition or these rules. (4-1-88)
 - c.** Orally within twenty-four (24) hours from the time the permittee became aware of any noncompliance which may endanger the public health or the environment at telephone numbers provided in the permit by the Director. (4-1-88)

d. In writing as soon as possible but within five (5) days of the date the permittee knows or should know of any noncompliance unless extended by the Department. This report shall contain: (4-1-88)

i. A description of the noncompliance and its cause; (4-1-88)

ii. The period of noncompliance including to the extent possible, times and dates and, if the noncompliance has not been corrected, the anticipated length of time it is expected to continue; and (4-7-11)

iii. Steps taken or planned, including timelines, to reduce or eliminate the continuance or reoccurrence of the noncompliance. (4-7-11)

e. In writing as soon as possible after the permittee becomes aware of relevant facts not submitted or incorrect information submitted, in a permit application or any report to the Director. Those facts or the correct information shall be included as a part of this report. (4-1-88)

07. Minimize Impacts. The permittee shall take all necessary actions to eliminate and correct any adverse impact on the public health or the environment resulting from permit noncompliance. (4-1-88)

08. Compliance with "Ground Water Quality Rule." Permits issued pursuant to these rules shall require compliance with IDAPA 58.01.11, "Ground Water Quality Rule." (4-7-11)

9. General Permit Conditions

The following general permit conditions are based on the cited rules at the time of issuance and are enforceable as part of this permit. Note that the rules cited in this section, and elsewhere in this permit, are supplemented by the rules themselves. Rules applicable to your facility are enforceable whether or not they appear in this permit.

9.1 Operations

9.1.1 Backflow Prevention

Reuse facilities with existing or planned cross-connections or interconnections between the recycled water system and any water supply (potable or nonpotable) or surface water, shall have backflow prevention assemblies, devices, or methods as required by applicable rule or as specified in this permit and approved by DEQ.

For public water systems, backflow assemblies shall meet the requirements of IDAPA 58.01.08.543. Assemblies shall be adequately maintained and shall be tested annually by a certified backflow assembly tester, and repaired or replaced as necessary to maintain operational status.

For domestic water supply wells, backflow prevention devices shall meet the requirements of IDAPA 07.02.04 and shall be adequately operated and maintained.

Irrigation water supply wells shall meet the requirements of IDAPA 37.03.09.36 for preventing any waste or contamination of the ground water resource. Backflow prevention assemblies or devices used to protect the ground water shall be adequately operated and maintained.

Discharge of recycled water to surface water is regulated by the DEQ Idaho Pollutant Discharge Elimination System (IPDES) program. An IPDES permit is required for any discharge to surface water and backflow prevention shall be implemented to prevent any unauthorized discharge. Backflow prevention assemblies or devices used to protect surface water shall be adequately operated and maintained.

Records of all testable backflow assembly test results, repairs, and replacements shall be kept at the reuse facility along with other operational records, and shall be discussed in the annual report and made available for inspection by DEQ. Other approved means of backflow prevention, such as siphons and air-gap structures that cannot be tested, shall be maintained in operable order.

9.1.2 Restricted to Premises

Wastewaters or recharge waters applied to the land surface must be restricted to the premises of the application site. Wastewater discharges to surface water that require a permit under the Clean Water Act must be authorized by the EPA (IDAPA 58.01.16.600.02).

9.1.3 Health Hazards, Nuisances, and Odors Prohibited

Health hazards, nuisances, and odors are prohibited as follows:

Wastewater must not create a public health hazard or nuisance condition (IDAPA 58.01.16.600.03).

No person shall allow, suffer, cause, or permit the emission of odorous gases, liquids, or solids into the atmosphere in such quantities as to cause air pollution (IDAPA 58.01.01.776.01).

Air Pollution defined as the presence in the outdoor atmosphere of any air pollutant or combination thereof in such quantity of such nature and duration and under such conditions as would be injurious to human health or welfare, to animal or plant life, or to property, or to interfere unreasonably with the enjoyment of life or property (IDAPA 58.01.01.006.06).

9.1.4 Solids Management

Biosolids are the nutrient-rich organic materials resulting from the treatment of sewage sludge. When treated and processed, sewage sludge becomes biosolids that can be safely recycled and applied as fertilizer to sustainably improve and maintain productive soils and stimulate plant growth.

Biosolids generated from sewage sludge are regulated by EPA under 40 CFR Part 503 and require a DEQ approved sludge disposal plan as outlined in IDAPA 58.01.16.650. Contact DEQ before to applying biosolids at any permitted reuse facility.

Sludge is the semi-liquid mass produced and removed by wastewater treatment processes. This does not include grit, garbage, and large solids.

Sludge may be generated by wastewater treatment processes at municipal and industrial facilities. A DEQ-approved sludge disposal plan, as outlined in IDAPA 58.01.16.650, may be required.

Solid waste is any garbage or refuse, sludge from a waste water treatment plant, water supply treatment plant, or air pollution control facility and other discarded material including solid, liquid, semi-solid, or contained gaseous material resulting from industrial, commercial, mining, and agricultural operations and from community activities, but does not include solid or dissolved materials in domestic sewage, or solid or dissolved material in irrigation return flows or industrial discharges that are point sources subject to permits under Section 402 of the Federal Water Pollution Control Act, as amended or source, special nuclear, or by-product material as defined by the Atomic Energy Act of 1954, as amended.

Solid waste does not include inert wastes, manures and crop residues ultimately returned to the soils at agronomic rates, and any agricultural solid waste that is managed and regulated pursuant to rules adopted by the Idaho Department of Agriculture. DEQ reserves the right to use existing authorities to regulate agricultural waste that impacts human health or the environment.

Solid waste is regulated under the "Solid Waste Management Rules" (IDAPA 58.01.06). Wastes otherwise regulated by DEQ (i.e., this permit) are not regulated under IDAPA 58.01.06.

Waste solids include sludge and wastes otherwise regulated by DEQ according with IDAPA 58.01.06.001.03.a.xii. Waste solids may include vegetative waste, silt and mud containing organic matter, and other non-inert solid wastes.

Inert wastes are defined as non-combustible, nonhazardous, and non-putrescible solid wastes that are likely to retain their physical and chemical structure and have a de minimis potential to generate leachate under expected conditions of disposal, which includes resistance to biological attack.

Waste solids require a DEQ approved sludge disposal plan as outlined in IDAPA 58.01.16.650.

9.1.5 Temporary Cessation of Operations and Closure (IDAPA 58.01.17.801)

Temporary cessation of operations and closure must be addressed as follows:

01. Temporary Cessation. A permittee shall implement any applicable conditions specified in the permit for temporary cessation of operations. When the permit does not specify applicable temporary cessation conditions, the permittee shall notify the Director prior to a temporary cessation of operations at the facility greater than sixty (60) days in duration and any cessation not for regular maintenance or repair. Cessation of operations necessary for regular maintenance or repair of a duration of sixty (60) days or less are not required to notify the Department under this section. All notifications required under this section shall include a proposed temporary cessation plan that will ensure the cessation of operations will not pose a threat to human health or the environment. (4-7-11)

02. Closure. A closure plan shall be required when a facility is closed voluntarily and when a permit is revoked or expires. A permittee shall implement any applicable conditions specified in the permit for closure of the facility. Unless otherwise directed by the terms of the permit or by the Director, the permittee shall submit a closure plan to the Director for approval at least ninety (90) days prior to ceasing operations. The closure plan shall ensure that the closed facility will not pose a threat to human health and the environment. Closure plan approval may be conditioned upon a permittee's agreement to complete such site investigations, monitoring, and any necessary remediation activities that may be required. (4-7-11)

9.1.6 Plan of Operation (IDAPA 58.01.17.300.05)

The PO must comply with the following:

05. Reuse Facility Operation and Maintenance Manual or Plan of Operations. A facility's operation and maintenance manual must contain all system components relating to the reuse facility in order to comply with IDAPA 58.01.16 "Wastewater Rules," Section 425. Manuals and manual amendments are subject to the review and approval provision therein. In addition to the content required by IDAPA 58.01.16.425, manuals for reuse facilities shall include, if applicable: operation and management responsibility, permits and standards, general plant description, operation and control of unit operations, land application site maps, wastewater characterization, cropping plan, hydraulic loading rate, constituent loading rates, compliance activities, seepage rate testing, site management plans, monitoring, site operations and maintenance, solids handling and processing, laboratory testing, general maintenance, records and reports, store room and inventory, personnel, an emergency operating plan, and any other information required by the Department. (4-7-11)

9.1.7 Reserved.

9.1.8 Ground Water Quality Rule (IDAPA 58.01.11)

The permittee shall comply with the requirements of the "Ground Water Quality Rule" (IDAPA 58.01.11).

9.2 Administrative

Requirements for administration of the permit are defined as follows.

9.2.1 Permit Modification (IDAPA 58.01.17.700)

01. Modification of Permits. A permit modification may be initiated by the receipt of a request for modification from the permittee, or may be initiated by the Department if one (1) or more of the following causes for modification exist: (4-7-11)

a. Alterations. There are material and substantial alterations or additions to the permitted facility or activity which occurred after permit issuance which justify the application of permit conditions that are different or absent in the existing permit. (4-7-11)

b. New standards or regulations. The standards or regulations on which the permit was based have been changed by promulgation of amended standards or regulations or by judicial decision after the permit was issued. (4-7-11)

c. Compliance schedules. The Department determines good cause exists for modification of a compliance schedule or terms and conditions of a permit. (4-7-11)

d. Non-limited pollutants. When the level of discharge of any pollutant which is not limited in the permit exceeds the level which may cause an adverse impact to surface or ground waters. (4-7-11)

e. To correct technical mistakes, such as errors in calculation, or mistaken interpretations of law made in determining permit conditions. (4-7-11)

f. When a treatment technology proposed, installed, and properly operated and maintained by the permittee fails to achieve the requirements of the permit. (4-7-11)

9.2.2 Permit Transferable (IDAPA 58.01.17.800)

01. General. A permit may be transferred only upon approval of the Department. No transfer is required for a corporate name change as long as the secretary of state can verify that a change in name alone has occurred. An attempted transfer is not effective for any purpose until approved in writing by the Department. (4-7-11)

9.2.3 Permit Revocation (IDAPA 58.01.17.920)

01. Conditions for Revocation. The Director may revoke a permit if the permittee violates any permit condition or these rules, or the Director becomes aware of any omission or misrepresentation of condition or information relied upon when issuing the permit. (4-7-11)

02. Notice of Revocation. Except in cases of emergency, the Director shall issue a written notice of intent to revoke to the permittee prior to final revocation. Revocation shall become final within thirty-five (35) days of receipt of the notice by the permittee, unless within that time the permittee requests an administrative hearing in writing. The hearing shall be conducted in accordance with IDAPA 58.01.23, Rules of Administrative Procedure before the Board of Environmental Quality.” (5-3-03)

03. Emergency Action. If the Director finds the public health, safety or welfare requires emergency action, the Director shall incorporate findings in support of such action in a written notice of emergency revocation issued to the permittee. Emergency revocation shall be effective upon receipt by the permittee. Thereafter, if requested by the permittee in writing, the Director shall provide the permittee a revocation hearing and prior notice

thereof. Such hearings shall be conducted in accordance with IDAPA 58.01.23, "Rules of Administrative Procedure Before the Board of Environmental Quality." (3-15-02)

04. Revocation and Closure. A permittee shall perform the closure requirements in a permit, the closure requirements of these rules, and complete all closure plan activities notwithstanding the revocation of the permit. (4-7-11)

9.2.4 Violations (IDAPA 58.01.17.930)

Any person violating any provision of these rules or any permit or order issued thereunder shall be liable for a civil penalty not to exceed ten thousand dollars (\$10,000) or one thousand dollars (\$1,000) for each day of a continuing violation, whichever is greater. In addition, pursuant to Title 39, Chapter 1, Idaho Code, any willful or negligent violation may constitute a misdemeanor. (4-1-88)

9.2.5 Severability

The provisions of this permit are severable, and if a provision or its application is declared invalid or unenforceable for any reason, that declaration will not affect the validity or enforceability of the remaining provisions.

10. Other Applicable Laws

DEQ may refer enforcement of the following provisions to the state agency authorized to enforce that rule. The permittee shall comply with all applicable provisions identified in this section. Compliance with this permit does not relieve the permittee from applicable requirements in other federal, state, and local laws, statutes, and rules.

10.1 Owner Responsibilities for Well Use and Maintenance

10.1.1 Well Use

The well owner must not operate any well in a manner that causes waste or contamination of the ground water resource. Failure to operate, maintain, knowingly allow the construction of any well in a manner that violates these rules, or failure to repair or properly decommission (abandon) any well as herein required will subject the well owner to civil penalties as provided by statute. See IDAPA 37.03.09.036.01 and consult the Idaho Department of Water Resources (IDWR) for more information.

10.1.2 Well Maintenance


The well owner must maintain the well to prevent waste or contamination of ground waters through leaky casings, pipes, fittings, valves, pumps, seals, or through leakage around the outside of the casings, whether the leakage is above or below the land surface. Any person owning or controlling a noncompliant well must have the well repaired by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.02 and consult IDWR for more information.

10.1.3 Wells Posing a Threat to Human Health and Safety or Causing Contamination of the Ground Water Resource


The well owner must have any well shown to pose a threat to human health and safety or cause contamination of the ground water resource immediately repaired or decommissioned (abandoned) by a licensed well driller under a permit issued by the IDWR director according to the applicable rules. See IDAPA 37.03.09.036.06 and consult IDWR for more information.

11. Site Maps

11.1 Regional Map



11.2 Facility Map



11.3 Process Flow Diagram

